

Electrical Safety Guide

Approved worker rules and site regulations from the SentinelLoop knowledge base. These instructions support factory safety practice. They do not replace trained emergency responders or a competent person's isolation and repair work.

Immediate worker actions

1. Keep away from exposed wires, sparks, smoke, or damaged electrical equipment.
2. Do not touch the damaged equipment, cables, or nearby metal parts.
3. Warn nearby workers to stay away from the dangerous area.
4. Stop using the equipment only if this can be done without approaching the hazard.
5. Keep water and wet materials away from the electrical danger.
6. Report the hazard immediately through the site safety process.
7. Keep the area clear until it is made safe.

Site regulations

1. Only authorized electrical personnel may isolate, inspect, test, or repair electrical systems.
2. Do not restore power until a competent person confirms isolation and the area is safe.
3. Electrical rooms, panels, and substations must stay locked and access-controlled.
4. Keep a clear approach in front of every distribution board and control panel.
5. Do not store tools, pallets, drums, or combustible materials in electrical rooms.
6. Damaged cords, cracked plugs, missing covers, and overloaded sockets must be taken out of use.
7. Temporary wiring is not a substitute for a permanent, inspected supply.
8. Work on or near live parts is prohibited unless you are trained, authorized, and protected.
9. Report buzzing, burning smell, overheating, tripping breakers, or flickering lights at once.
10. Outdoor or wet-area equipment must be treated as higher risk until confirmed dry and intact.

Worker duties

1. Treat every unknown cable as live until a competent person says otherwise.
2. Use only inspected tools and PPE assigned for electrical work.
3. Do not wear metal jewellery or wet clothing when near exposed conductors.
4. Follow lock-out and tag-out instructions posted by the electrical team.
5. Stay at a safe distance from overhead lines, transformers, and welding supplies.
6. Guide visitors and contractors away from the electrical hazard until it is controlled.

Prohibited actions

1. Do not attempt DIY repairs, jumper connections, or bypassing of safety devices.

2. Do not use water, foam, or wet cloths on electrical fires or live equipment.
3. Do not pull cables, open panels, or reset breakers unless you are authorized.
4. Do not leave an electrical hazard unmarked or unreported at shift change.

Always follow instructions from trained safety or emergency personnel.