U.S. DEPARTMENT OF ENERGY

Electricity Delivery & Energy Reliability

NASPI North American SynchroPhasor Initiative

American Recovery and Reinvestment Act of 2009

# Synchrophasor Technology and Renewables Integration

## NASPI Technical Workshop

## June 7, 2012

NASPI Synchrophasor Technical Report

SMARTGRID.GOV RECOVERY ACT SMART GRID PROGRAMS

www.naspi.org



# NASPI Synchrophasor Technical Report
# Renewables Integration with Synchrophasors
# NASPI Technical Workshop

## June 7, 2102 Workshop
## Technical Summary

Context

This technical material was developed in June 2012 by the North American SynchroPhasor Initiative (NASPI). NASPI is a collaboration between the North American electric industry (utilities, grid operators, vendors and consultants), the North American Electric Reliability Corporation, academics, and the U.S. Department of Energy, to advance and accelerate the development and use of synchrophasor technology for grid reliability and efficiency. The material attached was produced for one of a series of NASPI technical workshops intended to educate and document the stakeholder community on the state of the art for key synchrophasor technology issues.

For this workshop NASPI partnered with the National Renewable Energy Laboratory to explore the use of synchrophasor technology to enhance the integration of renewable generation.

Synchrophasor technology was developed thanks to early research efforts by the U.S. Department of Energy and Bonneville Power Administration in the 1990s. With recognition that synchrophasor technology -- high-speed, wide-area, time-synchronized grid monitoring and sophisticated analysis -- could become a foundational element of grid modernization for transmission system, the Department continued and expanded its investment and industry partnership in the areas of synchrophasor measurement devices, communications, applications, measurements, and technical interoperability standards.

In 2009, the Department committed a total of $412 million of funds from the American Recovery & Reinvestment Act of 2009 to twelve Smart Grid Investment Grants and one Smart Grid Demonstration Project that implemented and tested synchrophasor

technology using matching private funds. While some of the ARRA funds was spent on other transmission assets, in aggregate over $328 million of federal and matching private investment was spent on synchrophasor technology and related communications networks.

Additionally, DOE has funded significant technical assistance for NASPI and synchrophasor advancement through the National Laboratories and the National Institute for Standards & Technology.

NASPI serves as a forum for information-sharing and problem-solving among the synchrophasor projects and stakeholders. Much of the work and insights reflected in this technical workshop was enabled by individuals and companies funded by DOE's on-going research and development projects and the ARRA investments. Thus it is appropriate to recognize the insights and work product documented in this workshop and technical report as one of many consequences and work products resulting from the federal Smart Grid investments. Therefore, the Department joins NASPI in re-releasing this material to the smart grid community to document additional impacts and value realized from the federal Smart Grid investments in synchrophasor technology.

The purpose of the Renewables Integration Workshop

In the on-going effort to improve grid reliability for the North American bulk electric system, this workshop looked at how renewable generation can be increased, while protecting grid reliability, using synchrophasor technology. Synchrophasor technology is the most significant control center data improvement tool introduced in the last decade. Additionally, synchrophasor data offers unprecedented insight into the interaction between generators and the bulk power system, enabling sophisticated engineering analysis that can improve grid design and protection.

This workshop was the first opportunity for members of the renewables community to meet with electric system operators and synchrophasor experts to explore how this technology can be used to enhance renewables integration.

This technical report includes the following elements:

1. The workshop summary, prepared by Alison Silverstein (project manager for NASPI), YC Chang (NREL) and David Corbus (NREL).
2. The agenda for the workshop.
3. All of the presentations made by workshop participants.

It is worth noting that since the workshop was held, there has been a significant increase in the number of phasor measurement units deployed on the grid (most installed by participants in the Smart Grid Investment Grants) and in the availability of analytical applications using synchrophasor data for real-time grid operations and engineering analysis. Much of this further progress has been documented in presentations at NASPI meetings (see www.naspi.org/meetings) and in trade and technical press, and much more has been done since then using synchrophasor technology to support the expansion and integration of renewable generation.

# NASPI-NREL
# SYNCHROPHASOR TECHNOLOGY AND RENEWABLES INTEGRATION WORKSHOP
## Hyatt Regency Denver Tech Center
## Grand Mesa Room
## Denver, CO

## JUNE 7, 2012
## 8:30am – 12:00pm

On the day after the North American SynchroPhasor Initiative meeting (on June 5-6 at the Hyatt Regency Denver Tech Center), this workshop will bring together electric industry synchrophasor experts, utility and RTO-ISO leaders at the forefront of renewables use, and NREL experts on renewable energy development and integration. The goal of the workshop is to find opportunities to share and leverage information and insights in each community in ways that advance and accelerate renewables use and grid reliability with phasor technology.

Format – very short presentations in panel format for show-and-tell portions, followed by facilitated discussion on focused topics

Meeting registration -- NASPI NREL Workshop Registration

## AGENDA (speaker confirmations on-going)

8:30 am Introductions

8:45 am Introduction to synchrophasor technology – Jeff Dagle (PNNL)

8:55 am Challenges – Dave Corbus (NREL), Kara Clark (NREL), Mike McMullen (MISO), Bob Zavadil (Enernex), John Adams (ERCOT), Karen Forsten (EPRI)
Charlie Smith (UVIG) -- moderator

- Magnitude of renewables on-line today and coming (5 minutes)
- Key characteristics of variable generation that create challenges for grid operation (10 minutes)
- What do we know now about integrating renewables?
- What do we not know yet that we want to figure out?

- What renewable integration problems are being worked on that phasor data could help solve?
- What insights or projects do renewables research folks have that could be useful for phasor experts trying to support operations people?
- Discussion

9:40 am Break

10:00 am Tools -- Austin White (OG&E), Mike McMullen (MISO), Louis Signoretty (Alstom), Yingchen Zhang (NREL), Jason Banks (NREL), John Adams (ERCOT)
Alison Silverstein (NASPI) -- moderator

- What synchrophasor tools are we using now?
- What synchrophasor tools do we need or want but don't have yet?
- What renewable integration tools and methods are now being used that phasor data could make better?
- Discussion

11:30am Next steps
Alison Silverstein (NASPI) & Dave Corbus (NREL) -- moderators

12:00 pm Adjourn

**Topics we expect to come up:**

- Phasor-data-based grid monitoring and state estimation
- Fault location
- Real-time monitoring of primary frequency
  - determination of variable generation impacts on primary frequency and inertia
  - oscillation detection and damping
  - assessing real-time inertia
- Active, automated control of wind and solar plants using PMU data collection and feedback
- Real-time monitoring, switching and controls for plant-side and grid-side equipment
  - Storage devices
  - Power electronics, SMES, DSMES, SVCs
  - Switches
- Available Transmission Capacity determination, dynamic line ratings and congestion management using both real-time monitoring and dynamic controls
- Monitoring and screening renewable energy "events" using phasor data

- Equipment and control diagnostics on renewable plants and on plants providing primary frequency response (e.g., stabilizers)
- Voltage monitoring of renewable energy systems using PMUs
- Model validation for renewable energy plants (units v. plants)
- Improving wind and solar forecasting
- Operations prediction – what actions can operators take to resolve problems identified by the tools above?

**WORKSHOP COORDINATORS**

- Alison Silverstein, NASPI Project Manager -- alisonsilverstein@mac.com
- Dave Corbus, NREL Program Manager, Electric Systems – david_corbus@nrel.gov

If you are interested in the NASPI Work Group meeting that will be held on June 5-6, the meeting agenda is posted at NASPI Work Group Meeting Registration

# NASPI- NREL Synchrophasor Technology and Renewable Integration Workshop
# Summary

Denver, CO !

June 7, 2012 !

**Opening remarks by Alison Silverstein (project manager for the North American Synchrophasor Initiative) and greetings by Dave Corbus (Lab program manager for electricity systems, National Renewable Energy Laboratory)**

The goal of this workshop is to bring two groups together to share and leverage information and insights in each community in ways that advance and accelerate renewables use and grid reliability with phasor technology. System operators will explain their needs and others will explain the tools they have and need that the renewable researchers and synchrophasor community might be able to develop to help address those needs.

In Panel 1, representatives who manage and study grid operations will review the challenges entailed in operating a grid with high levels of renewable generation; in Panel 2, several grid operators offer suggestions for how to use synchrophasor-based tools to improve grid operations and renewable integration. At the end of each panel, and at the close of the workshop, the 80-member group offered comments, observations, responses, and suggestions for further work.

NASPI and NREL thank all of the workshop speakers and audience members for their contributions and participation in this unprecedented discussion.

**Panel 1: Challenges**

*Charlie Smith (UVIG)*

- Magnitude of renewables (wind and solar) on-line equals 40-50GW in U.S., 250GW world-wide
- U.S. had 300GW of renewables in interconnection queues as of June 2012
- Variable generation: variability and uncertainty.

*Kara Clark (NREL)*

- Characterizing the extent of uncertainty and variability
- Spatial and temporal diversity can temper variability
- Means to cope with uncertainty: forecasting, reserves, increased flexibility of wind and other generators (ramp rate, fast scheduling/dispatch), operational procedures, balancing area coordination, storage and demand response, better use of transmission

*Mike McMullen (MISO)*

- High wind penetration in the Dakotas and Minnesota. 11GW across several generation areas with several transient stability-limited interfaces.
- Transient stability software solve every 45 minutes for stability assessment (critical contingency calculation); high levels of wind generation make transient stability analysis harder.
- PMU and real-time data can be used for the management of wind assets (real time angle calculation) and on-line system stability assessment

*Bob Zavadil (Enernex)*

- Over the last 10-15 years we have learned how to make wind plants perform like a regular plant in terms of volt/var output.
- Years of work have been done on wind plant dynamic modeling, but vendors treat wind plant model as proprietary. The wind community is working on generic PSS/E, PSLF models which assume 10 sec dynamic performance under constant wind speed.
- Installation of PMUs at each turbine is not practical. Each wind facility needs to have POI monitoring. Wind plant modeling based on point of interconnection metering is essential to improve models of aggregate wind generator behavior.
- Measurements requirement: cycle by cycle, not filtered. Large amount of data will bring a greater analytical burden and requires better data management. There are analytical challenges re asymmetrical events.
- We need to figure out small signal behavior.
- Using markets and newer technology to mimic the behavior of conventional generation to make wind more reliable and predictable as compared to conventional generation
- Are there existing procedures for model validation? How will NERC MOD 26 & 27 be implemented by renewables?

*Charlie Smith (UVIG)*

- See NERC IVGTF activities with respect to grid codes, especially task 1.3 (interconnection requirement) and task 1.7 (reconciliation of ride-through requirement and drop-out requirement)

*John Adams (ERCOT)*

- With higher wind penetration, ERCOT is seeing sub-synchronous resonance affecting other frequencies and other generators. Electromagnetic resonance effects are not just on large shaft generators or series-compensated transmission lines.
- There are voltage oscillations in low fault duty ratio driven by wind farm reactive controls. We need better reactive coordination among wind plants.
- Needs for better modeling of wind collector systems and interconnection studies with regards to wind generation, especially in areas with light offsetting load and transmission, to figure out what frequency ranges we should be worrying about.
- Modeling wind generation is a concern because of sub-synchronize resonance phenomenon. We need look into frequencies other than 60Hz in the PSCAD

electromagnetic model to decide which frequency range is a concern. Feedback loops in control systems makes modeling problem harder
- There are primary frequency response issues and frequency deviations caused by new wind plants.
- There is significant ramping related to wind plants, limits need to be put on CPS-1 performance to manage ramping.

*Dave Corbus (NREL)*
- Lots of high renewable penetration: Puerto Rico high solar with low system inertia and primary frequency response. Also Hawaii has high wind and solar, Ireland has high wind. But wind plants can provide primary frequency response.
- How can we use phasor technology to address the challenges? Real-time monitoring of frequency. Determine the grid impact of renewables on inertia and primary frequency response. Detect oscillation and low damping. Calculate real time inertia.
- Perform active and automated control of wind and solar plants using PMU data, model validation and untapped capabilities of wind generation for grid support.
- Testing these capabilities at NREL's National Wind Technology Center (NWTC).

*Alison Silverstein (NASPI) for Dmitry Kosterev (BPA)*
- There is 9,900MW of highly concentrated wind penetration, particularly in central Idaho and western Oregon/Washington State.
- Challenges: wind model validation (type 2 wind turbines), voltage control (type 1 and 2 turbines don't have voltage control and can cause problems, type 3 and 4 turbines have the ability for voltage control but it's not always enabled), wind hub voltage control coordination (several plants have the same point of interconnection, effective reactive power sharing, operating in droop mode), dynamic transfer (because of ramping of wind generation, power from conventional plant need to transfer via stability-limited path).

*Audience Responses*
- Classic controllable generation model versus variable/ungoverned generation sources, how can renewables interact with the classic generation sources?
- Wind plant modeling -- should every turbine be modeled and with all permutations of on/off state etc. for each generator within a plant? Single machine wind plant models compared against more complex multi-machine or statistical models. EPRI is working along these lines.
- PNNL model calibration and validation, looking into wind power solutions, classical governor-based models compared against wind power inputs.
- Advanced wind modeling can require resolution higher than once per cycle output offered by PMUs, approaching waveform capture and similar PQ metering methods. Improving wind plant modeling based on this data.
- System operation continues as this on-going wind research is being done.

**Panel 2: Synchrophasor-based tools for managing high levels of renewables**

*Austin White (OG&E)*

- Wind integration (1GW) at Oklahoma Gas and Electric and associated induced oscillations. Using FFT-based tool to automatic detect oscillations. Use it to manage/curtail wind plants that are creating oscillations.
- Some observed event examples (LVRT)

*Mike McMullen (MISO)*

- Using synchrophasor tools to increase situational awareness with wide-area visualization for operators.
- Using phasor data to improve state estimation, perform angle difference analysis, transient stability analysis.
- Need these tools to solve faster.

*Louis Signoretty (Alstom)*

- We need measurement-based applications, including wide-area measurement systems using phasor data, to improve visibility into remote wind generation.
- Alstom has different tool sets that concentrate on transmission level and distribution level.
- Transmission: Long transmission lines to transport wind energy is a challenge. PMU based application, model based application plus forecasting capability will provide solution. Example: UK, PMU is used to increase visibility.
- Distribution: Lots of distributed generators are not monitored. We should use PMUs and active management at the distribution feeders, with minimum communications requirements, to enhance and increase local generation with minimal impact.

*John Adams (ERCOT)*

- There are two barriers to phasor technology adoption. The first is the security issue, which raises the degree of difficulty and cost.
- Bandwidth limitation is also a concern. ERCOT is hitting bandwidth limits on communications, and encryption requirements make this harder.
- The second barrier is, how should system operators respond when they see a problem? We need to understand phasor data and present the information effectively to the system operators in a way that tells them effective options for action.
- ERCOT is currently relying on N-1 analysis but that does not tell you whether the system is stable. The historic voltage stability tools are thermal limit-oriented and don't assume a fault at the time of outage, so we need to figure out new tools for system stability assessment.

*Ying-Chen Zhang (NREL)*

- New NERC frequency response standard doesn't distinguish between generator types in terms of intertia and frequency response requirements. Renewable generation frequency response is currently investigated by the team of NREL, EPRI and ERCOT.
- Transient stability tools are still model-based. Model validation is essential because even the transient analysis tools are partially model based. NREL is working on renewable generation model validation using PMU data.
- NREL has done extensive work of renewable integration based on production cost simulations.
- Active control and voltage control of wind plant need feedback from fast measurement such as PMUs.
- Current production tools that could use phasor data include:
    - real-time monitoring (but that doesn't look deeply at angle differences between the wind facility and the system).
    - State estimation isn't fast enough yet, not yet synchronized.
    - Transient stability analysis tools (VSAT and DSA), GIS, unit dispatch could use PMU signal to increase visibility, stability assessment and management of renewables.
    - For PSSE and PSLF, can we use actual phasor measurements to inform operations planning and long-term planning?
    - Link phasor data with Geographic Information Systems?

*Jason Bank (NREL)*

- Dynamic modeling at the distribution level is in its infancy. It has a similar network structure to the PMU and phasor communications network, and we could use high resolution PMUs and power quality monitors at the distribution level in large numbers to collect data on distribution-level loads and generation.
- Use these data to inform advanced inverter and distribution (PV) dynamic modeling.
- Associated visualization applications

*John Adams (ERCOT)*

- The tools that are already used in production: visualization (map and angle difference display), FFT analysis and modal analysis. CAISO has an example of detecting control system failure at a power plant.

*Audience Responses*

- PMU can be used for protection but in a supervisory scheme.
- Use PMU at the point of interconnection and PV side to detect islanding and trip-off.
- RIM and Gridlab-D from PNNL for renewable modeling and distribution level modeling
- Going past N-1 security criteria
- Transient limits and the impact of phasors
- Calibration of the developed phasor tools against the existing system to avoid false positives and other nuisance alarming

- Integration of phasor data with DEW (or other distribution modeling packages) particularly with distribution-level phasor measurements. This is something that has already been done to an extent at NREL.

***Whole Group Lightning Round***

- Continuous feedback and control for phasor/PMU data with renewable generation
- Better models of all generation possible using phasor data, including renewable/variable generation sources
- Feedback from operators on vendor tools such as dynamic analyzer
- Use phasor data to characterize nomograms and identify system operating limits – how much margin is necessary? EPG has used phasor data to set up a dynamic nomogram.
- PJM has lots of phasor and renewables data and invites others to help analyze them
- Mehtatech makes devices that produce point-on-wave and phasor data.
- We need better tools for phasor data mining and analysis
- What are the data handling needs that we (Grid Protection Alliance) can help you solve?
- Redefine the operation of the power system based on results from PMU data collection and model validation
- Phasor data lets us look at the power system very differently – we need to look at primary frequency response impacts from loads as well as generation.
- Better operator tools which recommend immediate solutions, not just display data and show more problems.
- There are institutional problems with putting PMUs on generator terminals.
- Worthwhile to understand what type of data is available and develop applications based on those data.
- Model validation needs to go beyond renewables. Can we develop improved simulators to effectively simulate the whole system using system-level measurements and analysis?
- Most SEL relays and reclosers are PMU function-capable and can be given control capabilities.
- We need to solve critical infrastructure protection issues with respect to phasor systems.
- Need N-1 instability detector and control failure detector.
- Design electric markets to better monetize and use renewable sources
- PMUs enable dynamic line ratings that could let us reduce wind curtailments.
- Data sharing and model sharing are needed not only among utilities but also with the research community. How do we make it safe for utilities and manufacturers to share their data?
- We need to use phasor data to make wind and renewables more controllable, especially for interial ramping – we should bring the inverter manufacturers into this discussion.
- We need policy support to continue and broaden PMU deployments

- Test case and demos related to renewable integration
- NASPI needs to continue education, training and spreading value messages
- Research toward distribution-level PMUs and distribution-level renewables – once we have more zero net energy homes, we'll need to be able to manage distributed generation more effectively.
- What can power electronics do in the future to solve some of these issues? Interaction with current modeling regimes?
- If you have a grid event, you should share the data and findings about the problems encountered with the rest of the power and research communities.

Alison Silverstein (NASPI)
YC Zhang (NREL)
Dave Corbus (NREL)

Pacific Northwest
NATIONAL LABORATORY
Proudly Operated by Battelle Since 1965

# Introduction to Synchrophasor Technology

## NASPI-NREL Synchrophasor Technology and Renewables Integration Workshop

## June 7, 2012

Jeff Dagle, PE
Chief Electrical Engineer
Advanced Power and Energy Systems
Pacific Northwest National Laboratory
(509) 375-3629
jeff.dagle@pnnl.gov

# Wide Area Measurement System (WAMS)



Data acquisition devices (continuously recording and time synchronized)

- Phasor Measurement Units (PMU)
  - Inputs from potential transformers (PT) and current transformers (CT)
- Analog signal recorders (with transducer inputs)
- Point-on-wave (POW) recorders (with PT, CT inputs)
- Controller monitors (generators, HVDC, FACTS)
  - Inputs from the controller interface or the controlled device
- Advanced relays and other Intelligent Electronic Devices (IED)
- Digital fault recorders and other sequence of events recorders

Generally **NOT** supervisory control and data acquisition (SCADA), typically a polling architecture that does not collect time-synchronized measurements (time stamps applied when the signals are logged into the energy management system at the control center)

# Lessons Learned from August 10, 1996

Pacific Northwest NATIONAL LABORATORY
Proudly Operated by Battelle Since 1965

## Data captured from WAMS was essential to support the blackout investigation




## The need for better model validation was demonstrated



# North American SynchroPhasor Initiative

Pacific Northwest NATIONAL LABORATORY
Proudly Operated by Battelle Since 1965

***DOE and NERC are working together closely with industry to enable wide area time-synchronized measurements that will enhance the reliability of the electric power grid through improved situational awareness and other applications***

**April 2007**




**March 2012**




**"Better information supports better - and faster - decisions."**

NASPI North American SynchroPhasor Initiative

NERC NORTH AMERICAN ELECTRIC RELIABILITY CORPORATION

# NASPI Organization





# NASPI Work Group Meetings: 2009-2011

Pacific Northwest NATIONAL LABORATORY
Proudly Operated by Battelle Since 1965

| Date | Location | Meeting Themes |
|---|---|---|
| February 4-5, 2009 | Scottsdale, Arizona | Networking and cyber security |
| June 3-4, 2009 | Sacramento, California | Operations and success stories |
| October 7-8, 2009 | Chattanooga, Tennessee | Vendor showcase |
| February 24-25, 2010 | Austin, Texas | Recovery Act projects, technology specifications, intermittent generation |
| June 8-9, 2010 | Vancouver, Canada | International activities and baselining |
| October 5-6, 2010 | Arlington, Virginia | Recovery Act project updates |
| February 23-24, 2011 | Fort Worth, Texas | Technical standards and vendor showcase |
| June 8-9, 2011 | Toronto, Ontario | Success stories |
| October 12-13, 2011 | San Francisco, California | Recovery Act project updates |

# NASPI Work Group Meetings: 2012

Pacific Northwest NATIONAL LABORATORY
Proudly Operated by Battelle Since 1965

| Date | Location | Meeting Themes |
|---|---|---|
| Feb. 29-March 1, 2012 | Orlando, Florida | Research initiatives and application training sessions |
| June 6-7, 2012 | Denver, Colorado | Success stories and vendor show |
| October 17-18, 2012 | Atlanta, Georgia | Recovery Act project updates |

# REAL-TIME SYNCHROPHASOR APPLICATIONS AND THEIR PREREQUISITES

Pacific Northwest NATIONAL LABORATORY
Proudly Operated by Battelle Since 1965




## Prerequisites

| | | | | | |
|---|---|---|---|---|---|
| **ANALYSIS** | Good data collection | Interconnection-wide baselining | Pattern detection | Model validation – system & elements | System studies |
| **COMMUNICATIONS** | Interoperability standards | High availability, high speed | Appropriate physical & cyber-security | Redundant, fault-tolerant | |
| **USERS** | Familiarity | | Good visual interface | Training | |

# Technology Maturation Progress



- Sharing users' and vendors' success stories and high-value applications
- Accelerating development of technical interoperability standards
- Focusing and facilitating baselining and pattern recognition research (e.g., oscillation detection) and other R&D
- Early identification of project implementation challenges and community work to develop and share solutions
  - Develop and test PMU device specifications and interoperability
  - Communications network design
  - PMU placement
  - End-to-end data flow and quality
  - Developing requirements for "production-grade" systems
  - Building key software infrastructure (NERC GPA investment)
  - Enhance applications value and operator and user training
  - On the horizon – more technical standards; cyber-security and GPS

# The NASPInet Vision –
## A Distributed Network for Data Exchange and Sharing

Pacific Northwest NATIONAL LABORATORY
Proudly Operated by Battelle Since 1965



# NASPI Application Classification



| *Class* | *Basic Description* | *Sampling/ Data Rate* | *Required Latency* |
|---|---|---|---|
| A | Feedback Control | Fast | Fast |
| B | Open Loop Control | Medium | Medium |
| C | Visualization | Medium | Medium |
| D | Event Analysis | Fast | Slow |
| E | Research/Experimental | N/A | N/A |

***Security requirements are a function of the application***

# Security of Synchrophasors



- Synchrophasors are becoming part of the bulk electric system and will require physical and cyber security
  - ***But these systems shouldn't be treated any differently than other forms of measurement and control telemetry***
- Synchrophasor systems will coexist with other bulk electricity system (BES) cyber infrastructure and will have similar dependencies on common communications and network elements
- System designers and owners are leveraging emerging cyber-security standards and technologies
- Currently available phasor applications require further data analysis, software refinement and operational validation to be fully effective; many are in advanced development and testing and are not in full operational use
  - Therefore, many of these systems are not currently considered critical cyber assets
- Due to nature of continuous, high-volume data flows, new technology will likely be required for measurement, communications, and applications
  - Technology anticipated to undergo rapid change and refinement over the next several years

# Conclusions



- DOE has played a key catalyst role in the development and implementation of synchrophasor technology
- DOE and NERC will continue to support industry efforts to promote and enable widespread adoption of advanced monitoring technologies to ensure grid reliability
- DOE will actively support needed R&D to ensure that the full value of a North American phasor network will be realized
  - ***Hardware*** – measurement technologies
  - ***Network*** –data access and security
  - ***Software Applications*** – focus on reliability management objectives
  - ***Demonstrations*** – regional in scope
- Recovery Act is enabling unprecedented advancement of synchrophasor technology deployment

# http://www.naspi.org/

# RE Integration and PMUs- How can we use synchrophasors

- **Real-time monitoring of primary frequency**
  - **determination of variable generation impacts on primary frequency and inertia**
  - **oscillation detection and damping**
  - **assessing real-time inertia**
- **Active, automated control of wind and solar plants using PMU data collection and feedback**

# 56% Power Penetration Example in PSCo



# Wind Power to Provide PFR









# Wind Power to Provide Secondary Reserve

## Operation with 10% reserve






# RE Integration and PMUs

- **Voltage monitoring of renewable energy systems using PMUs**
- **Model validation for renewable energy plants (plants not turbine)**
- **Operations prediction – what actions can operators take to resolve problems identified by the tools above?**

# Some Issues Not Specific to RE

- Fault location
- Available Transmission Capacity determination, dynamic line ratings and congestion management using both real-time monitoring and dynamic controls
  - Wind conditions cool lines for more ATC
- Equipment and control diagnostics on renewable plants and on plants providing primary frequency response (e.g., stabilizers)

# Renewable Plant Model Validation with Synchrophasor Data

NASPI-NREL *

**SYNCHROPHASOR TECHNOLOGY AND RENEWABLES INTEGRATION WORKSHOP** (

June 7, 2012

Denver, CO *

Robert Zavadil
Executive Vice President
620 Mabry Hood Road, Suite 300
Knoxville, Tennessee 37932
Tel: (865) 218-4600 ex. 6149
bobz@enernex.com
www.enernex.com

# Objectives of Presentation

- Apprise PC of some ongoing activities related to development of planning models for bulk wind plants
- Convey progress and status regarding model validation
- Solicit input and advice from PC

# Why?

- >50 GW of bulk wind and PV installed
- Increasing emphasis on validation of models for BES
- Novel generation technologies for wind and solar pose new challenges
- Model needs for bulk renewable plants
  - $Planning: PSS/E, PSLF; ~ 10 Hz bandwidth; utilized for stability and other dynamic studies (has received most of the attention to date)
  - $Operating: On-line security assessment; “look-ahead” simulations that may include dynamic or pseudo-dynamic behavior

# How? %

- Validation of as-built plant using recorded disturbance data at POI is likely the best route
  - ) Validation may be required for each plant
  - ) Other methods more complicated, expensive
- Requires monitoring at POI for each facility
- Most existing renewable plants do not have disturbance monitoring at present



# Questions/Issues/Challenges 0

- Measurement requirements
- Monitor deployment
- Clerical and analytical burden
  - *Managing data
  - *Identifying appropriate disturbances for validation
  - *Performing analysis, adjusting models
- Are there existing processes for validating models on an ongoing basis?
- How will NERC Mod 26 and 27 be implemented by REs? *

# ERCOT Operational concerns with Wind Energy

**John Adams**
**Principal Engineer**
**Electric Reliability Council of Texas**

**June 7, 2012**

# Operational Challenges for Wind Integration

- Uncertainty
- Variability
- Interconnection




Average hour-ahead wind forecast error is significant (MAPE is ~7%)




MW errors may be high (>1000 MW; occasionally >2000 MW)



# Primary Frequency Response

- All generation in ERCOT is required to provide governor response with a 5% droop setting
- Wind farms were recently required to provide primary frequency response to frequency deviations from 60 Hz.



# Generation Ramps



# Interconnection-Related Requirements

- Inverter-connected resources may not fit with traditional technical requirements

- **Static and dynamic reactive capability**
- **Voltage-ride through capability**
- **Modeling**
  - Collector system and support device modeling
  - Dynamic model and parameters
- **Reactive coordination** in CREZ area
- **Voltage Oscillations** in low fault duty ratio areas
  - ERCOT has observed voltage oscillations driven by wind farm reactive controls in areas with low fault duty ratio.
- Operational Concerns – **Sub Synchronous Resonance** with Series Compensated Transmission lines

# ERCOT Synchrophasor observed voltage event near wind turbine



# Questions

# Wind Farm Oscillations

- Only during high winds
- FFT analysis shows 12-14Hz
- Voltage fluctuations as high as 5%
- Determined it is a problem at different wind farms with the same turbine model
- Manufacturer has resolved the problem with new converter parameters
- Some turbines were reverting back to default parameters






# FFT Detection Program

- Performs an FFT on a sliding window of 256 samples
- Sends email or text message when the oscillations reach an objectionable level
- Almost 8 hours of oscillations detected



# SCADA vs Synchrophasors

- Black trace shows the voltage magnitude reported by SCADA
- Red trace shows the synchrophasor data
- The oscillations are obviously undetectable with SCADA



# Oscillation/LVRT Event of 12/14

- One line was out of service for maintenance
- Fault on another line started the oscillations
- Voltage pull-down was about 80% for 5 cycles (normal clearing time)
- Wind farm closest to the disturbance lost 57MW
- Why didn't the LVRT function properly at this facility?



# Using PMUs to Facilitate the Reliable Integration of Wind Generation in Pacific Northwest

NASPI Renewable Workshop &

June 2012 &

Presented by Alison Silverstein for BPA &


WIND GENERATION CAPACITY IN THE BPA BALANCING AUTHORITY AREA
Sequential Increases in Capacity, Based on Date When Actual Generation First Exceeded 50% of Nameplate
MW
4500
4250
4000
3750
3500
3250
3000
2750
2500
2250
2000
1750
1500
1250
1000
750
500
250
0
4421 MW
3/1/12
2/29/12
11/20/11
2/11/11
12/1/10
11/29/10
11/15/10
10/24/10
8/11/10
10/8/10
6/6/10
8/11/10
1/15/10
6/30/10
1/1/10
12/16/09
11/30/09
9/21/09
8/6/09
5/1/09
2/12/09
3/22/09
1/27/09
1/1/09
12/7/08
6/6/08
11/26/07
5/10/08
11/17/07
4/29/08
10/15/07
10/5/07
10/4/06
8/10/06
11/25/05
10/25/98
12/18/01
1/16/02
6/18/02
6/28/05
1/1/1998
7/2/1998
1/1/1999
7/2/1999
1/1/2000
7/2/2000
12/31/2000
7/2/2001
12/31/2001
7/2/2002
1/1/2003
7/2/2003
1/1/2004
7/1/2004
12/31/2004
7/2/2005
12/31/2005
7/2/2006
12/31/2006
7/2/2007
1/1/2008
7/1/2008
12/31/2008
7/1/2009
12/31/2009
7/2/2010
12/31/2010
7/2/2011
12/31/2011
7/1/2012

# Many of BPA Paths are Stability-Limited




BPA wind is highly correlated

- Installed capacity is about 4,400 MW
- Actual peak is above 4,000 MW in spring 2012

# Challenges

1. Wind power plant models
2. Wind power plant voltage control
3. Wind hub voltage control coordination )
4. Dynamic transfers

# 1. Wind Power Plant Modeling

- BPA has 4,500 MW of wind generation interconnected with no validated models
- Existing models failed to indicate some of the operational issues
- Type 2 generator models are particularly deficient (next slide)

# Type 2 Wind Power Plant Model Validation %

## Frequency (input)

60.15




59.85

400 sec

## Voltage (input)

1.05




0.90

400 sec

[ 0MW][COI 4799MW][IDAHO - SIERRA 258MW][IDAHO - MONTANA -270MW]
[ 0MW][ 0MW][ 0MW][ALTURAS PROJECT -58MW]
[WEST OF CASCADES - NORTH 3880MW][MIDWAY - LOS BANOS -301MW][PATH C -154MW][
[ 0MW][SOUTHERN NEW MEXICO (NM1) 184MW][CHOLLA - PINNACLE PEAK 848MW][INT
ALL COMMENTS RESULTING FROM THE OC & TSS REVIEW ARE INCLUDED.

Red = model

Blue = actual

Page 1

NRW_2009_07_12_2308.chf

events\From Dmitry 8-2-11

Sun Aug 21 18:38:46 2011

## Plant MW (output)

200




100

400 sec

## Plant MVAr (output)

20




-80

400 sec

[ 0MW][COI 4799MW][IDAHO - SIERRA 258MW][IDAHO - MONTANA -270MW]
[ 0MW][ 0MW][ 0MW][ALTURAS PROJECT -58MW]
[WEST OF CASCADES - NORTH 3880MW][MIDWAY - LOS BANOS -301MW][PATH C -154MW][
[ 0MW][SOUTHERN NEW MEXICO (NM1) 184MW][CHOLLA - PINNACLE PEAK 848MW][INT
ALL COMMENTS RESULTING FROM THE OC & TSS REVIEW ARE INCLUDED.

Red = model

Blue = actual

Page 2

NRW_2009_07_12_2308.chf

events\From Dmitry 8-2-11

Sun Aug 21 18:43:56 2011

# 2. Wind Power Plant Voltage Control

- LEGACY PLANTS:
  - Legacy plants (with type 1 and 2 technologies) do not have voltage control capabilities
  - Account for about 2,000 MW of capacity
  - The projects experienced a few operational issues, that were not identified in the planning studies (next two slides)










Normal operating range '

Voltage and power ' oscillations at a type 2 ' wind power plant, July 2009 '

Required MVAR operating range




Normal operating range

Voltage and power oscillations at a wind hub with type 2 wind power plants and a type 3 plant in power factor mode, December 2010

# 2. Wind Power Plant Voltage Control

- NEWER PLANTS:
  - Type 3 and 4 generators are capable of voltage controls
  - CAN is not the same as WILL
  - Several plants do not have appropriate controls and operate in power factor mode => BPA is working with plant operators on enabling voltage control functions
  - Many new plants have adequate voltage control and provide adequate voltage support to the grid

# Voltage Controls help to increase the amount of wind integration




Wind hub reached a 420 MW voltage stability limit with no dynamic voltage control

The hub generation is increased to 600 MW by adding 200 MW of generators with dynamic voltage control capabilities

# 3. Wind Hub Voltage Control Coordination

- BPA wind is highly concentrated
- Wind plants are clustered into large hubs
- Need to coordinate reactive power sharing among the plants

- New plants operating in voltage control have stable reactive power sharing
- Coordination with legacy technologies remains challenging

- New plants that have dynamic voltage control and operating in droop mode have stable and equitable reactive power sharing







Blue = WPP1

Green = WPP2

Red = Desired

- Early wind plants that do not have voltage controls have operational challenges in sharing reactive power






# 4. Dynamic Transfers

- Wind is ramping up / down
  - BPA wind ramps are large and fast because of high concentration #
- Conventional generation is used to balance wind generation
- Conventional generation is often far from the where the wind is (e.g. British Columbia, Montana, California)
- The power needs to travel across the stability-limited paths
- Need to make sure that the system adjustments are keeping up with the dynamic transfers

# Solutions and how Synchro-phasors can help

# 1. Wind Power Plant Modeling

- BPA is installing PMUs at wind power plants
  - Data from 15 plants is expected in April 2013
- PMU data will be used for wind power plant model validation
- BPA is supporting NREL-UVGIG project on wind power plant model validation

# 2. Wind Power Plant Voltage Control

- BPA is working with WPP operators on upgrading their voltage controls
- Trust but verify. BPA has developed OSI-Soft PI application for voltage control monitoring

Voltage

Active Power

Reactive Power







V-Q control:
Red = desired
Blue = actual

Power plant is in powerfactor control

# 3. Wind Hub Voltage Coordination

- PMU measurements can be used for wind hub voltage control and reactive power coordination
- How … Studies are in process

# 4. Dynamic Transfers

- Reliability starts with good planning. BPA is developing time-sequence powerflow capabilities to study voltage stability impacts of fast wind ramps.
- PMU measurements will provide better situational awareness for dispatchers to track voltage stability during fast wind ramps
  - Model-based VSA, similar to V&R ROSE
  - Measurement-based approaches
- Voltage stability controls – reactive switching

# BPA Contacts

- Terry Oliver, tvoliver@bpa.gov,
  - BPA Technology Innovation – BPA TI projects to support reliable wind integration
- Dmitry Kosterev, dnkosterev@bpa.gov,
  - BPA Transmission Planning – voltage control, modeling and monitoring

# Synchrophasors & Renewables

## *Renewables Integration*

- *Transmission Connections*
- *Distribution Connections*
- *Network Stability Impact*

**PhasorPoint:**

- **Controller (Angle Constraint Active Management)**
- **Angle & Dynamics baselining and trending**
- **Wide area event analysis**

GRID

ALSTOM

# Transmission Connections

- Network constraints across transmission zone boundaries
- Angle difference – a simple measure of stress between zones
  - Related to power flow
  - Related to corridor strength
- Angles useful for
  - Operator awareness / response
  - Constraint definition
  - Control for flexible constraint management







GRID | ALSTOM

# Distribution Connections

Increase capacity by **constraining by angle**:

- Manages multiple constraints
- Simple control logic
- Minimal comms requirements
- Generalized 'connect & manage' solution

Installation also applicable to **Loss-of-Mains** solution







**Marginal reduction of capacity factor**

➔ *More capacity*

➔ *More energy*

GRID | ALSTOM

# Renewable integration tools and PMU

## Renewable integration




Will renewable generation qualify for regulation? What primary response and secondary response can they provide?

## Power System stability studies




Are the renewable models good enough? What about energy storage, and demand response aggregated with renewables?

## Renewable generation field control




Are the current measurements adequate enough for real, reactive power and other type of control of renewable generations?

PMU provides high resolution measurements of power system states, can provide aid to close-loop control, dynamic modeling, frequency response studies, and?

1 Impacts of Integrating Wind Resources into the California ISO Market Construct, Clyde Loutan, Taiyou Yong, Sirajul Chowdhury, A. A. Chowdhury
2 Validation of Wind Power Plant Models, E. Muljadi, A. Ellis
3 Active Power Control Testing at the U.S. National Wind Technology Center, E. Ela

# Tools with/to enable renewable features

## Real time monitoring




## State estimation



## VSA and DSA




## Steady states and dynamic simulation




## GIS

## Unit dispatch

1 www.energy.ca.gov
2 Caiso Five Year Synchrophasor plan
3 www.dsatools.com
4 www.ge-energy.com
5 routescout.blogspot.com
6 www.aimms.com

NREL
NATIONAL RENEWABLE ENERGY LABORATORY

# Distribution Level Metering and Visualization Applications

**Jason Bank**

**May 1, 2012**

NREL is a national laboratory of the U.S. Department of Energy, Office of Energy Efficiency and Renewable Energy, operated by the Alliance for Sustainable Energy, LLC.

# Data Collection Network Objectives

- In order to support research projects related to the integration of distributed generation NREL has developed a solution for high-speed, real-time, measurement of electrical quantities a low voltage points in a distribution system
- Remote measurement devices stream data back to a set of central data collection servers, in a network architecture similar to those used for PMUs
- The servers collect and store this data which is then made available for end users through a set of query tools and visualization applications
- Most off-the-shelf products did not meet all the requirements for data rates, compact size, all weather capability, and real-time data transmission

# Distribution Monitoring Units

- Based in National Instruments sbRIO hardware and C-series modules
- GPS equipped for timestamping and Phasor calculations
- Developed specifically for metering at low voltage points on the distribution level
- Each Unit measures voltage and current phasors, RMS values, real, reactive and apparent power, power factor and temperature (external and internal)
- Output data rate configurable from 1 Hz up to 60 Hz
- Designed for metering at points up to 300 Vrms, higher voltage levels can be achieved with PTs or divider circuits
- Uses clip on voltage probes and Rogowski coils
- 9” x 11” x 3.5”



# Distribution Monitoring Units

- High temperature and weather rated for outdoor installations
- Data transmitted in real-time through a Ethernet, WiFi or Cellular internet connection
- 120/240 Split-Phase and 277 Y models have been developed
- Twelve units have been fielded into SMUD's Anatolia Circuit
- Five units have been installed on the Kihei Circuit on Maui



Meter installation on a Pad Mount Residential Transformer in Sacramento %

# Data Collection Network

- DMU measurements are immediately sent out through the onboard cellular modem, ethernet or Wi-Fi connection using the PMU communication protocol specified by the IEEE C37.118 Standard
- The data streams pass through the internet, arriving at the Data Concentrator housed at NREL
- The Data Concentrator time-aligns these streams and condenses them into one data set containing all of the measurement data
- The concentrator data stream is sent to the Historian for archival, then onto the Data Visualization applications and any other end users requiring live data feeds.
- The Data Concentrator is capable of receiving data from any internet connected device that can transmit using the C37.118 protocol, which includes almost all off the shelf PMUs and Phasor Data Concentrators
- The OpenPDC  software package (*http://openpdc.codeplex.com/*) provides the server-side software for both the concentrator and historian



# Solar Irradiance Measurements

- This data collection network is focused on irradiance measurement
- Individual stations are solar powered and equipped for cellular communication
- Once fielded the units begin collecting global horizontal measurements at data rates up to once per second
- Data is passed to the central servers at NREL in a batch process

# Collected Data – PV Production

- The red traces on these plots are global horizontal Irradiance measurements Taken from a MIDC tower in the Anatolia Neighborhood
- Blue traces are power flow through a transformer serving 10 houses, each with about 2kW of installed rooftop PV
- These plots represent three consecutive days, one cloudy, one sunny and one with intermittent cloud cover









# Collected Data – Observed Load Characteristics

- Upper plot is measured P and Q at a transformer serving 10 houses in Anatolia
- A load is observed switching on then off throughout the time span
- This load is about 5 kW and is observed all over the system at all times of day, most likely AC
- This switching effect is also apparent in the voltage measurements on the bottom plot



# Data Visualization







-Live data is displayed in Google Earth

-Accessible to internet connected users with the proper credentials

# Strip Chart Displays

- A strip chart based display has also " been developed for this live data "
- This interface uses the IEEE C37.118 protocol to connect directly to data historian
- The data is presented in a series of " strip charts and phasor diagram "
- The user can select individual channels for display on the charts, building up customized live displays
- This package is capable of communicating directly to any IEEE C37.118 compliant device





# Data Access

- Access to the data sets are granted to project members via a website (username/password authentication)
- With a form based tool a user can request a specific data set
- The website then pulls the required data from the database and returns a delimited text file



Distribution Monitoring Database

NREL

ABOUT THE DATABASE | QUERY DATABASE | DOWNLOAD RESULTS | MANAGE PROJECTS | LOG OUT

You are logged in as jason.bank@nrel.gov.

**Query the Database**

To retrieve a dataset from the database, fill out this form describing the dataset you desire and click the *Submit* button at the bottom.

Active Project: SMUD - RES/CES [Update]

**Data Set Timing Parameters**

*Complete the fields below to define a timeframe for your dataset.*
*Note: The "with DST" time zone options take Daylight Saving Time into account, and the "without DST" options do not.*

| | Time & Date | Format | Time Zone |
|---|---|---|---|
| Start Time | hh:mm:ss dd/mm/yyyy | AM | GMT (without DST) |
| End Time | hh:mm:ss dd/mm/yyyy | AM | |
| Time Resolution* | 1 | second | |
| Output Time Format | Unix-Style Timestamp (Elapsed Seconds Since 00:00:00 Jan 1 1970 GMT) | | |

** Minimum of 1 second. Values greater than 1 will decimate from existing 1 second datasets by selecting the nearest point. Only accepts integers.*

**Distribution Transformer Measurements (from DMUs)**

*Check the boxes for measurements you want to include in the dataset*
*To select or deselect entire rows or columns use the SET and CLR buttons*

| | | | Anatolia Transformers | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | 2K9 | 9K2 | 3K7 | 8K2 | 9K1 | 1K8 | 2K1 | 8K5 | 10K5 | 4K7 | 5K7 | 2K7 |
| | | | SET CLR | SET CLR | SET CLR | SET CLR | SET CLR | SET CLR | SET CLR | SET CLR | SET CLR | SET CLR | SET CLR | SET CLR |
| V1 Phasor Magnitude | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| V1 Phase Angle | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| V2 Phasor Magnitude | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| V2 Phase Angle | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| V12 Phasor Magnitude | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| V12 Phase Angle | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| I1 Phasor Magnitude | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| I1 Phase Angle | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| I2 Phasor Magnitude | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| I2 Phase Angle | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| In Phasor Magnitude | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| In Phase Angle | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| Frequency | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| V1 RMS | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| V2 RMS | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| V12 RMS | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| I1 RMS | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| I2 RMS | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| In RMS | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| Apparent Power Magnitude (\|S\|) | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| Real Power (P) | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| Reactive Power (Q) | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| Power Factor | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| Displacement Power Factor | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| Meter Internal Temperature | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |
| Transformer Housing Temperature | SET | CLR | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ | ☐ |

[Submit]

# Continuing Work

- Further deployment of meters into other distribution circuits
  - SCE High Pen Study
  - CPS Bluewing
- Development of other meter models for additional metering locations and reduced hardware cost
  - DFR-style triggered waveform capture
  - More complete support for Harmonics and THD
  - FTP store and forward version (trades real-time for reliability, higher measurement rates and ease of communications)
- Integration of other, data sets into data retrieval website
  - Utility SCADA data
  - Household level and Smart Meter Data
  - Solar and weather measurements
- Refinement and addition of features to Visualizations
- Integration of other sources into visualizations, including results from simulation and modeling

# Integration of Simulation and Modeling

- The communications to the Google Earth and Strip chart displays have an open architecture which allows for easy integration of other data sources
- This would include data sets generated by simulation and modeling packages
- On going work includes the integration of the DEW distribution system modeling package so that simulation results can be incorporated and displayed along with the live data
- DEW can also receive the live data feeds as input to its solver, allowing it to fill in the missing points on the map

# NASPI - NREL RENEWABLES WORKSHOP

| NAME | ORGANIZATION | PHONE | EMAIL ADDRESS |
|---|---|---|---|
| alisonsilverstein | NASPI | 5126703493 | alisonsilverstein@mac.com |
| Jeff Dagle | PNNL | 509 375-3629 | jeff.dagle@pnnl.gov |
| Dave Corbus | NREL | 303 384 6966 | David.Corbus@NREL.GOV |
| Ken Martin | EPG | 503 284 8984 | martin@electricpowergroup.com |
| Eric H. Allen | NERC | 609 651 7185 | eric.allen@nerc.net |
| Viheram Budhraja | EPG/CERTS | 6266852015 | budhraja@electricpowergroup.com |
| Jim Dyer | EPG | 714-293-5316 | dyerjd@AOL.com |
| Mahendra Patel | PJM | 610-633-8277 | patelm3@pjm.com |
| KAREN FORSTEN | EPRI | 865-218-8052 | kforsten@epri.com |
| FRED ELMENDORF | GPA | 423-702-8136 | felmendorf@gridprotectionalliance.org |
| JIM HACKETT | MEHTA TECH | 563-285-9151 | hackett@mehtatech.com |
| TARIQ RAHMAN | SDG&E | 858-636-5547 | trahman@SEMPRAUTILITIES.com |
| Richard Pirret | Fluke | 425-577-4951 | RMPIRRET@gmail.com |
| GEOFF IVES | FLUKE | +44 1603 256 724 | geoff.ives@fluke.com |
| Mike McMullen | MISO | 651 632-8404 | mmcmullen@misoenergy.org |
| Dino Lelic | quanta T. | 919-274-1375 | dlelic@quanta-technology.com |
| Marcus Young | ORNL | 865-719-1568 | youngmaii@ornl.gov |
| BOB ZAVADIL | ENERNEX | 865-386-7456 | bobz@enernex.com |
| Phil Overholt | DOE/OE | 202-586-8110 | philip.overholt@hq.doe.gov |
| Allen Goldstein | Fluke Calibration | 206-276-7347 | allen.goldstein@fluke.com |
| KARL REINHARD | UNIV OF IL @ URBANA CHAMPAIGN | 217 719 0658 | REINHRDL@ILLINOIS.EDU |
| Luigi Vanfretti | KTH Sweden | +46 8790 6625 +46 73 4612478 | LUIGIV@KTH.SE |
| Nanay Huang | PJM Interconnection | 6106664723 | huangn@pjm.com |
| DAVID HISLOP | PJM INTERCONNECTION | 610.666.4242 | hislod@pjm.com |
| Marissa Hummon | NREL | 303-275-3269 | marissa.hummon@nrel.gov |

| NAME | ORGANIZATION | PHONE | EMAIL |
|---|---|---|---|
| Charlie Smith | UVIG | 252-715-0796 | charlie@uvig.org |
| Kara Clark | NREL | 303-384-7098 | kara.clark@nrel.gov |
| Bill Flerchinger | SEL | 509 334-8091 | BillFlerchinger@SELINC.com |
| John Adams | ERCOT | 512 248-3130 | jadams@ercot.com |
| Kevin Frankeny | MISO | 317-249-5620 | kfrankeny@misoenergy.org |
| Louis SIGNORETTY | ALSTOM | 425-250-2804 | Louis.signoretty@alstom.com |
| Austin White | OGE | 405-553-5996 | whitead@oge.com |
| Yi Hu | Quanta Technology | 919-334-3042 | yhu@quanta-technology.com |
| Yingchen (YC) Zhang | NREL | 303-384-7090 | yingchen.zhang@nrel.gov |
| Sascha von Meier | CIEE/UCB | 707.322.3538 | vonmeier@uc-ciee.org |
| LLOYD CIBULKA | CIEE/U. of CA-Bkly, | 570-290-3875 | lloyd.cibulka@uc-ciee.org |
| Ed Muljadi | NREL | (303)384-6904 | eduard.muljadi@nrel.gov |
| Yih-huei Wan | NREL | 303-384-7025 | yih-huei.wan@nrel.gov |
| Jason BANK | NREL | 303 275 4338 | jason.bank@nrel.gov |
| Barry Mather | NREL | 303-275-4378 | barry.mather@nrel.gov |
| Hari Singh | Xcel Energy | 303-571-7095 | hari.singh@xcelenergy.com |
| Jeff Otto | SEL | (509) 336-4426 | jeff_otto@selinc.com |
| Justin Fuith | Xcel Energy | 612-303-5802 | Justin.T.Fuith@Xcelenergy.com |
| Vahan Gevorgian | NREL | 303.384.6940 | vahan_gevorgian@nrel.gov |
| HECTOR ANDRES R. VOLSKIS | ONS | +55 21 22039990 | HECTORVOLSKIS@ONS.ORG.BR |
| Lisa Beard | Quanta Technology | 805-323-8799 | lbeard@quanta-technology.com |
| Ittiphong Leevongwat | Univ. of New Orleans | 504-280-7381 | ILEEVONG@UNO.EDU |
| ANGELA NELSON | ENTERGY | 504-365-3614 | anels90@entergy.com |
| FLOYD GALVAN | ENTERGY | 5043653614 | fgalvan@entergy.com |
| Joel Phelps | Duke Energy | 317.838.6474 | Joel.Phelps@Duke-Energy.com |
| Jim Kleitsch | ATC | 608.877.8102 | jKleitsch@atcllc.com |

| NAME | ORG | PHONE | EMAIL ADDRESS |
|---|---|---|---|
| David Burnham | FERC | 202-502-8732 | david.burnham@ferc.gov |
| Hamish Mehta | Mehta Tech, Inc | 563-285-9151 | hamish@mehtatech.com |
| DOUG OSBORN | FOA | 918-627-4200 | DOSBORN@OBERLENDER.COM |
| RICH BAUER | IPCO | 208-388-5669 | rbauer@idahopwr.com |
| Henry Huang | PNNL | 509-372-6781 | zhenyu.huang@pnnl.gov |
| Jerry FitzPatrick | NIST | 301-975-8922 | fitzpa@nist.gov |
| Tom Nelson | NIST | 301-975-2986 | thomas.nelson@nist.gov |
| Mohit Singh | NREL | 303-384-6931 | mohit.singh@nrel.gov |
| Alicia Allen | Univ of Texas | | aliciajallen@utexas.edu |
| Joseph Mullen | PJM | 610-862-6351 | mullej@pjm.com |
| BHARAT BHARGAVA | EPG | 626.685.2015 | BHARGAVA@electricpowergroup.com |
| Laura Hicks | ERL Phase | 206-200-1570 | lhicks@erlphase.com |
| TONY RANSON | MEHTATECH, INC | 563-285-9151 | TRANSON@MEHTATECH.COM |
| Larry Bugh | Reliability First | 330-247-3046 | larry.bugh@rfirst.org |
| RT Jackson | Mehta Tech | 515-223-0769 | |
| Mike Finlo | NREL | 720-394-2113 | michael.finto@NREL.gov |
| Aaron Wright | SEL | 509-334-8086 | Aaron.Wright@selinc.com |
| Jim Reilly | Reilly Assoc | 732-706-9460 | j_reilly@verizon.net |
| Clifton Black | Southern Company | 205-257-6184 | crblack@southernco.com |
| JACK ARNOLD | NATIONAL INSTRUMENTS | 512-683-5720 | jack.arnold@ni.com |
| Jing Liu | PJM | 610-666-4326 | liuj@pjm.com |
| Bonian Shi | Beijing Sifang | | shibonian@sf-auto.com |
| Yi-hua Tang | NIST | 301 975 4691 | yi-hua.tang@nist.gov |
| Shawn Fountain | BRIDGE Energy Group | 303.886.9207 | sfountain@bridgeenergygroup.com |
| Said Siddiqi | TVA | 423.697.4162 | sisiddiqi@tva.gov |
| Mamadou Diong | Dominion | 804-257-4797 | MAMADOU.DIONG@DOM.COM |
| Scott Dahman | PowerWorld | 217 384 6330 | scott@powerworld.com |

| NAME | ORG | PHONE | EMAIL ADDRESS |
|---|---|---|---|
| David Gao | University of Denver | 3038713570 | wenzhong.gao@du.edu |
| Yutaka Kokai | Hitachi America | 9149808716 | yutaka.kokai@hal.hitachi.com |
| DAVID BERTHOLD | ISO NEW ENGLAND | 413-530-5356 | dbert@iso-ne.com |
| Paul Sweat | National Instruments | 720-929-8946 | paul.sweat@ni.com |