




A1
3-5/8" 20ga stud @ 16" OC, 1 layer 5/8" Type X each side (4-7/8")



A2
A1 with 3-1/2" acoustic batt, to deck (4-7/8")




B1
6" 18ga stud @ 16" OC, 1 layer 5/8" Type X each side (7-1/4")




C1
2-hr shaft wall: 2-1/2" CH stud @ 24" OC, 1" liner shaft side, 2 layers 5/8" Type X room side (4-3/4")




D1
Chase wall: double 3-5/8" stud @ 16" OC with 6" gap, 1 layer 5/8" each outer side (14-1/2")



F1
Furring: 7/8" hat channel @ 16" OC + 1 layer 5/8" one side, on CMU (1-1/2")



EXT-1
Exterior: 6" 18ga stud @ 16" OC, 5/8" gyp inside, 5/8" sheathing, 1-1/2" EPS + EIFS (8-7/8")



EXT-2
Exterior: 6" 18ga stud @ 16" OC, 5/8" gyp inside, 5/8" sheathing, 3-coat stucco (8-1/8")



CMU
8" CMU (by others not drywall scope)



SF
Aluminum storefront, 4-1/2" frame (by others not drywall scope)

REVISIONS

DATE: 08/04/2026
ISSUE: BID SET

SCALE: 3" = 1'-0"

PARTITION TYPES

A-501