

ADDENDUM NO. 1

Project: Sanibel Fire and Rescue Station 172 - 100% Construction Documents dated January 5, 2024

Commission No. 2023820

Date of Addendum: January 19, 2024

EVAL FIXTURE - fictional addendum written for a synthetic evaluation. It was not issued by the project's architect and changes nothing about the real project.

This Addendum forms part of the Contract Documents and modifies them as follows.

ITEM 1 - DRAWINGS, SHEET A500 DOOR SCHEDULE

Door 220 (Second Floor): revise the door panel leaf width from 3'-0" to 3'-6" and revise the door hardware set from 10 to 11. The leaf height (8'-0"), leaf type (F), leaf material (WD), frame type (1), frame material (HM), door/frame rating (20) and detail references are unchanged.

ITEM 2 - BIDDING

Bidders shall acknowledge receipt of this Addendum on the Bid Form.

END OF ADDENDUM NO. 1