SUBMITTAL TRANSMITTAL

Field	Value
Project	Smoke project
Submittal no.	08 11 13-001, revision 0
Section	08 11 13 Hollow Metal Doors and Frames
Type	Product data and frame schedule
From	Lakeside Door & Frame Co. (subcontractor)
To	Example Builders, Inc. for review
Date	October 1, 2026

Contents: product data (page 2), frame schedule (page 3).

PRODUCT DATA - LDF SERIES HOLLOW METAL FRAMES AND DOORS

Item	Lakeside standard
Frame	16 gauge cold-rolled steel, welded, factory primed
Door	1-3/4 in, 18 gauge face sheets, honeycomb core
Jamb anchors	Wall anchors, 3 per jamb
Floor anchors	20 ga (0.036 in) steel clip, 2 per frame
Finish	Rust-inhibitive primer

FRAME SCHEDULE

Mark	Size	Frame	Door
D101	3'-0" x 7'-0"	HM	by others
D102	3'-0" x 7'-0"	HM	HM
D103	3'-0" x 7'-0"	HM	by others
D104	3'-0" x 7'-0"	HM	HM
D105	3'-0" x 7'-0"	HM	by others
D106	3'-0" x 7'-0"	HM	HM
D107	3'-0" x 7'-0"	HM	by others
D108	3'-0" x 7'-0"	HM	HM
D109	3'-0" x 7'-0"	HM	by others
D110	3'-0" x 7'-0"	HM	HM
D111	3'-0" x 7'-0"	HM	by others
D112	3'-0" x 7'-0"	HM	HM
D113	3'-0" x 7'-0"	HM	by others
D114	3'-0" x 7'-0"	HM	HM