

Wood Environment & Infrastructure



SUPPLIER NAME:	Perimeter Concrete	PROJECT NO:	WX12593	FIRST SINGLE SPECIMEN AGE:	7
MIX NUMBER:	RMXSS35A55F	PROJECT NAME:	MMTP	SECOND SINGLE SPECIMEN AGE:	28
SPEC. STRENGTH:	35 MPa			THIRD SPECIMEN AGE:	56
SPECIFIED AIR:	4 to 7 %	CLIENT:	Manitoba Hydro Head Office Facilities Department Winnipeg Mb Canada	CEMENT TYPE:	HS
SPECIFIED SLUMP:	50 to 110 mm				
SPECIFIED SPREAD:	to mm	CAST DATE RANGE:	9/4/2019 - 11/15/2019		

PROJECT #	LAB NO	CAST DATE	Location of Placement	SLUMP (mm)	SPREAD (mm)	AIR(%)	Temp(C)	7 Days Result	MOVING AVG OF 3	28 Days Result	MOVING AVG OF 3	56 DAYS RESULT	MOVING AVG OF 3
WX12593	WX12593-87	9/17/2019	Tower 14, Leg 3	70		5.9	26	32.7		44.2		47.4	
WX12593	WX12593-238	10/23/2019	Tower 34 Leg 4	80		6.5	20	29.9		40.1		47.2	

Reporting of these results constitutes a testing service only. Engineering interpretation or evaluation of the test results is provided only on written request.

Wood Environment & Infrastructure Solutions - 440 Dovercourt Drive - Winnipeg, MB - R3Y 1N4