

Lakeshore Hall C: AHU-3 Air System

1 Description

This note describes the arrangement of air handling unit AHU-3, which conditions Hall C, and the devices that drive, power and control it.

2 Arrangement

Air enters at the outdoor air damper, passes the mixing box, the filter bank, the cooling coil in turn, and reaches the supply fan. The supply duct receives the air from the supply fan. Hall C receives the air from the supply duct. Downstream of Hall C comes the return fan. The mixing box receives the air from the return fan. AHU-3 houses the mixing box. The filter bank sits within AHU-3. The cooling coil sits within AHU-3. AHU-3 houses the supply fan. The supply fan is driven by the motor M-3. The motor M-3 is fed from the panel LP-2. The outdoor air damper is modulated by the controller DDC-3. The motor M-3 is modulated by the controller DDC-3. The sensor TS-1 reports to the controller DDC-3. The sensor TS-1 sits on the supply duct. The motor M-3 is rated 61 hp. The sensor TS-1 holds the supply air at 52 °F.