



检验报告

TEST REPORT

中心编号(No.): 201608CW022

DIMIT

样品名称: Sample Name	内墙乳胶漆				
委托单位: Client	唐山市丰润区德心水性涂料厂				
检验类别:	委托检验				
Test Type					

建筑材料工业技术监督研究中心
Technical Supervision and Research Center of the Building Materials Industry





建筑材料工业技术监督研究中心

Technical Supervision and Research Center of the Building Materials Industry

150002283084

检验报告

REPORT

中心编号(No.): 201608CW022 第1页共2页 样品名称 内墙乳胶漆 检验类别 委托检验 委托单位 唐山市丰润区德心水性涂料厂 商 标 生产单位 唐山市丰润区德心水性涂料厂 等 级 合格 生产日期 样品编号 DXH 来样日期 2016年08月24日 规格型号 样品数量 5kg 样品状态 液态 检验依据 GB 18582-2008《室内装饰装修材料 内墙涂料中有害物质限量》 1. 挥发性有机化合物含量 (VOC) 2. 游离甲醛 检验项目 3. 苯、甲苯、乙苯、二甲苯总和 4. 可溶性重金属(铅Pb、镉Cd、铬Cr、汞Hg) *经检验, 送检样品的挥发性有机化合物含量 (VOC), 游离甲醛, 苯、甲苯、乙苯、二甲苯总和、可溶性重金属(铅 Pb、镉 Cd、铬 Cr、 汞 Hg)的检验结果符合标准 GB 18582-2008 中水性墙面涂料的技术指标 检验结论 要求。* 签发日期: 2016年11月22日 检验测试章 备注: (此处空白) 松掘区测专用章

3W 2 # 核. 萧瑛

检验单位地址: 北京市朝阳区管庄中国建材院内北楼

电话: 010-51164723



建筑材料工业技术监督研究中心

Technical Supervision and Research Center of the Building Materials Industry

检验报告

TEST REPORT

中心编号(No.): 201608CW022

第2页共2页

2010000 11022				第4贝共2贝	
序号	检验项目		标准要求	检验结果	单项结论
	挥发性有机化合物含量 (VOC)/(g/L)		≤120	未检出	合格
2	游离甲醛/(mg/kg)		≤100	16	合格
3	苯、甲苯、乙苯、 二甲苯总和/(mg/kg)		<300	未检出	合格
可溶性 4 重金属 /(mg/kg)		铅 Pb	< 90	120.20	合格
	一编 Cd /	₹ 15	未检出	合格	
		络 Cr	<60	2.0	合格
		汞Hg	< 60	未检出	合格

(以下空白)

备注: (此处空白)



说明

Notice

- 1、本报告无中心"检验测试章"和骑缝章无效。 This test report is invalid without the seal.
- 本报告无"编制、审核、批准"签字无效。
 This test report is invalid without the signatures of the related persons.
- 本报告涂改、部分复印无效。
 This test report is invalid if erased, altered or copied partially.
- 4、对本报告若有异议,应于收到报告之日起十五个工作日内向本中心提出,逾 期恕不受理。

Any doubt should inform us within 15 workdays after receiving the test report.

5、委托检验样品和委托信息由委托人提供,中心不对真实性负责,委托检验结果仅对来样负责。

The commissioned testing samples and commission information are provided by the applicant. The results shown in the test report refer only to the sample(s) tested unless otherwise stated. Identifying authenticity of the supplied samples and information is out of our responsibility.

6、本报告的法律责任山建筑材料工业技术监督研究中心承担。
The legal responsibility of this test report is charged with Technical Supervision and Research Center of the Building Materials Industry.

本报告采用防伪纸张,复印后应带有网络底纹。
 This test report is printed on anti-counterfeiting paper. Its copy should have grid shading.

本中心联系方式:

地址 (Address): 北京市朝阳区管庄东里一号北楼

No.1 Guanzhuang Dongli, Chaoyang District, Beijing 100024, P.R. China.

邮编 (Post Code): 100024

电话 (Tel): (010) 51164723 51164718

传真 (Fax): (010) 51164724

报告真伪查询 (Tel): (010) 51164716

网址 (Web): http://www.dmtc.org.cn/

电子邮箱 (E-mail): dmtc2007@163.com