



2012003084M

存档

# TEST REPORT

(Report No.): 201412DW132(E)

201412DW132

Sample Name: PVC Woven Carpet

Client: Shanghai Hanfei Industry Co.,Ltd

Test Type: Authorized Testing

(国家) 建筑材料工业技术监督研究中心

建筑材料工业干混砂浆产品质量监督检验测试中心

China Building Material Industry Center for Quality Supervision and Test of Dry-mixed Mortar



(国家) 建筑材料工业技术监督研究中心  
Technical Supervision and Research Center of the Building Materials Industry



(国家) 建筑材料工业技术监督研究中心

## 建筑材料工业干混砂浆产品质量监督检验测试中心

China Building Material Industry Center for Quality Supervision and Test of Dry-mixed Mortar

### TEST REPORT

(Report No.): 201412DW132(E)

Page 1 of 2

Sample Name	PVC Woven Carpet	Test Type	Authorized Testing
Client	Shanghai Hanfei Industry Co.,Ltd	Trademark	G+
Manufacturer	Shanghai Hanfei Industry Co.,Ltd	Grade	—
Production Date	30 <sup>th</sup> November,2014	Sample No.	—
Sample Date	9 <sup>th</sup> December,2014	Specification	50cm×50cm
Sample Quantity	4	Sample Status	Block
Testing Standard	“Indoor decorating and refurbishing materials-Limit of harmful substances of polyvinyl chloride floor coverings”,GB 18586-2001		
Test Content	1. Volatile		
Test Conclusion	* The test result of volatile meets the technical requirements of standard GB 18586-2001 of non-foamed floor roller sheets-other base materials. *		
Remark: (blank area)	Reported Date: 4 <sup>th</sup> January, 2015 (Test Stamp)		

Reported by

Checked by

Authorized by

Address: North building of China Building Materials Academy, GuanZhuang, ChaoYang district, Beijing  
Tel:010-51164723 Postcode:100024



(国家)建筑材料工业技术监督研究中心  
Technical Supervision and Research Center of the Building Materials Industry



(国家) 建筑材料工业技术监督研究中心

# 建筑材料工业干混砂浆产品质量监督检验测试中心

China Building Material Industry Center for Quality Supervision and Test of Dry-mixed Mortar

## TEST REPORT

(Report No.): 201412DW132(E)

Page 2 of 2

No.	Test Content	Standard Request (non-foamed floor roller sheets - other base materials)	Test Result	Single Conclusion
1	Volatile /(g/ m <sup>2</sup> )	≤10	L89	Qualified
(blank below)				
Remark: (blank area)				

Address: North building of China Building Materials Academy, GuanZhuang, ChaoYang district, Beijing  
Tel:010-51164723 Postcode:100024



(国家)建筑材料工业技术监督研究中心  
Technical Supervision and Research Center of the Building Materials Industry