



2012003084M



(2012)建材质监认字(24号)

存档

检 验 报 告

TEST REPORT

中心编号(No.): 201212FW124

DMTC

样品名称: 高性能复合阻锈防腐剂

Sample Name

委托单位: 山西鸿伟益达建材科技有限公司

Client

检验类别: 委托检验

Test Type

(国家) 建筑材料工业技术监督研究中心

Technical Supervision and Research Center of the Building Materials Industry



(国家) 建筑材料工业技术监督研究中心
Technical Supervision and Research Center of the Building Materials Industry



2012003084M

(国家) 建筑材料工业技术监督研究中心

Technical Supervision and Research Center of the Building Materials Industry

检 验 报 告

TEST REPORT

中心编号(No.): 201212FW124

第 1 页 共 2 页

样品名称	高性能复合阻锈防腐剂	检验类别	委托检验
委托单位	山西鸿伟益达建材科技有限公司	商 标	—
生产单位	山西鸿伟益达建材科技有限公司	样品状态	粉状, 无结块
生产日期	—	生产批号	—
来样日期	2012 年 12 月 24 日	样品编号	—
样品数量	10kg	规格型号	HD-10
检验依据	JC/T 1011-2006 《混凝土抗硫酸盐类侵蚀防腐剂》		
检验项目	1.比表面积 2.凝结时间 3.抗压强度比 4.膨胀率 5.抗蚀系数 6.膨胀系数 7.氧化镁 8.氯离子 9.碱含量		
检验结论	<p>*经检验, 送检样品的比表面积、凝结时间、抗压强度比、膨胀率、抗蚀系数、膨胀系数、氧化镁、氯离子、碱含量的检验结果符合 JC/T 1011-2006 中抗硫酸盐类侵蚀防腐剂的技术指标要求。*</p> <p style="text-align: right;">签发日期: 2013 年 04 月 08 日 (检验测试章)</p>		
备注:	(此处空白)		

批 准:

审 核:

编 制:

检验单位地址: 北京市朝阳区管庄中国建材院内北楼

电话: 010-51164723

邮编: 100024



(国家) 建筑材料工业技术监督研究中心

Technical Supervision and Research Center of the Building Materials Industry

检 验 报 告

TEST REPORT

中心编号(No.): 201212FW124

第 2 页 共 2 页

序号	检验项目		标准要求 (抗硫酸盐类侵蚀防腐剂)	检验结果	单项结论
1	比表面积/ m ² /kg		≥300	490	合格
2	凝结 时间	初凝/ min	≥45	202	合格
		终凝/h	≤10	4	合格
3	抗压强 度比/%	7d	≥90	123	合格
		28d	≥100	132	合格
4	膨胀率 /%	1d	≥0.05	0.088	合格
		28d	≤0.60	0.185	合格
5	抗蚀系数(K)		≥0.85	1.0	合格
6	膨胀系数(E)		≤1.50	1.14	合格
7	氧化镁/%		≤5.0	2.7	合格
8	氯离子/%		≤0.05	0.019	合格
9	碱含量/%		≤0.60	0.32	合格
备注：试验时，高性能复合阻锈防腐剂的掺量为内掺4%。					

说 明 Notice

- 1、本报告无中心“检验测试章”和骑缝章无效。
This test report is invalid without the seal.
- 2、本报告无“编制、审核、批准”签字无效。
This test report is invalid without the signatures of the related persons.
- 3、本报告涂改、部分复印无效。
This test report is invalid if erased, altered or copied partially.
- 4、对本报告若有异议，应于收到报告之日起十五日内向本中心提出，逾期恕不受理。
Any doubt should inform us within 15 days after receiving the test report.
- 5、委托检验样品和委托信息由委托人提供，中心不对真实性负责，委托检验结果仅对来样负责。
The commissioned testing samples and commission information are provided by the applicant. The results shown in the test report refer only to the sample(s) tested unless otherwise stated. Identifying authenticity of the supplied samples and information is out of our responsibility.
- 6、本报告采用防伪纸张，复印后应带有网络底纹。
This test report is printed on anti-counterfeiting paper. Its copy should have grid shading.

本中心联系方式：

地址 (Address)：北京市朝阳区管庄东里一号北楼

No.1 Guanzhuang Dongli, Chaoyang District, Beijing 100024, P.R. China.

邮编 (Post Code)：100024

电话 (Tel)：(010) 51164723 51164718

传真 (Fax)：(010) 51164723 51164718

网址 (Web)：<http://www.dmtc.org.cn/>

电子邮箱 (E-mail)：sj13146197542@126.com

