



检验报告

TEST REPORT

中心编号(No.): 201701CW101

DIME

样品名称: Sample Name	建筑结构胶
委托单位: Client	北京众固新业科技开发有限公司
检验类别: Test Type	委托检验

建筑材料工业技术监督研究中心
Technical Supervision and Research Center of the Building Materials Industry





建筑材料工业技术监督研究中心

Technical Supervision and Research Center of the Building Materials Industry

检验报告

TEST REPORT

中心编号(No.): 201701CW101

第1页共2页

1 3 24 3 (140.): 201701C W101		第1页 共2页			
样品名称	建筑结构胶	检验类别	委托检验		
委托单位	北京众固新业科技开发有限公司	商标	众固		
生产单位	北京众固新业科技开发有限公司	等 级	A级		
生产日期	學說說說	样品编号			
来样日期	2017年02月06日	规格型号	ZHG		
样品数量	1kg	样品状态	液态, 双组分		
检验依据	GB 18583-2008《室内装饰装修材料 胶粘剂中有害物质限量》				
检验项目	1. 苯 2. 甲苯+二甲苯 3. 总挥发性有机物				
检验结论	*经检验,送检样品的游离甲醛、3的检验结果符合标准 GB 18583-2008 求。*	中溶剂型其他胶 明: 2017年 03 检验测	粘剂的技术指标要		

备注: (此处空白)

批准:多加入市核:萧瑛

编制:张红珍

检验单位地址:北京市朝阳区管庄中国建材院内北楼

电话: 010-51164723

邮编: 100024



建筑材料工业技术监督研究中心

Technical Supervision and Research Center of the Building Materials Industry

检验报告

TEST REPORT

中心编号(No.): 201701CW101

第2页 共2页

HILL	TATHUL AUT A SE		第2 次 六 2 贝	
序号	检验项目	标准要求 (溶剂型其他胶粘剂)	检验结果	单项结论
	苯/(g/kg)	≤ 5.0	未检出	合格
2	甲苯+二甲苯/(g/kg)	≤150	未检出	合格
835	总挥发性有机物/(g/L)	≤700	20	合格



备注: 配比: A:B=3:1。

164191 164191

检验单位地址: 北京市朝阳区管庄中国建材院内北楼

电话: 010-51164723

邮编: 100024



说明

Notice

- 1、本报告无中心"检验测试章"和骑缝章无效。 This test report is invalid without the seal.
- 本报告无"编制、审核、批准"签字无效。
 This test report is invalid without the signatures of the related persons.
- 3、本报告涂改、部分复印无效。

This test report is invalid if erased, altered or copied partially.

4、对本报告若有异议,应于收到报告之日起十五个工作日内向本中心提出,逾 期恕不受理。

Any doubt should inform us within 15 workdays after receiving the test report.

5、委托检验样品和委托信息由委托人提供,中心不对真实性负责,委托检验结果仅对来样负责。

The commissioned testing samples and commission information are provided by the applicant. The results shown in the test report refer only to the sample(s) tested unless otherwise stated. Identifying authenticity of the supplied samples and information is out of our responsibility.

6、本报告的法律责任山建筑材料工业技术监督研究中心承担。
The legal responsibility of this test report is charged with Technical Supervision and Research Center of the Building Materials Industry.

7、本报告采用防伪纸张,复印后应带有网络底纹。
This test report is printed on anti-counterfeiting paper. Its copy should have grid shading.

本中心联系方式:

地址(Address): 北京市朝阳区管庄东里一号北楼

No.1 Guanzhuang Dongli, Chaoyang District, Beijing 100024, P.R. China.

邮编 (Post Code): 100024

电话 (Tel): (010) 51164723 51164718

传真 (Fax): (010) 51164724

报告真伪查询 (Tel): (010) 51164716

网址 (Web): http://www.dmtc.org.cn/

电子邮箱 (E-mail): dmtc2007@163.com