WASTEWATER SYSTEM AND POTABLE WATER SUPPLY INNOVATIVE AND ALTERNATIVE (I/A) TECHNOLOGY GENERAL USE APPROVAL

LAWS/REGULATIONS INVOLVED

10 V.S.A. Chapter 64, Potable Water Supply and Wastewater System Permit
Wastewater System and Potable Water Supply Rules, Effective November 06, 2023

Applicant and I/A Approval Recipient:
Infiltrator Water Technologies
4 Business Park Road
PO Box 768
Old Saybrook, CT 06475

www.infiltratorwater.com
800-221-4436

Jeanne Allen – Regulatory Specialist
jallen@infiltratorwater.com
603-631-4897

Approval Number: **2006-04-R9**

Date Issued: **04/30/2026**
Date Expires: **05/01/2028**

This approval is for the following gravel-less chamber distribution I/A technology models:

Product Name	Effective Leaching Area (trench)	Effective Leaching Area (bed)
Quick4 Standard	4.54 ft^2 per linear ft. see Manual	3.62 ft^2 per linear ft. see Manual
Quick4 + STD	4.54 ft^2 per linear ft. see Manual	3.62 ft^2 per linear ft. see Manual
Quick4 + STD LP	4.54 ft^2 per linear ft. see Manual	3.62 ft^2 per linear ft. see Manual
Quick4 EQ 36	3.22 ft^2 per linear ft. see Manual	-
Quick4 + EQ 36 LP	3.22 ft^2 per linear ft. see Manual	-
Quick4 High Cap.	4.86 ft^2 per linear ft. see Manual	3.89 ft^2 per linear ft. see Manual
Quick4 + High Cap.	4.96 ft^2 per linear ft. see Manual	3.97 ft^2 per linear ft. see Manual

The technologies listed in this I/A Approval are used to disperse low strength effluent as part of the discharge to a soil-based wastewater disposal system. The technologies, consisting of subsurface, gravel-less chamber distribution systems, are hereby approved under the requirements of the regulations named above subject to the following conditions.

1. GENERAL

1.1 The technologies listed in this I/A Approval may be used as part of a soil-based wastewater system, subject to the jurisdiction of, and permitted pursuant to, the referenced Rules provided the conditions of this I/A Approval are met.

1.2 Failure by the I/A Approval Recipient to comply with these conditions is grounds for the Secretary to revoke, or to decline to renew, this I/A Approval.

1.3 The approval shall expire on **May 1, 2028.** Applications for renewal of this I/A Approval shall be submitted to the Division by March 1, 2028, to avoid a lapse in approval. The renewal request shall be submitted on a form prepared by the Secretary and shall include: a description of any changes to the equipment, technical specifications and drawings, installation requirements, and operation and maintenance manuals.

1.4 No changes shall be made to the approved technology without prior review and approval by the Secretary.

1.5 This I/A Approval is based on the design, operation, and maintenance manuals submitted by the Applicant to the Secretary. Misrepresentation in the application material is grounds for the Secretary to revoke this I/A Approval.

1.6 If the Rules are revised during the term of this I/A Approval, it shall be required to be revised as needed to conform to the Rules revisions.

1.7 Site-specific permission for the use of this technology is required in the form of a Wastewater System and Potable Water Supply Permit (WW Permit).

1.8 This I/A Approval is not a representation or guarantee of the effectiveness, efficiency, or operation of the approved technology.

1.9 This I/A Approval is limited to treating septic tank effluent that is characterized as low strength according to §1-805(b) of the Rules.

1.10 This I/A Approval is based on information submitted by the Applicant indicating that the technology will effectively distribute and treat the effluent.

1.11 Upon issuance of a site-specific WW Permit, each corresponding Vermont landowner in interest shall be shown a copy of this Wastewater System and Potable Water Supply Innovative and Alternative Technology General Use Approval, the Operation and Maintenance manual(s), and projected maintenance costs, prior to the installation of any permitted unit.

1.12 All components of the technology shall be warrantied for at least the first two (2) years following commencement of use of the I/A technology unit. The I/A Approval Recipient shall have an inventory of replacement parts available locally or available for delivery within 24 hours.

1.13 All conditions set forth in WW Permits that include the use of the approved technology shall remain in effect and may surpass the conditions set herein.

1.14 A WW Permit that approves the use of a technology approved by this I/A Approval remains valid for the use of the technology identified in the WW Permit even if this I/A Approval expires.

2. DOCUMENTS

2.1 The approval of the I/A technology is based on the following documents submitted by the Applicant:

Title	Submission Date	Revision
Design and Installation Manual for Infiltrator Chambers – Vermont (January 2022)	02/20/2026	-
VT-ANR Innovative and Alternative Technology Renewal Application	02/20/2026	02/27/2026

2.2 Use of the I/A technology in any way not depicted or described in the referenced documents, or otherwise not identified and authorized by this I/A Approval, is not allowed without prior approval by the Drinking Water and Groundwater Protection Division.

3. Inspection and Diagnostic Professionals

3.1 The Applicant has designated all Vermont Licensed Wastewater Designers (Classes 1, B, and BW) as Inspection and Diagnostic Professionals for the State of Vermont (Vermont I/D Professional) to perform the inspections, maintenance, and repairs required by this I/A Approval and by conditions of the corresponding WW Permit.

3.2 The I/A Approval Recipient shall maintain a minimum of three Vermont I/D Professionals. Failure to maintain a minimum of three Vermont I/D Professionals will result in the Secretary prohibiting the issuance of a WW Permit with the approved technology.

3.3 The I/A Approval Recipient deems that all Vermont Licensed Wastewater Designers (Classes 1, B, and BW) have sufficient knowledge and understanding for the proper installation, operation, maintenance, and repair of each approved technology.

3.4 Vermont I/D Professionals must follow the I/A Approval Recipient's, and the associated WW Permit's, conditions for inspection, maintenance, and reporting requirements.

3.5 Maintenance and inspections of the approved technology must be performed by a Vermont I/D Professional authorized by the I/A Approval Recipient. Reports shall be provided to the I/A Approval Recipient, landowner, and Division in a timely manner so that they can ensure conditions of the WW Permits are met.

3.6 Maintenance and inspections performed by Vermont I/D Professionals shall be in accordance with the operation and maintenance manual submitted as part of the I/A Approval renewal application, as provided in trainings by the I/A Recipient, and as specified in the WW Permits issued by this Division.

3.7 Any performance issues with this technology including, but not limited to, premature failure of the wastewater system, must be reported to the I/A Approval Recipient by the Vermont I/D Professional within 72 hours, so that the I/A Approval Recipient may be involved in the determination of the cause and be able to meet reporting requirements to the Division.

4. REPORTS

4.1 The I/A Approval Recipient shall submit electronically by April 1st of each year an annual report to the Division containing the following information for the previous 12-month period ending December 31st:

A. the entities who are distributing the permitted technology in the State of Vermont; and

B. an analysis of all sites that were deemed to have a performance issue involving the technology including, but not limited to, premature failure of the system, which shall include:
   i. the corresponding WW Permit number;
   ii. the property's SPAN number;
   iii. the name of the installer;
   iv. the name of the Vermont-licensed Designer who determined there was a performance issue with the system;
   v. the name of the Vermont-licensed Designer who provided the installation certification;
   vi. the date installed;
   vii. the date a performance issue was determined to exist;
   viii. a description of the performance issue;
   ix. potential/known causes of the performance issue;
   x. a listing of the required repair/remediation; and
   xi. identification of changes to the technology specification.

4.2 The I/A Approval Recipient shall ensure that the Vermont I/D Professional for each of the permitted systems utilizing this technology installed in Vermont are submitting to the Division the following reports:

A. an inspection report of the I/A technology for those systems which specify a required inspection in the WW Permit.

4.3 Maintenance and inspection reports shall be submitted on the Secretary-approved inspection report form and shall be signed and dated by the Vermont I/D Professional.

4.4 Inspection reports by the Vermont I/D Professional shall include, but not be limited to, a summary of all known problems, damages, and/or failures of the technology to comply with this I/A Approval and the operating requirements for the technology, as follows:

A. a description of any problems, damages, and/or failures;

B. potential/known causes of any problems, damages, and/or failures;

C. a statement of system operability including whether or not the technology is operating in compliance with this approval and operating specifications following repairs or corrections of any problems, damages, and/or failures;

D. a listing of the required repair/remediation;

E. identification of changes to the technology specifications; and

F. any observed failure of the wastewater system including wastewater exposed to the open air, wastewater pooling on the surface of the ground, wastewater discharging directly to surface water, or wastewater backing up into the building or structure.

4.5 Problems, damages, and/or failures of the technology identified during an investigation or inspection must be reported by the Vermont I/D Professional immediately to the landowner and I/A Approval Recipient, and within 30 days to the Division.

4.6 Maintenance and inspections shall be performed in accordance with the permitted operation and maintenance manual that are specified in the WW Permits issued by this Division.

5. DESIGN SPECIFICATIONS

5.1 The design of a wastewater system using the approved technology shall identify the specific approved model and shall not be replaced with any other model without an amendment to the WW Permit.

5.2 Certain components of I/A technologies shall be equipped with anti-flotation devices. The I/A Approval Recipient may specify whether or not an anti-flotation device is required, if a designer demonstrates that flotation will not occur or if the designer proposes in an application an effective alternative method to stabilize the technology that complies with the I/A Approval Recipient's requirements for installation.

5.3 Technology model choice and sizing shall be in accord with the I/A Approval Recipient's technical requirements approved by the Secretary. Sizing of each unit shall be based on the calculated design flow per §1-803 of the Rules.

6 INSTALLATION SPECIFICATIONS

6.1 The approved technology shall be installed under the guidance of a Vermont Designer.

6.2 The installation of each technology shall be in accordance with the I/A Approval Recipient's technical requirements approved by the Secretary.

Any person aggrieved by this permit may appeal to the Environmental Court within 30 days of the date of issuance of this permit in accordance with 10 V.S.A. Chapter 220 and the Vermont Rules of Environmental Court Proceedings.

Julia S. Moore, Secretary
Agency of Natural Resources

By David R. Swift
David R. Swift, Environmental Analyst – Wastewater Technical Services
Drinking Water and Groundwater Protection Division

Dated at Rutland, Vermont this __30th__ day of __April_____, 2026.