VERMONT

State of Vermont
Department of Environmental Conservation

Agency of Natural Resources
Drinking Water and Groundwater Protection Division

WASTEWATER SYSTEM AND POTABLE WATER SUPPLY PERMIT

LAWS/REGULATIONS INVOLVED

10 V.S.A. Chapter 64, Potable Water Supply and Wastewater System Permit
Wastewater System and Potable Water Supply Rules, Effective November 6, 2023

Permittee(s): Giovani Querido and David Ostafin
1 Wall Street
Bolton, CT 06043

Permit Number: WW-2-7902-1

This permit affects the following property/properties in Dover, Vermont:

Lot	Parcel	SPAN	Acres	Book(s)/Page(s)#
2	CP021-A	183-058-10829	12.58	Book:401 Page(s):149

This application, a permit amendment for Lot 2 (WW-2-7902) to modify the proposed wastewater system design utilizing gravity distribution on the proposed mound system with the house and well to remain in their previously permitted locations and no changes in design flow proposed, located at Lot 2 Higley Hill Road, East Dover in Dover, Vermont, is hereby approved under the requirements of the regulations named above subject to the following conditions. Any person aggrieved by this permit may appeal to the Environmental Court within 30 days of the date of issuance of this permit in accordance with 10 V.S.A. Chapter 220 and the Vermont Rules of Environmental Court Proceedings.

1. GENERAL

1.1. The permittee is responsible for recording this permit in the Dover Land Records within 30 days of issuance of this permit and prior to the conveyance of any lot subject to the jurisdiction of this permit.

1.2. The permittee is responsible for recording the design and installation certifications and other documents that are required to be filed under these Rules or under a permit condition in the Dover Land Records.

1.3. Each assign or successor in interest shall be shown a copy of the Wastewater System and Potable Water Supply Permit and the stamped plan(s) prior to the conveyance of a lot.

1.4. All previous permits and/or Certifications of Compliance issued by the Drinking Water and Groundwater Protection Division for this property shall remain in full effect except where specifically modified or amended herein.

1.5. The wastewater system includes the use of an Innovative/Alternative component. Each prospective owner of a lot that utilizes an Innovative/Alternative component shall be shown a copy of **Innovative/Alternative System Approval # 2006-04-R9 for General Use of Infiltrator® Quick4 Chambers** prior to conveyance of the lot.

1.6. By acceptance of this permit, the permittee agrees to allow representatives of the State of Vermont access to the property covered by the permit, at reasonable times, for the purpose of ascertaining compliance with the Vermont environmental and health statutes and regulations, and permit conditions.

1.7. The Drinking Water and Groundwater Protection Division relied upon the Vermont Licensed Designer's certification that the design-related information submitted is true and correct and complies with the Wastewater System and Potable Water Supply Rules. This permit may be revoked if it is determined the design of the wastewater system or potable water supply does not comply with these rules.

1.8. This permit does not relieve the landowner from obtaining all other approvals and permits from other State Agencies or Departments or local officials prior to construction.

2. CONSTRUCTION

2.1. Construction shall be completed as shown on the plans and/or documents prepared by John E. Dupras, with the stamped plans listed as follows:

Title	Sheet	Plan Date	Revision
Wastewater Disposal System and Potable Water Supply Design	C-1	07/16/2026	07/16/2026
Wastewater Disposal System and Potable Water Supply Design	C-2	07/16/2026	07/16/2026

2.2. Construction of wastewater systems or potable water supplies, or buildings or structures (as defined by the Wastewater System and Potable Water Supply Rules), or campgrounds, not depicted on the stamped plans, or identified in this permit, is not allowed without prior approval by the Drinking Water and Groundwater Protection Division.

2.3. No buildings, roads, earthwork, re-grading, excavation, or other construction that might interfere with the operation of the wastewater system or potable water supply are allowed on or near the site-specific wastewater system, wastewater replacement area, or potable water supply depicted on the stamped plans. Adherence to all isolation distances that are set forth in the Wastewater System and Potable Water Supply Rules are required.

3. INSPECTIONS

3.1. No permit issued by the Secretary shall be valid for a substantially completed potable water supply and wastewater system until the Secretary receives a signed and dated certification from a qualified Vermont Licensed Designer (or where allowed, the installer) on a Secretary-approved form that states: *"I hereby certify that, in the exercise of my reasonable professional judgment, the installation-related information submitted is true and correct and the potable water supply and wastewater system were installed in accordance with the permitted design and all permit conditions, were inspected, were properly tested, and have successfully met those performance tests."* or which satisfies the requirements of §1-311 of the referenced rules.

3.2. Prior to the use of the potable water supply, the permittee shall collect untreated water and test for Arsenic, Escherichia coli (E. coli), Fluoride, Lead, Manganese, Nitrate as N, Nitrite as N, Total Coliform Bacteria, Uranium, Adjusted Gross Alpha Particle Activity, Chloride, Sodium, Iron, and pH. The Lead sample shall be a first-draw. All water quality tests shall be conducted at a laboratory certified by the Vermont Department of Health (a list of which can be found on the VDH website). Results of the water tests shall be submitted to the Vermont Department of Health prior to use or at the submission of the Installation Certification required in Condition 3.1, whichever comes first.

4. DESIGN FLOW

4.1. The following table provides the flows that the wastewater system and potable water supply are designed to accept based on existing and proposed lot and building uses. The design flows in gallons per day (gpd) in the following table are derived from section 1-803 of the Rules:

Lot	Building	Building Use / Design Flow Basis	Wastewater	Water
2	1	4-bedroom single-family home for up to 7 occupants	490	490

The table above reflects the designed capacity for wastewater systems and potable water supplies derived from the uses documented in the permit application. If additional capacities are needed, a permit amendment will be required for the total design flows.

5. WASTEWATER SYSTEM

5.1. Prior to the construction or site work, a designer shall flag the proposed leachfield, and the owner shall maintain the flags until commencement of construction of the system.

5.2. Should a wastewater system fail and not qualify as a minor repair or for an exemption, the landowner shall engage a qualified Licensed Designer to evaluate the cause of the failure and submit an application to the Drinking Water and Groundwater Protection Division, and obtain approval thereof, prior to correcting the failure.

5.3. Should the wastewater system approved in this permit experience future performance issues, including but not limited to failure, the landowner shall engage a qualified Licensed Designer who will contact one of the technology's listed Service Providers regarding the performance issue and permit the Service Provider to inspect the site to ensure reporting requirements of the Innovative/Alternative Approval may be met.

5.4. This permit does not relieve the permittee of the obligations of Title 10, Chapter 48, Subchapter 4, for the protection of groundwater.

6. POTABLE WATER SUPPLY

6.1. Prior to construction or site work on the lot, a designer shall flag the center of the proposed potable water source, and the owner shall maintain the flag until commencement of construction of the source.

6.2. Should a potable water supply fail and not qualify as a minor repair or for an exemption, the landowner shall engage a qualified licensed Designer to evaluate the cause of the failure and submit an application to the Drinking Water and Groundwater Protection Division, and obtain approval thereof, prior to correcting the failure.

Julia S. Moore, Secretary
Agency of Natural Resources

By _____ Dated August 19, 2026
Jeff Svec, Regional Engineer
Springfield Regional Office
Drinking Water and Groundwater Protection Division

Enclosure: I/A Approval Letter

cc: John E. Dupras