



PUSEY
ELECTRIC

301 State Road, Media PA 19063
Phone: (610) 566-1972 Fax: 610-891-9296

**APPROVAL OF ELECTRICAL LAYOUT
PRIOR TO DRYWALL INSTALLATION**

NAME:	Zareh & Jolee Zohrabian	DATE:	12/22/2020
JOBSITE:	Marsh lea	LOT#	16

This certifies that the buyer(s) has reviewed the layout and location of all electrical devices including, but not limited to, switches, receptacles, light fixture locations (including recessed lights), phones and TV jacks, central vacuum ports and intercom locations. At this time, the Builder is authorized to complete drywall installation.

Exception/revision needed (If none, please indicate):

Finished theater room in the basement	
Add 4 Recessed lights in the newly finished room in the basement controlled by a single pole switch at the entrance.	\$ 660.00
Add 6 receptacles protected by a GFI (unfinished floor) around the room to meet code	\$ 445.00
Finished basement main room	
Install 4 wafer lights in place of the recessed lights under the duct work	N/C
Unfished area panel side	
Add 2 GFI receptacles	\$ 170.00
Unfished area bathroom side	
Add 2 GFI receptacles	\$ 170.00
TOTAL DUE FROM OWNERS PER PRE-DRYWALL INSPECTION:	\$ 1,445.00

DocuSigned by:
Zareh Zohrabian
AA21D0EFF8AA468...

DocuSigned by:
Jolee Persco Zohrabian
OWNERS REQUIRED SIGNATURE