

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

General Information

Meter Serial Number	0.0.96.1.0.255	XB485951
Application Firmware/Clem Name	1.0.0.0.1.255	M2X7G06
DLMS Firmware Version	1.0.0.2.0.255	M1XXG04
Meter Date-Time	0.0.1.0.0.255	28/02/2026 15:31:27
Current Tariff	1.0.96.141.1.255	R1TOD25
Old Tariff	1.0.96.141.1.101	R1TOD25
Manufacturer Name	0.0.96.1.1.255	SECURE METERS LTD.
Manufacturer Year	0.0.96.1.4.255	2017
Logical Device Name	0.0.42.0.0.255	EHLE3Txxx
Commissioned CT Ratio	1.0.0.4.2.255	20
Commissioned PT Ratio	1.0.0.4.3.255	1
Meter Type	0.0.94.91.9.255	LT(3ph-4W) 5 A Ib, 10 A Imax
Meter Class	1.0.96.141.0.255	Class 0.5 s
Meter Constant	1.0.0.3.0.255	400.000000 pulses / kWh
Meter P.T. Rating		240V
Meter C.T. Rating		100/5A
Category	0.0.94.91.11.255	B
Current Rating	0.0.94.91.12.255	5 - 10
Apparent Energy Definition	1.0.96.141.2.255	Lag only when kW+ve and Lag+Lead when kW-ve

Billing Dates

Period	Billing Date	Duration	Cause of Billing
History 1	01/02/2026 00:00:00	31 days	Auto
History 2	01/01/2026 00:00:00	31 days	Auto
History 3	01/12/2025 00:00:00	30 days	Auto
History 4	01/11/2025 00:00:00	31 days	Auto
History 5	01/10/2025 00:00:00	0 days	Auto
History 6	01/10/2025 00:00:00	30 days	Start of delayed start tariff
History 7	01/09/2025 00:00:00	31 days	Auto
History 8	01/08/2025 00:00:00	31 days	Auto
History 9	01/07/2025 00:00:00	30 days	Auto
History 10	01/06/2025 00:00:00	31 days	Auto
History 11	01/05/2025 00:00:00	30 days	Auto
History 12	01/04/2025 00:00:00	---	Auto

Main Energy

Param 1: Active(I) Total (Channel 1) (1.0.1.8.0.255)

Param 2: Active(E) Total (Channel 2) (1.0.2.8.0.255)

Param 3: Active(I) (Channel 3) (1.0.129.8.0.255)

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Param 4: Active(E) (Channel 4) (1.0.130.8.0.255)

Param 5: Reactive(I)-Active(I) (Channel 5) (1.0.5.8.0.255)

Param 6: Reactive(I)-Active(E) (Channel 6) (1.0.6.8.0.255)

Param 7: Reactive(E)-Active(E) (Channel 7) (1.0.7.8.0.255)

Param 8: Reactive(E)-Active(I) (Channel 8) (1.0.8.8.0.255)

Param 9: Apparent-Active(I) - type 2 (Channel 9) (1.0.9.8.0.255)

Param 10: Apparent-Active(E) - type 6 (Channel 10) (1.0.10.8.0.255)

Param 11: Net Reactive High (Channel 11) (1.0.94.91.1.255)

Param 12: Net Reactive Low (Channel 12) (1.0.94.91.2.255)

Param 13: Net Active (Channel 13) (1.0.16.8.0.255)

Period	Param 1 kWh	Param 2 kWh	Param 3 kWh	Param 4 kWh	Param 5 kVAh	Param 6 kVAh	Param 7 kVAh	Param 8 kVAh	Param 9 kVAh	Param 10 kVAh
Current	229054.00	86830.40	229624.20	86288.80	23710.40	21076.40	5449.20	37502.00	236605.00	95521.20
History 1	226911.20	86264.40	227479.00	85726.60	23425.60	20732.80	5445.20	37428.40	234349.20	94787.80
History 2	224506.60	85581.80	225081.20	85045.00	23139.40	20388.80	5439.00	37330.60	231835.60	93950.40
History 3	222097.80	84967.60	222687.20	84429.60	22859.40	19993.80	5435.20	37232.00	229317.60	93155.40
History 4	219771.20	84278.20	220359.00	83743.60	22603.00	19654.00	5428.60	37123.80	226899.80	92320.60
History 5	217294.40	83480.00	217894.00	82944.60	22312.60	19412.60	5411.80	36986.40	224338.20	91429.60
History 6	217294.40	83480.00	217894.00	82944.60	22312.60	19412.60	5411.80	36986.40	224338.20	91429.60
History 7	214704.00	83121.00	215293.00	82587.80	21903.20	19297.40	5400.20	36738.80	221626.40	91026.40
History 8	212146.80	82737.60	212737.20	82204.80	21471.20	19205.40	5375.40	36464.20	218940.40	90600.80
History 9	208321.80	82721.40	208909.00	82188.60	20932.20	19191.60	5375.20	36185.80	215028.40	90577.60
History 10	206010.60	82280.60	206590.60	81749.80	20538.20	19067.40	5341.80	35875.60	212595.60	90079.40
History 11	203568.40	81664.40	204137.20	81137.60	20129.80	18854.60	5317.40	35575.00	210020.40	89372.20
History 12	201558.00	80908.60	202122.80	80384.80	19825.80	18540.80	5293.20	35283.60	207882.00	88472.40

Period	Param 11 kVAh	Param 12 kVAh	Param 13 kWh
Current	-19352.40	2582.60	142223.40
History 1	-19588.00	2579.40	140646.80
History 2	-19831.80	2577.00	138924.80
History 3	-20044.60	2575.80	137130.20
History 4	-20057.20	2574.00	135492.80
History 5	-19976.80	2567.80	133814.20
History 6	-19976.80	2567.80	133814.20
History 7	-19943.00	2567.60	131583.00
History 8	-19895.60	2546.00	129409.00
History 9	-19810.80	2496.60	125600.20
History 10	-19623.60	2483.00	123730.00
History 11	-19486.80	2454.20	121903.80
History 12	-19291.60	2375.20	120649.20

	XB485951 - Readings				EMF (Applied)		
	Source: XB48595120260228150730.cdf				Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12				1.00	1.00	1.00

Main Consumption

Param 1: Active(I) Total (Channel 1) (1.0.1.9.0.255)

Param 2: Active(E) Total (Channel 2) (1.0.2.9.0.255)

Param 3: Active(I) (Channel 3) (1.0.129.9.0.255)

Param 4: Active(E) (Channel 4) (1.0.130.9.0.255)

Param 5: Reactive(I)-Active(I) (Channel 5) (1.0.5.9.0.255)

Param 6: Reactive(I)-Active(E) (Channel 6) (1.0.6.9.0.255)

Param 7: Reactive(E)-Active(E) (Channel 7) (1.0.7.9.0.255)

Param 8: Reactive(E)-Active(I) (Channel 8) (1.0.8.9.0.255)

Param 9: Apparent-Active(I) - type 2 (Channel 9) (1.0.9.9.0.255)

Param 10: Apparent-Active(E) - type 6 (Channel 10) (1.0.10.9.0.255)

Period	Param 1 kWh	Param 2 kWh	Param 3 kWh	Param 4 kWh	Param 5 kVArh	Param 6 kVArh	Param 7 kVArh	Param 8 kVArh	Param 9 kVAh	Param 10 kVAh
Current	2142.80	566.00	2145.20	562.20	284.80	343.60	4.00	73.60	2255.80	733.40
History 1	2404.60	682.60	2397.80	681.60	286.20	344.00	6.20	97.80	2513.60	837.40
History 2	2408.80	614.20	2394.00	615.40	280.00	395.00	3.80	98.60	2518.00	795.00
History 3	2326.60	689.40	2328.20	686.00	256.40	339.80	6.60	108.20	2417.80	834.80
History 4	2476.80	798.20	2465.00	799.00	290.40	241.40	16.80	137.40	2561.60	891.00
History 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
History 6	2590.40	359.00	2601.00	356.80	409.40	115.20	11.60	247.60	2711.80	403.20
History 7	2557.20	383.40	2555.80	383.00	432.00	92.00	24.80	274.60	2686.00	425.60
History 8	3825.00	16.20	3828.20	16.20	539.00	13.80	0.20	278.40	3912.00	23.20
History 9	2311.20	440.80	2318.40	438.80	394.00	124.20	33.40	310.20	2432.80	498.20
History 10	2442.20	616.20	2453.40	612.20	408.40	212.80	24.40	300.60	2575.20	707.20
History 11	2010.40	755.80	2014.40	752.80	304.00	313.80	24.20	291.40	2138.40	899.80

Power Factor

Period	Calculated Avg Imp Power Factor (signed) (1.0.13.0.0.255)
Current	0.95
History 1	0.96
History 2	0.96
History 3	0.96
History 4	0.97
History 5	1.00
History 6	0.96
History 7	0.95
History 8	0.98
History 9	0.95
History 10	0.95
History 11	0.94

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Period 11 Calculated Avg Exp Power Factor (signed) (1.0.84.0.0.255)

Current -0.77

MD Reset Dates

MD Reset Dates	MD Reset Mechanism
History 1 25/02/2026 05:00:00	Auto
History 2 08/02/2026 02:00:00	Auto
History 3 25/02/2026 05:00:00	Auto
History 4 08/02/2026 02:00:00	Auto
History 5 25/02/2026 05:00:00	Auto
History 6 08/02/2026 02:00:00	Auto
History 7 25/02/2026 05:00:00	Auto
History 8 08/02/2026 02:00:00	Start of delayed start tariff
History 9 25/02/2026 05:00:00	Auto
History 10 08/02/2026 02:00:00	Auto
01/07/2025 00:00:00	Auto
01/06/2025 00:00:00	Auto
01/05/2025 00:00:00	Auto
01/04/2025 00:00:00	Auto

Maximum Demand

Current

Parameter	Obis Code	Value	Date Time
Active(I) Total (Channel 1)	1.0.1.6.0.255	9.34 kW	25/02/2026 05:00 PM
Active(E) Total (Channel 2)	1.0.2.6.0.255	12.42 kW	08/02/2026 02:00 PM
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.0.255	10.04 kVA	25/02/2026 05:00 PM
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.0.255	12.42 kVA	08/02/2026 02:00 PM

Parameter	MD/Trigger
Active(I) Total (Channel 1)	Active(I) Total (MD)
Active(E) Total (Channel 2)	Active(E) Total (MD)
Apparent-Active(I) - type 2 (Channel 3)	Apparent-Active(I) - type 2 (MD)
Apparent-Active(E) - type 6 (Channel 4)	Apparent-Active(E) - type 6 (MD)

History 1

Parameter	Obis Code	Value	Date Time
Active(I) Total (Channel 1)	1.0.1.6.0.101	8.80 kW	13/01/2026 06:00 PM
Active(E) Total (Channel 2)	1.0.2.6.0.101	11.76 kW	18/01/2026 01:00 PM
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.0.101	9.28 kVA	13/01/2026 06:00 PM
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.0.101	11.74 kVA	18/01/2026 01:00 PM

Parameter	MD/Trigger
Active(I) Total (Channel 1)	Active(I) Total (MD)
Active(E) Total (Channel 2)	Active(E) Total (MD)
Apparent-Active(I) - type 2 (Channel 3)	Apparent-Active(I) - type 2 (MD)

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Apparent-Active(E) - type 6 (Channel 4) Apparent-Active(E) - type 6 (MD)

History 2

Parameter	Obis Code	Value	Date Time
Active(I) Total (Channel 1)	1.0.1.6.0.102	8.80 kW	18/12/2025 06:00 PM
Active(E) Total (Channel 2)	1.0.2.6.0.102	10.06 kW	28/12/2025 01:30 PM
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.0.102	9.50 kVA	18/12/2025 06:00 PM
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.0.102	10.06 kVA	28/12/2025 01:30 PM

Parameter	MD/Trigger
Active(I) Total (Channel 1)	Active(I) Total (MD)
Active(E) Total (Channel 2)	Active(E) Total (MD)
Apparent-Active(I) - type 2 (Channel 3)	Apparent-Active(I) - type 2 (MD)
Apparent-Active(E) - type 6 (Channel 4)	Apparent-Active(E) - type 6 (MD)

History 3

Parameter	Obis Code	Value	Date Time
Active(I) Total (Channel 1)	1.0.1.6.0.103	9.70 kW	25/11/2025 06:00 PM
Active(E) Total (Channel 2)	1.0.2.6.0.103	11.90 kW	16/11/2025 01:00 PM
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.0.103	10.26 kVA	25/11/2025 06:00 PM
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.0.103	11.92 kVA	16/11/2025 01:00 PM

Parameter	MD/Trigger
Active(I) Total (Channel 1)	Active(I) Total (MD)
Active(E) Total (Channel 2)	Active(E) Total (MD)
Apparent-Active(I) - type 2 (Channel 3)	Apparent-Active(I) - type 2 (MD)
Apparent-Active(E) - type 6 (Channel 4)	Apparent-Active(E) - type 6 (MD)

History 4

Parameter	Obis Code	Value	Date Time
Active(I) Total (Channel 1)	1.0.1.6.0.104	9.66 kW	16/10/2025 06:00 PM
Active(E) Total (Channel 2)	1.0.2.6.0.104	13.88 kW	02/10/2025 12:30 PM
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.0.104	9.96 kVA	27/10/2025 06:00 PM
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.0.104	13.88 kVA	02/10/2025 12:30 PM

Parameter	MD/Trigger
Active(I) Total (Channel 1)	Active(I) Total (MD)
Active(E) Total (Channel 2)	Active(E) Total (MD)
Apparent-Active(I) - type 2 (Channel 3)	Apparent-Active(I) - type 2 (MD)
Apparent-Active(E) - type 6 (Channel 4)	Apparent-Active(E) - type 6 (MD)

History 5

Parameter	Obis Code	Value	Date Time
Active(I) Total (Channel 1)	1.0.1.6.0.105	0.02 kW	01/10/2025 12:30 AM

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Active(E) Total (Channel 2)	1.0.2.6.0.105	0.00 kW	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.0.105	0.00 kVA	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.0.105	0.00 kVA	---

Parameter	MD/Trigger
Active(I) Total (Channel 1)	Active(I) Total (MD)
Active(E) Total (Channel 2)	Active(E) Total (MD)
Apparent-Active(I) - type 2 (Channel 3)	Apparent-Active(I) - type 2 (MD)
Apparent-Active(E) - type 6 (Channel 4)	Apparent-Active(E) - type 6 (MD)

History 6

Parameter	Obis Code	Value	Date Time
Active(I) Total (Channel 1)	1.0.1.6.0.106	10.08 kW	19/09/2025 07:00 PM
Active(E) Total (Channel 2)	1.0.2.6.0.106	9.92 kW	21/09/2025 04:00 PM
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.0.106	10.56 kVA	19/09/2025 07:00 PM
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.0.106	9.92 kVA	21/09/2025 04:00 PM

Parameter	MD/Trigger
Active(I) Total (Channel 1)	Active(I) Total (MD)
Active(E) Total (Channel 2)	Active(E) Total (MD)
Apparent-Active(I) - type 2 (Channel 3)	Apparent-Active(I) - type 2 (MD)
Apparent-Active(E) - type 6 (Channel 4)	Apparent-Active(E) - type 6 (MD)

History 7

Parameter	Obis Code	Value	Date Time
Active(I) Total (Channel 1)	1.0.1.6.0.107	15.40 kW	13/08/2025 06:00 PM
Active(E) Total (Channel 2)	1.0.2.6.0.107	13.62 kW	10/08/2025 02:30 PM
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.0.107	18.36 kVA	13/08/2025 06:00 PM
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.0.107	13.66 kVA	10/08/2025 02:30 PM

Parameter	MD/Trigger
Active(I) Total (Channel 1)	Active(I) Total (MD)
Active(E) Total (Channel 2)	Active(E) Total (MD)
Apparent-Active(I) - type 2 (Channel 3)	Apparent-Active(I) - type 2 (MD)
Apparent-Active(E) - type 6 (Channel 4)	Apparent-Active(E) - type 6 (MD)

History 8

Parameter	Obis Code	Value	Date Time
Active(I) Total (Channel 1)	1.0.1.6.0.108	12.16 kW	26/07/2025 03:00 PM
Active(E) Total (Channel 2)	1.0.2.6.0.108	3.56 kW	29/07/2025 01:00 PM
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.0.108	13.14 kVA	26/07/2025 03:00 PM
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.0.108	4.58 kVA	29/07/2025 01:00 PM

Parameter	MD/Trigger
Active(I) Total (Channel 1)	Active(I) Total (MD)

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Active(E) Total (Channel 2)	Active(E) Total (MD)
Apparent-Active(I) - type 2 (Channel 3)	Apparent-Active(I) - type 2 (MD)
Apparent-Active(E) - type 6 (Channel 4)	Apparent-Active(E) - type 6 (MD)

History 9

Parameter	Obis Code	Value	Date Time
Active(I) Total (Channel 1)	1.0.1.6.0.109	9.28 kW	13/06/2025 06:00 PM
Active(E) Total (Channel 2)	1.0.2.6.0.109	12.32 kW	22/06/2025 12:30 PM
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.0.109	12.70 kVA	30/06/2025 02:00 PM
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.0.109	12.34 kVA	22/06/2025 12:30 PM

Parameter	MD/Trigger
Active(I) Total (Channel 1)	Active(I) Total (MD)
Active(E) Total (Channel 2)	Active(E) Total (MD)
Apparent-Active(I) - type 2 (Channel 3)	Apparent-Active(I) - type 2 (MD)
Apparent-Active(E) - type 6 (Channel 4)	Apparent-Active(E) - type 6 (MD)

History 10

Parameter	Obis Code	Value	Date Time
Active(I) Total (Channel 1)	1.0.1.6.0.110	11.12 kW	16/05/2025 03:00 PM
Active(E) Total (Channel 2)	1.0.2.6.0.110	13.06 kW	11/05/2025 12:30 PM
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.0.110	12.34 kVA	16/05/2025 03:00 PM
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.0.110	13.06 kVA	11/05/2025 12:30 PM

Parameter	MD/Trigger
Active(I) Total (Channel 1)	Active(I) Total (MD)
Active(E) Total (Channel 2)	Active(E) Total (MD)
Apparent-Active(I) - type 2 (Channel 3)	Apparent-Active(I) - type 2 (MD)
Apparent-Active(E) - type 6 (Channel 4)	Apparent-Active(E) - type 6 (MD)

History 11

Parameter	Obis Code	Value	Date Time
Active(I) Total (Channel 1)	1.0.1.6.0.111	12.86 kW	03/04/2025 05:00 PM
Active(E) Total (Channel 2)	1.0.2.6.0.111	13.18 kW	06/04/2025 01:30 PM
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.0.111	14.08 kVA	03/04/2025 05:00 PM
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.0.111	13.20 kVA	06/04/2025 01:30 PM

Parameter	MD/Trigger
Active(I) Total (Channel 1)	Active(I) Total (MD)
Active(E) Total (Channel 2)	Active(E) Total (MD)
Apparent-Active(I) - type 2 (Channel 3)	Apparent-Active(I) - type 2 (MD)
Apparent-Active(E) - type 6 (Channel 4)	Apparent-Active(E) - type 6 (MD)

History 12

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Parameter	Obis Code	Value	Date Time
Active(I) Total (Channel 1)	1.0.1.6.0.112	8.28 kW	31/03/2025 06:00 PM
Active(E) Total (Channel 2)	1.0.2.6.0.112	13.58 kW	09/03/2025 01:30 PM
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.0.112	8.44 kVA	31/03/2025 06:00 PM
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.0.112	13.60 kVA	09/03/2025 01:30 PM

Parameter	MD/Trigger
Active(I) Total (Channel 1)	Active(I) Total (MD)
Active(E) Total (Channel 2)	Active(E) Total (MD)
Apparent-Active(I) - type 2 (Channel 3)	Apparent-Active(I) - type 2 (MD)
Apparent-Active(E) - type 6 (Channel 4)	Apparent-Active(E) - type 6 (MD)

Cumulative Maximum Demand

Param 1: Active(I) Total (Channel 1) (1.0.1.2.0.255)

Param 2: Active(E) Total (Channel 2) (1.0.2.2.0.255)

Param 3: Apparent-Active(I) - type 2 (Channel 3) (1.0.9.2.0.255)

Param 4: Apparent-Active(E) - type 6 (Channel 4) (1.0.10.2.0.255)

Period	Param 1 kW	Param 2 kW	Param 3 kVA	Param 4 kVA
Current	1134.50	1454.36	1195.16	1466.76

Time of Day Energy

Current

Param 1: Active(I) Total (Channel 1) (1.0.1.8.0.255)

Param 2: Active(E) Total (Channel 2) (1.0.2.8.0.255)

Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.8.0.255)

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.8.0.255)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.8.0.255)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.8.0.255)

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.8.0.255)

Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.8.0.255)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVAh	Param 4 kVAh	Param 5 kVAh	Param 6 kVAh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	94148.40	0.00	135.60	0.00	2.60	21108.20	94143.60	2.60
TOD/SLAB 2	68850.80	55519.00	16795.80	13169.40	3585.00	6814.00	74130.60	60951.60
TOD/SLAB 3	12199.60	31303.40	5241.60	7906.40	1854.20	544.60	14288.60	34553.00
TOD/SLAB 4	53855.20	8.00	1537.40	0.60	7.40	9035.20	54042.20	14.00
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 1

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Param 1: Active(I) Total (Channel 1) (1.0.1.8.0.101)
 Param 2: Active(E) Total (Channel 2) (1.0.2.8.0.101)
 Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.8.0.101)
 Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.8.0.101)
 Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.8.0.101)
 Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.8.0.101)
 Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.8.0.101)
 Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.8.0.101)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	93427.40	0.00	133.20	0.00	2.60	21074.20	93423.40	2.60
TOD/SLAB 2	68526.00	55519.00	16791.40	13169.40	3585.00	6802.20	73804.60	60951.60
TOD/SLAB 3	11996.80	30739.20	5061.40	7562.80	1850.20	544.60	13994.00	33821.20
TOD/SLAB 4	52961.00	6.20	1439.60	0.60	7.40	9007.40	53127.20	12.40
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 2

Param 1: Active(I) Total (Channel 1) (1.0.1.8.0.102)
 Param 2: Active(E) Total (Channel 2) (1.0.2.8.0.102)
 Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.8.0.102)
 Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.8.0.102)
 Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.8.0.102)
 Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.8.0.102)
 Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.8.0.102)
 Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.8.0.102)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	92651.00	0.00	132.20	0.00	2.60	21031.40	92647.00	2.60
TOD/SLAB 2	68168.60	55519.00	16788.00	13169.40	3585.00	6788.80	73447.20	60951.60
TOD/SLAB 3	11751.20	30058.20	4873.80	7218.80	1844.00	544.40	13657.40	32985.20
TOD/SLAB 4	51935.80	4.60	1345.40	0.60	7.40	8966.00	52084.00	11.00
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 3

Param 1: Active(I) Total (Channel 1) (1.0.1.8.0.103)
 Param 2: Active(E) Total (Channel 2) (1.0.2.8.0.103)
 Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.8.0.103)

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.8.0.103)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.8.0.103)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.8.0.103)

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.8.0.103)

Param 8: Apparent-Active(E) - type 2 (Channel 8) (1.0.10.8.0.103)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	91863.20	0.00	131.60	0.00	2.60	20985.60	91859.40	2.60
TOD/SLAB 2	67807.40	55519.00	16784.40	13169.40	3585.00	6774.80	73086.20	60951.60
TOD/SLAB 3	11555.40	29444.00	4700.60	6823.80	1840.20	544.20	13369.20	32190.20
TOD/SLAB 4	50871.80	4.60	1242.80	0.60	7.40	8927.40	51002.80	11.00
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 4

Param 1: Active(I) Total (Channel 1) (1.0.1.8.0.104)

Param 2: Active(E) Total (Channel 2) (1.0.2.8.0.104)

Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.8.0.104)

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.8.0.104)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.8.0.104)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.8.0.104)

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.8.0.104)

Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.8.0.104)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	91105.40	0.00	131.00	0.00	2.60	20937.60	91101.80	2.60
TOD/SLAB 2	67488.00	55519.00	16780.80	13169.40	3585.00	6760.60	72766.20	60951.60
TOD/SLAB 3	11337.60	28755.40	4532.80	6484.00	1833.60	543.60	13073.40	31356.20
TOD/SLAB 4	49840.20	3.80	1158.40	0.60	7.40	8882.00	49958.40	10.20
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 5

Param 1: Active(I) Total (Channel 1) (1.0.1.8.0.105)

Param 2: Active(E) Total (Channel 2) (1.0.2.8.0.105)

Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.8.0.105)

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.8.0.105)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.8.0.105)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.8.0.105)

	XB485951 - Readings				EMF (Applied)		
	Source: XB48595120260228150730.cdf				Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12				1.00	1.00	1.00

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.8.0.105)

Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.8.0.105)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	90349.80	0.00	130.60	0.00	2.60	20872.40	90346.60	2.60
TOD/SLAB 2	67202.40	55515.00	16779.80	13169.40	3584.80	6739.60	72480.00	60948.20
TOD/SLAB 3	10966.00	27962.40	4329.00	6243.00	1817.00	542.20	12629.20	30469.80
TOD/SLAB 4	48776.20	2.60	1073.20	0.20	7.40	8832.20	48882.40	9.00
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 6

Param 1: Active(I) Total (Channel 1) (1.0.1.8.0.106)

Param 2: Active(E) Total (Channel 2) (1.0.2.8.0.106)

Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.8.0.106)

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.8.0.106)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.8.0.106)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.8.0.106)

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.8.0.106)

Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.8.0.106)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	90349.80	0.00	130.60	0.00	2.60	20872.40	90346.60	2.60
TOD/SLAB 2	67202.40	55515.00	16779.80	13169.40	3584.80	6739.60	72480.00	60948.20
TOD/SLAB 3	10966.00	27962.40	4329.00	6243.00	1817.00	542.20	12629.20	30469.80
TOD/SLAB 4	48776.20	2.60	1073.20	0.20	7.40	8832.20	48882.40	9.00
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 7

Param 1: Active(I) Total (Channel 1) (1.0.1.8.0.107)

Param 2: Active(E) Total (Channel 2) (1.0.2.8.0.107)

Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.8.0.107)

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.8.0.107)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.8.0.107)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.8.0.107)

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.8.0.107)

Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.8.0.107)

	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
--	----------------	----------------	------------------	------------------	------------------	------------------	-----------------	-----------------

	XB485951 - Readings						EMF (Applied)		
	Source: XB48595120260228150730.cdf						Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12						1.00	1.00	1.00

Time of Day

TOD/SLAB 1	89431.20	0.00	129.40	0.00	2.60	20720.80	89427.20	2.60
TOD/SLAB 2	66314.00	55283.00	16487.20	13091.80	3579.20	6693.40	71504.20	60686.20
TOD/SLAB 3	10757.60	27835.40	4235.20	6205.40	1811.00	539.40	12389.40	30328.60
TOD/SLAB 4	48201.20	2.60	1051.40	0.20	7.40	8785.20	48305.60	9.00
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 8

Param 1: Active(I) Total (Channel 1) (1.0.1.8.0.108)

Param 2: Active(E) Total (Channel 2) (1.0.2.8.0.108)

Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.8.0.108)

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.8.0.108)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.8.0.108)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.8.0.108)

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.8.0.108)

Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.8.0.108)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	88500.80	0.00	126.00	0.00	2.60	20556.40	88495.40	2.60
TOD/SLAB 2	65487.00	54990.60	16198.40	13024.20	3561.60	6647.20	70587.00	60363.00
TOD/SLAB 3	10501.80	27744.40	4126.80	6181.00	1803.80	535.40	12100.20	30226.20
TOD/SLAB 4	47657.20	2.60	1020.00	0.20	7.40	8725.20	47757.80	9.00
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 9

Param 1: Active(I) Total (Channel 1) (1.0.1.8.0.109)

Param 2: Active(E) Total (Channel 2) (1.0.2.8.0.109)

Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.8.0.109)

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.8.0.109)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.8.0.109)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.8.0.109)

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.8.0.109)

Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.8.0.109)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	87586.80	0.00	124.80	0.00	2.60	20405.60	87581.00	2.60
TOD/SLAB 2	63771.60	54978.00	15816.60	13013.00	3561.60	6585.00	68809.00	60345.00

	XB485951 - Readings						EMF (Applied)		
	Source: XB48595120260228150730.cdf						Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12						1.00	1.00	1.00

TOD/SLAB 3	9855.60	27740.80	3991.40	6178.40	1803.60	525.20	11432.40	30221.00
TOD/SLAB 4	47107.80	2.60	999.40	0.20	7.40	8670.00	47206.00	9.00
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 10

Param 1: Active(I) Total (Channel 1) (1.0.1.8.0.110)
Param 2: Active(E) Total (Channel 2) (1.0.2.8.0.110)
Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.8.0.110)
Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.8.0.110)
Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.8.0.110)
Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.8.0.110)
Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.8.0.110)
Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.8.0.110)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	86725.80	0.00	124.80	0.00	2.60	20207.00	86719.00	2.60
TOD/SLAB 2	63016.00	54678.80	15535.20	12931.40	3541.80	6536.60	67964.00	60007.80
TOD/SLAB 3	9638.60	27599.20	3896.40	6135.80	1790.00	523.40	11185.20	30060.00
TOD/SLAB 4	46630.20	2.60	981.80	0.20	7.40	8608.60	46727.40	9.00
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 11

Param 1: Active(I) Total (Channel 1) (1.0.1.8.0.111)
Param 2: Active(E) Total (Channel 2) (1.0.2.8.0.111)
Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.8.0.111)
Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.8.0.111)
Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.8.0.111)
Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.8.0.111)
Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.8.0.111)
Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.8.0.111)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	85800.00	0.00	124.80	0.00	2.60	20017.80	85793.60	2.60
TOD/SLAB 2	62161.60	54279.40	15213.20	12794.40	3524.40	6493.40	67005.20	59547.80
TOD/SLAB 3	9502.40	27382.40	3828.00	6060.00	1783.00	520.40	11022.40	29812.80
TOD/SLAB 4	46104.40	2.60	963.80	0.20	7.40	8543.40	46199.20	9.00
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

	XB485951 - Readings							EMF (Applied)		
	Source: XB48595120260228150730.cdf							Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12							1.00	1.00	1.00

TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 12

Param 1: Active(I) Total (Channel 1) (1.0.1.8.0.112)

Param 2: Active(E) Total (Channel 2) (1.0.2.8.0.112)

Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.8.0.112)

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.8.0.112)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.8.0.112)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.8.0.112)

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.8.0.112)

Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.8.0.112)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	84904.00	0.00	124.80	0.00	2.60	19835.40	84897.60	2.60
TOD/SLAB 2	61599.40	53766.40	14963.40	12572.40	3509.00	6449.00	66335.20	58931.20
TOD/SLAB 3	9458.60	27139.60	3796.80	5968.20	1774.20	519.80	10961.80	29529.60
TOD/SLAB 4	45596.00	2.60	940.80	0.20	7.40	8479.40	45687.40	9.00
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Time of Day Consumption

Current

Param 1: Active(I) Total (Channel 1) (1.0.1.9.0.255)

Param 2: Active(E) Total (Channel 2) (1.0.2.9.0.255)

Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.9.0.255)

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.9.0.255)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.9.0.255)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.9.0.255)

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.9.0.255)

Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.9.0.255)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	721.00	0.00	2.40	0.00	0.00	34.00	720.20	0.00
TOD/SLAB 2	324.80	0.00	4.40	0.00	0.00	11.80	326.00	0.00
TOD/SLAB 3	202.80	564.20	180.20	343.60	4.00	0.00	294.60	731.80
TOD/SLAB 4	894.20	1.80	97.80	0.00	0.00	27.80	915.00	1.60
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

	XB485951 - Readings						EMF (Applied)		
	Source: XB48595120260228150730.cdf						Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12						1.00	1.00	1.00

TOD/SLAB 7 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00

TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
------------	------	------	------	------	------	------	------	------

History 1

Param 1: Active(I) Total (Channel 1) (1.0.1.9.0.101)

Param 2: Active(E) Total (Channel 2) (1.0.2.9.0.101)

Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.9.0.101)

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.9.0.101)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.9.0.101)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.9.0.101)

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.9.0.101)

Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.9.0.101)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	776.40	0.00	1.00	0.00	0.00	42.80	776.40	0.00
TOD/SLAB 2	357.40	0.00	3.40	0.00	0.00	13.40	357.40	0.00
TOD/SLAB 3	245.60	681.00	187.60	344.00	6.20	0.20	336.60	836.00
TOD/SLAB 4	1025.20	1.60	94.20	0.00	0.00	41.40	1043.20	1.40
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 2

Param 1: Active(I) Total (Channel 1) (1.0.1.9.0.102)

Param 2: Active(E) Total (Channel 2) (1.0.2.9.0.102)

Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.9.0.102)

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.9.0.102)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.9.0.102)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.9.0.102)

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.9.0.102)

Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.9.0.102)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	787.80	0.00	0.60	0.00	0.00	45.80	787.60	0.00
TOD/SLAB 2	361.20	0.00	3.60	0.00	0.00	14.00	361.00	0.00
TOD/SLAB 3	195.80	614.20	173.20	395.00	3.80	0.20	288.20	795.00
TOD/SLAB 4	1064.00	0.00	102.60	0.00	0.00	38.60	1081.20	0.00
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 3

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Param 1: Active(I) Total (Channel 1) (1.0.1.9.0.103)

Param 2: Active(E) Total (Channel 2) (1.0.2.9.0.103)

Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.9.0.103)

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.9.0.103)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.9.0.103)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.9.0.103)

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.9.0.103)

Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.9.0.103)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVAh	Param 4 kVAh	Param 5 kVAh	Param 6 kVAh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	757.80	0.00	0.60	0.00	0.00	48.00	757.60	0.00
TOD/SLAB 2	319.40	0.00	3.60	0.00	0.00	14.20	320.00	0.00
TOD/SLAB 3	217.80	688.60	167.80	339.80	6.60	0.60	295.80	834.00
TOD/SLAB 4	1031.60	0.80	84.40	0.00	0.00	45.40	1044.40	0.80
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 4

Param 1: Active(I) Total (Channel 1) (1.0.1.9.0.104)

Param 2: Active(E) Total (Channel 2) (1.0.2.9.0.104)

Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.9.0.104)

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.9.0.104)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.9.0.104)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.9.0.104)

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.9.0.104)

Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.9.0.104)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVAh	Param 4 kVAh	Param 5 kVAh	Param 6 kVAh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	755.60	0.00	0.40	0.00	0.00	65.20	755.20	0.00
TOD/SLAB 2	285.60	4.00	1.00	0.00	0.20	21.00	286.20	3.40
TOD/SLAB 3	371.60	793.00	203.80	241.00	16.60	1.40	444.20	886.40
TOD/SLAB 4	1064.00	1.20	85.20	0.40	0.00	49.80	1076.00	1.20
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 5

Param 1: Active(I) Total (Channel 1) (1.0.1.9.0.105)

Param 2: Active(E) Total (Channel 2) (1.0.2.9.0.105)

Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.9.0.105)

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.9.0.105)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.9.0.105)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.9.0.105)

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.9.0.105)

Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.9.0.105)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 2	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 3	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 4	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 6

Param 1: Active(I) Total (Channel 1) (1.0.1.9.0.106)

Param 2: Active(E) Total (Channel 2) (1.0.2.9.0.106)

Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.9.0.106)

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.9.0.106)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.9.0.106)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.9.0.106)

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.9.0.106)

Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.9.0.106)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	918.60	0.00	1.20	0.00	0.00	151.60	919.40	0.00
TOD/SLAB 2	888.40	232.00	292.60	77.60	5.60	46.20	975.80	262.00
TOD/SLAB 3	208.40	127.00	93.80	37.60	6.00	2.80	239.80	141.20
TOD/SLAB 4	575.00	0.00	21.80	0.00	0.00	47.00	576.80	0.00
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 7

Param 1: Active(I) Total (Channel 1) (1.0.1.9.0.107)

Param 2: Active(E) Total (Channel 2) (1.0.2.9.0.107)

Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.9.0.107)

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.9.0.107)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.9.0.107)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.9.0.107)

	XB485951 - Readings					EMF (Applied)		
	Source: XB48595120260228150730.cdf					Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12					1.00	1.00	1.00

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.9.0.107)

Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.9.0.107)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	930.40	0.00	3.40	0.00	0.00	164.40	931.80	0.00
TOD/SLAB 2	827.00	292.40	288.80	67.60	17.60	46.20	917.20	323.20
TOD/SLAB 3	255.80	91.00	108.40	24.40	7.20	4.00	289.20	102.40
TOD/SLAB 4	544.00	0.00	31.40	0.00	0.00	60.00	547.80	0.00
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 8

Param 1: Active(I) Total (Channel 1) (1.0.1.9.0.108)

Param 2: Active(E) Total (Channel 2) (1.0.2.9.0.108)

Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.9.0.108)

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.9.0.108)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.9.0.108)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.9.0.108)

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.9.0.108)

Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.9.0.108)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	914.00	0.00	1.20	0.00	0.00	150.80	914.40	0.00
TOD/SLAB 2	1715.40	12.60	381.80	11.20	0.00	62.20	1778.00	18.00
TOD/SLAB 3	646.20	3.60	135.40	2.60	0.20	10.20	667.80	5.20
TOD/SLAB 4	549.40	0.00	20.60	0.00	0.00	55.20	551.80	0.00
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 9

Param 1: Active(I) Total (Channel 1) (1.0.1.9.0.109)

Param 2: Active(E) Total (Channel 2) (1.0.2.9.0.109)

Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.9.0.109)

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.9.0.109)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.9.0.109)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.9.0.109)

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.9.0.109)

Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.9.0.109)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
-------------	----------------	----------------	------------------	------------------	------------------	------------------	-----------------	-----------------

	XB485951 - Readings						EMF (Applied)		
	Source: XB48595120260228150730.cdf						Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12						1.00	1.00	1.00

TOD/SLAB 1	861.00	0.00	0.00	0.00	0.00	198.60	862.00	0.00
TOD/SLAB 2	755.60	299.20	281.40	81.60	19.80	48.40	845.00	337.20
TOD/SLAB 3	217.00	141.60	95.00	42.60	13.60	1.80	247.20	161.00
TOD/SLAB 4	477.60	0.00	17.60	0.00	0.00	61.40	478.60	0.00
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 10

Param 1: Active(I) Total (Channel 1) (1.0.1.9.0.110)

Param 2: Active(E) Total (Channel 2) (1.0.2.9.0.110)

Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.9.0.110)

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.9.0.110)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.9.0.110)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.9.0.110)

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.9.0.110)

Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.9.0.110)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	925.80	0.00	0.00	0.00	0.00	189.20	925.40	0.00
TOD/SLAB 2	854.40	399.40	322.00	137.00	17.40	43.20	958.80	460.00
TOD/SLAB 3	136.20	216.80	68.40	75.80	7.00	3.00	162.80	247.20
TOD/SLAB 4	525.80	0.00	18.00	0.00	0.00	65.20	528.20	0.00
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

History 11

Param 1: Active(I) Total (Channel 1) (1.0.1.9.0.111)

Param 2: Active(E) Total (Channel 2) (1.0.2.9.0.111)

Param 3: Reactive(I)-Active(I) (Channel 3) (1.0.5.9.0.111)

Param 4: Reactive(I)-Active(E) (Channel 4) (1.0.6.9.0.111)

Param 5: Reactive(E)-Active(E) (Channel 5) (1.0.7.9.0.111)

Param 6: Reactive(E)-Active(I) (Channel 6) (1.0.8.9.0.111)

Param 7: Apparent-Active(I) - type 2 (Channel 7) (1.0.9.9.0.111)

Param 8: Apparent-Active(E) - type 6 (Channel 8) (1.0.10.9.0.111)

Time of Day	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
TOD/SLAB 1	896.00	0.00	0.00	0.00	0.00	182.40	896.00	0.00
TOD/SLAB 2	562.20	513.00	249.80	222.00	15.40	44.40	670.00	616.60

	XB485951 - Readings						EMF (Applied)		
	Source: XB48595120260228150730.cdf						Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12						1.00	1.00	1.00

TOD/SLAB 3	43.80	242.80	31.20	91.80	8.80	0.60	60.60	283.20
TOD/SLAB 4	508.40	0.00	23.00	0.00	0.00	64.00	511.80	0.00
TOD/SLAB 5	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 6	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOD/SLAB 8	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Time of Day Power Factor

Current

Time of Day	Calculated Avg Imp Power Factor (signed) (1.0.13.0.0.255)
TOD/SLAB 1	-1.00
TOD/SLAB 2	-1.00
TOD/SLAB 3	0.69
TOD/SLAB 4	0.98
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

Time of Day	Calculated Avg Exp Power Factor (signed) (1.0.84.0.0.255)
TOD/SLAB 1	1.00
TOD/SLAB 2	1.00
TOD/SLAB 3	-0.77
TOD/SLAB 4	1.00
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

History 1

Time of Day	Calculated Avg Imp Power Factor (signed) (1.0.13.0.0.255)
TOD/SLAB 1	-1.00
TOD/SLAB 2	-1.00
TOD/SLAB 3	0.73
TOD/SLAB 4	0.98
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

Time of Day	Calculated Avg Exp Power Factor (signed) (1.0.84.0.0.255)
TOD/SLAB 1	1.00
TOD/SLAB 2	1.00

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

TOD/SLAB 3	-0.82
TOD/SLAB 4	1.00
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

History 2

Time of Day	Calculated Avg Imp Power Factor (signed) (1.0.13.0.0.255)
TOD/SLAB 1	-1.00
TOD/SLAB 2	-1.00
TOD/SLAB 3	0.68
TOD/SLAB 4	0.98
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

Time of Day	Calculated Avg Exp Power Factor (signed) (1.0.84.0.0.255)
TOD/SLAB 1	1.00
TOD/SLAB 2	1.00
TOD/SLAB 3	-0.77
TOD/SLAB 4	1.00
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

History 3

Time of Day	Calculated Avg Imp Power Factor (signed) (1.0.13.0.0.255)
TOD/SLAB 1	-1.00
TOD/SLAB 2	-1.00
TOD/SLAB 3	0.74
TOD/SLAB 4	0.99
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

Time of Day	Calculated Avg Exp Power Factor (signed) (1.0.84.0.0.255)
TOD/SLAB 1	1.00
TOD/SLAB 2	1.00
TOD/SLAB 3	-0.83

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

TOD/SLAB 4	1.00
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

History 4

Time of Day	Calculated Avg Imp Power Factor (signed) (1.0.13.0.0.255)
TOD/SLAB 1	-1.00
TOD/SLAB 2	-1.00
TOD/SLAB 3	0.84
TOD/SLAB 4	0.99
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

Time of Day	Calculated Avg Exp Power Factor (signed) (1.0.84.0.0.255)
TOD/SLAB 1	1.00
TOD/SLAB 2	1.00
TOD/SLAB 3	-0.90
TOD/SLAB 4	-1.00
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

History 5

Time of Day	Calculated Avg Imp Power Factor (signed) (1.0.13.0.0.255)
TOD/SLAB 1	1.00
TOD/SLAB 2	1.00
TOD/SLAB 3	1.00
TOD/SLAB 4	1.00
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

Time of Day	Calculated Avg Exp Power Factor (signed) (1.0.84.0.0.255)
TOD/SLAB 1	1.00
TOD/SLAB 2	1.00
TOD/SLAB 3	1.00
TOD/SLAB 4	1.00

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

History 6

Time of Day	Calculated Avg Imp Power Factor (signed) (1.0.13.0.0.255)
TOD/SLAB 1	-1.00
TOD/SLAB 2	0.91
TOD/SLAB 3	0.87
TOD/SLAB 4	-1.00
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

Time of Day	Calculated Avg Exp Power Factor (signed) (1.0.84.0.0.255)
TOD/SLAB 1	1.00
TOD/SLAB 2	-0.89
TOD/SLAB 3	-0.90
TOD/SLAB 4	1.00
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

History 7

Time of Day	Calculated Avg Imp Power Factor (signed) (1.0.13.0.0.255)
TOD/SLAB 1	-1.00
TOD/SLAB 2	0.90
TOD/SLAB 3	0.89
TOD/SLAB 4	-0.99
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

Time of Day	Calculated Avg Exp Power Factor (signed) (1.0.84.0.0.255)
TOD/SLAB 1	1.00
TOD/SLAB 2	-0.91
TOD/SLAB 3	-0.89
TOD/SLAB 4	1.00
TOD/SLAB 5	1.00

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

History 8

Time of Day	Calculated Avg Imp Power Factor (signed) (1.0.13.0.0.255)
TOD/SLAB 1	-1.00
TOD/SLAB 2	0.96
TOD/SLAB 3	0.97
TOD/SLAB 4	-1.00
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

Time of Day	Calculated Avg Exp Power Factor (signed) (1.0.84.0.0.255)
TOD/SLAB 1	1.00
TOD/SLAB 2	-0.70
TOD/SLAB 3	-0.69
TOD/SLAB 4	1.00
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

History 9

Time of Day	Calculated Avg Imp Power Factor (signed) (1.0.13.0.0.255)
TOD/SLAB 1	-1.00
TOD/SLAB 2	0.89
TOD/SLAB 3	0.88
TOD/SLAB 4	-1.00
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

Time of Day	Calculated Avg Exp Power Factor (signed) (1.0.84.0.0.255)
TOD/SLAB 1	1.00
TOD/SLAB 2	-0.89
TOD/SLAB 3	-0.88
TOD/SLAB 4	1.00
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

History 10

Time of Day	Calculated Avg Imp Power Factor (signed) (1.0.13.0.0.255)
TOD/SLAB 1	-1.00
TOD/SLAB 2	0.89
TOD/SLAB 3	0.84
TOD/SLAB 4	-0.99
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

Time of Day	Calculated Avg Exp Power Factor (signed) (1.0.84.0.0.255)
TOD/SLAB 1	1.00
TOD/SLAB 2	-0.87
TOD/SLAB 3	-0.88
TOD/SLAB 4	1.00
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

History 11

Time of Day	Calculated Avg Imp Power Factor (signed) (1.0.13.0.0.255)
TOD/SLAB 1	-1.00
TOD/SLAB 2	0.84
TOD/SLAB 3	0.72
TOD/SLAB 4	-0.99
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00
TOD/SLAB 8	1.00

Time of Day	Calculated Avg Exp Power Factor (signed) (1.0.84.0.0.255)
TOD/SLAB 1	1.00
TOD/SLAB 2	-0.83
TOD/SLAB 3	-0.86
TOD/SLAB 4	1.00
TOD/SLAB 5	1.00
TOD/SLAB 6	1.00
TOD/SLAB 7	1.00

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

TOD/SLAB 8	1.00
------------	------

Time of Day Maximum Demand

Current

TOD/SLAB 1

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.1.255	4.70 kW	18/02/2026 01:00 AM	---
Active(E) Total (Channel 2)	1.0.2.6.1.255	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.1.255	4.68 kVA	18/02/2026 12:30 AM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.1.255	0.00 kVA	---	---

TOD/SLAB 2

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.2.255	4.56 kW	18/02/2026 07:00 AM	---
Active(E) Total (Channel 2)	1.0.2.6.2.255	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.2.255	4.58 kVA	18/02/2026 07:00 AM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.2.255	0.00 kVA	---	---

TOD/SLAB 3

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.3.255	9.34 kW	25/02/2026 05:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.3.255	12.42 kW	08/02/2026 02:00 PM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.3.255	10.04 kVA	25/02/2026 05:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.3.255	12.42 kVA	08/02/2026 02:00 PM	---

TOD/SLAB 4

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.4.255	8.82 kW	23/02/2026 06:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.4.255	1.40 kW	22/02/2026 05:30 PM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.4.255	9.42 kVA	23/02/2026 06:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.4.255	1.40 kVA	22/02/2026 05:30 PM	---

TOD/SLAB 5

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.5.255	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.5.255	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.5.255	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.5.255	0.00 kVA	---	---

TOD/SLAB 6

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.6.255	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.6.255	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.6.255	0.00 kVA	---	---

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.6.255	0.00 kVA	---	---
---	----------------	----------	-----	-----

TOD/SLAB 7

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.7.255	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.7.255	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.7.255	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.7.255	0.00 kVA	---	---

TOD/SLAB 8

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.8.255	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.8.255	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.8.255	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.8.255	0.00 kVA	---	---

History 1

TOD/SLAB 1

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.1.101	4.72 kW	24/01/2026 04:30 AM	---
Active(E) Total (Channel 2)	1.0.2.6.1.101	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.1.101	4.72 kVA	24/01/2026 04:30 AM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.1.101	0.00 kVA	---	---

TOD/SLAB 2

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.2.101	5.08 kW	16/01/2026 07:00 AM	---
Active(E) Total (Channel 2)	1.0.2.6.2.101	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.2.101	5.06 kVA	16/01/2026 07:00 AM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.2.101	0.00 kVA	---	---

TOD/SLAB 3

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.3.101	8.26 kW	13/01/2026 05:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.3.101	11.76 kW	18/01/2026 01:00 PM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.3.101	8.82 kVA	13/01/2026 05:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.3.101	11.74 kVA	18/01/2026 01:00 PM	---

TOD/SLAB 4

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.4.101	8.80 kW	13/01/2026 06:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.4.101	0.72 kW	11/01/2026 05:30 PM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.4.101	9.28 kVA	13/01/2026 06:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.4.101	0.72 kVA	11/01/2026 05:30 PM	---

TOD/SLAB 5

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.5.101	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.5.101	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.5.101	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.5.101	0.00 kVA	---	---

TOD/SLAB 6

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.6.101	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.6.101	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.6.101	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.6.101	0.00 kVA	---	---

TOD/SLAB 7

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.7.101	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.7.101	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.7.101	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.7.101	0.00 kVA	---	---

TOD/SLAB 8

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.8.101	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.8.101	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.8.101	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.8.101	0.00 kVA	---	---

History 2

TOD/SLAB 1

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.1.102	4.70 kW	31/12/2025 12:30 AM	---
Active(E) Total (Channel 2)	1.0.2.6.1.102	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.1.102	4.72 kVA	31/12/2025 12:30 AM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.1.102	0.00 kVA	---	---

TOD/SLAB 2

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.2.102	4.60 kW	19/12/2025 06:30 AM	---
Active(E) Total (Channel 2)	1.0.2.6.2.102	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.2.102	4.60 kVA	19/12/2025 06:30 AM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.2.102	0.00 kVA	---	---

TOD/SLAB 3

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.3.102	6.78 kW	02/12/2025 05:00 PM	---

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Active(E) Total (Channel 2)	1.0.2.6.3.102	10.06 kW	28/12/2025 01:30 PM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.3.102	7.46 kVA	02/12/2025 05:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.3.102	10.06 kVA	28/12/2025 01:30 PM	---

TOD/SLAB 4

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.4.102	8.80 kW	18/12/2025 06:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.4.102	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.4.102	9.50 kVA	18/12/2025 06:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.4.102	0.00 kVA	---	---

TOD/SLAB 5

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.5.102	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.5.102	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.5.102	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.5.102	0.00 kVA	---	---

TOD/SLAB 6

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.6.102	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.6.102	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.6.102	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.6.102	0.00 kVA	---	---

TOD/SLAB 7

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.7.102	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.7.102	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.7.102	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.7.102	0.00 kVA	---	---

TOD/SLAB 8

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.8.102	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.8.102	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.8.102	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.8.102	0.00 kVA	---	---

History 3

TOD/SLAB 1

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.1.103	4.54 kW	11/11/2025 01:30 AM	---
Active(E) Total (Channel 2)	1.0.2.6.1.103	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.1.103	4.54 kVA	11/11/2025 01:30 AM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.1.103	0.00 kVA	---	---

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

TOD/SLAB 2

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.2.103	4.56 kW	28/11/2025 07:00 AM	---
Active(E) Total (Channel 2)	1.0.2.6.2.103	0.02 kW	03/11/2025 09:00 AM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.2.103	4.54 kVA	28/11/2025 07:00 AM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.2.103	0.02 kVA	03/11/2025 09:00 AM	---

TOD/SLAB 3

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.3.103	8.56 kW	05/11/2025 03:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.3.103	11.90 kW	16/11/2025 01:00 PM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.3.103	8.98 kVA	05/11/2025 03:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.3.103	11.92 kVA	16/11/2025 01:00 PM	---

TOD/SLAB 4

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.4.103	9.70 kW	25/11/2025 06:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.4.103	1.04 kW	02/11/2025 05:30 PM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.4.103	10.26 kVA	25/11/2025 06:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.4.103	1.04 kVA	02/11/2025 05:30 PM	---

TOD/SLAB 5

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.5.103	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.5.103	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.5.103	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.5.103	0.00 kVA	---	---

TOD/SLAB 6

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.6.103	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.6.103	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.6.103	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.6.103	0.00 kVA	---	---

TOD/SLAB 7

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.7.103	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.7.103	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.7.103	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.7.103	0.00 kVA	---	---

TOD/SLAB 8

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.8.103	0.00 kW	---	---

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Active(E) Total (Channel 2)	1.0.2.6.8.103	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.8.103	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.8.103	0.00 kVA	---	---

History 4

TOD/SLAB 1

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.1.104	5.42 kW	29/10/2025 01:00 AM	---
Active(E) Total (Channel 2)	1.0.2.6.1.104	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.1.104	5.42 kVA	29/10/2025 01:00 AM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.1.104	0.00 kVA	---	---

TOD/SLAB 2

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.2.104	4.26 kW	12/10/2025 06:30 AM	---
Active(E) Total (Channel 2)	1.0.2.6.2.104	1.30 kW	05/10/2025 09:00 AM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.2.104	4.26 kVA	12/10/2025 06:30 AM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.2.104	1.30 kVA	05/10/2025 09:00 AM	---

TOD/SLAB 3

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.3.104	9.10 kW	29/10/2025 02:30 PM	---
Active(E) Total (Channel 2)	1.0.2.6.3.104	13.88 kW	02/10/2025 12:30 PM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.3.104	9.66 kVA	29/10/2025 02:30 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.3.104	13.88 kVA	02/10/2025 12:30 PM	---

TOD/SLAB 4

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.4.104	9.66 kW	16/10/2025 06:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.4.104	0.82 kW	12/10/2025 05:30 PM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.4.104	9.96 kVA	27/10/2025 06:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.4.104	0.82 kVA	12/10/2025 05:30 PM	---

TOD/SLAB 5

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.5.104	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.5.104	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.5.104	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.5.104	0.00 kVA	---	---

TOD/SLAB 6

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.6.104	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.6.104	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.6.104	0.00 kVA	---	---

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.6.104	0.00 kVA	---	---
---	----------------	----------	-----	-----

TOD/SLAB 7

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.7.104	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.7.104	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.7.104	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.7.104	0.00 kVA	---	---

TOD/SLAB 8

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.8.104	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.8.104	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.8.104	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.8.104	0.00 kVA	---	---

History 5

TOD/SLAB 1

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.1.105	0.02 kW	01/10/2025 12:30 AM	---
Active(E) Total (Channel 2)	1.0.2.6.1.105	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.1.105	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.1.105	0.00 kVA	---	---

TOD/SLAB 2

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.2.105	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.2.105	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.2.105	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.2.105	0.00 kVA	---	---

TOD/SLAB 3

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.3.105	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.3.105	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.3.105	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.3.105	0.00 kVA	---	---

TOD/SLAB 4

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.4.105	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.4.105	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.4.105	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.4.105	0.00 kVA	---	---

TOD/SLAB 5

--	--	--	--	--

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.5.105	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.5.105	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.5.105	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.5.105	0.00 kVA	---	---

TOD/SLAB 6

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.6.105	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.6.105	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.6.105	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.6.105	0.00 kVA	---	---

TOD/SLAB 7

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.7.105	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.7.105	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.7.105	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.7.105	0.00 kVA	---	---

TOD/SLAB 8

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.8.105	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.8.105	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.8.105	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.8.105	0.00 kVA	---	---

History 6

TOD/SLAB 1

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.1.106	4.70 kW	01/09/2025 11:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.1.106	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.1.106	4.78 kVA	01/09/2025 11:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.1.106	0.00 kVA	---	---

TOD/SLAB 2

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.2.106	8.74 kW	16/09/2025 01:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.2.106	9.92 kW	21/09/2025 04:00 PM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.2.106	9.30 kVA	16/09/2025 01:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.2.106	9.92 kVA	21/09/2025 04:00 PM	---

TOD/SLAB 3

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.3.106	8.64 kW	15/09/2025 11:00 AM	---
Active(E) Total (Channel 2)	1.0.2.6.3.106	8.00 kW	14/09/2025 11:00 AM	---

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.3.106	9.50 kVA	29/09/2025 11:30 AM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.3.106	8.04 kVA	14/09/2025 11:00 AM	---

TOD/SLAB 4

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.4.106	10.08 kW	19/09/2025 07:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.4.106	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.4.106	10.56 kVA	19/09/2025 07:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.4.106	0.00 kVA	---	---

TOD/SLAB 5

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.5.106	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.5.106	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.5.106	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.5.106	0.00 kVA	---	---

TOD/SLAB 6

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.6.106	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.6.106	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.6.106	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.6.106	0.00 kVA	---	---

TOD/SLAB 7

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.7.106	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.7.106	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.7.106	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.7.106	0.00 kVA	---	---

TOD/SLAB 8

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.8.106	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.8.106	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.8.106	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.8.106	0.00 kVA	---	---

History 7

TOD/SLAB 1

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.1.107	8.24 kW	31/08/2025 05:30 AM	---
Active(E) Total (Channel 2)	1.0.2.6.1.107	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.1.107	9.20 kVA	31/08/2025 05:30 AM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.1.107	0.00 kVA	---	---

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

TOD/SLAB 2

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.2.107	15.40 kW	13/08/2025 06:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.2.107	13.62 kW	10/08/2025 02:30 PM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.2.107	18.36 kVA	13/08/2025 06:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.2.107	13.66 kVA	10/08/2025 02:30 PM	---

TOD/SLAB 3

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.3.107	8.62 kW	19/08/2025 11:00 AM	---
Active(E) Total (Channel 2)	1.0.2.6.3.107	11.16 kW	31/08/2025 12:00 PM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.3.107	9.08 kVA	19/08/2025 11:00 AM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.3.107	11.18 kVA	31/08/2025 12:00 PM	---

TOD/SLAB 4

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.4.107	15.40 kW	13/08/2025 06:30 PM	---
Active(E) Total (Channel 2)	1.0.2.6.4.107	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.4.107	17.74 kVA	13/08/2025 06:30 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.4.107	0.00 kVA	---	---

TOD/SLAB 5

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.5.107	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.5.107	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.5.107	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.5.107	0.00 kVA	---	---

TOD/SLAB 6

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.6.107	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.6.107	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.6.107	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.6.107	0.00 kVA	---	---

TOD/SLAB 7

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.7.107	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.7.107	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.7.107	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.7.107	0.00 kVA	---	---

TOD/SLAB 8

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.8.107	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.8.107	0.00 kW	---	---

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.8.107	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.8.107	0.00 kVA	---	---

History 8

TOD/SLAB 1

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.1.108	4.18 kW	03/07/2025 11:30 PM	---
Active(E) Total (Channel 2)	1.0.2.6.1.108	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.1.108	4.18 kVA	03/07/2025 11:30 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.1.108	0.00 kVA	---	---

TOD/SLAB 2

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.2.108	12.16 kW	26/07/2025 03:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.2.108	3.56 kW	29/07/2025 01:00 PM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.2.108	13.14 kVA	26/07/2025 03:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.2.108	4.58 kVA	29/07/2025 01:00 PM	---

TOD/SLAB 3

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.3.108	10.70 kW	09/07/2025 11:30 AM	---
Active(E) Total (Channel 2)	1.0.2.6.3.108	2.08 kW	01/07/2025 11:00 AM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.3.108	11.10 kVA	10/07/2025 12:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.3.108	2.64 kVA	01/07/2025 11:00 AM	---

TOD/SLAB 4

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.4.108	7.78 kW	17/07/2025 06:30 PM	---
Active(E) Total (Channel 2)	1.0.2.6.4.108	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.4.108	7.88 kVA	17/07/2025 06:30 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.4.108	0.00 kVA	---	---

TOD/SLAB 5

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.5.108	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.5.108	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.5.108	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.5.108	0.00 kVA	---	---

TOD/SLAB 6

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.6.108	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.6.108	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.6.108	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.6.108	0.00 kVA	---	---

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

TOD/SLAB 7

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.7.108	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.7.108	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.7.108	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.7.108	0.00 kVA	---	---

TOD/SLAB 8

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.8.108	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.8.108	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.8.108	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.8.108	0.00 kVA	---	---

History 9

TOD/SLAB 1

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.1.109	4.44 kW	30/06/2025 10:30 PM	---
Active(E) Total (Channel 2)	1.0.2.6.1.109	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.1.109	4.42 kVA	30/06/2025 10:30 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.1.109	0.00 kVA	---	---

TOD/SLAB 2

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.2.109	9.28 kW	13/06/2025 06:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.2.109	12.32 kW	22/06/2025 12:30 PM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.2.109	12.70 kVA	30/06/2025 02:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.2.109	12.34 kVA	22/06/2025 12:30 PM	---

TOD/SLAB 3

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.3.109	9.16 kW	19/06/2025 11:00 AM	---
Active(E) Total (Channel 2)	1.0.2.6.3.109	11.72 kW	08/06/2025 12:00 PM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.3.109	9.52 kVA	19/06/2025 11:00 AM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.3.109	11.76 kVA	08/06/2025 12:00 PM	---

TOD/SLAB 4

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.4.109	7.44 kW	18/06/2025 06:30 PM	---
Active(E) Total (Channel 2)	1.0.2.6.4.109	0.18 kW	22/06/2025 06:30 PM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.4.109	7.52 kVA	18/06/2025 06:30 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.4.109	0.20 kVA	22/06/2025 06:30 PM	---

TOD/SLAB 5

Parameter	Obis Code	Value	Date Time	MD/Trigger
-----------	-----------	-------	-----------	------------

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Active(I) Total (Channel 1)	1.0.1.6.5.109	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.5.109	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.5.109	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.5.109	0.00 kVA	---	---

TOD/SLAB 6

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.6.109	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.6.109	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.6.109	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.6.109	0.00 kVA	---	---

TOD/SLAB 7

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.7.109	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.7.109	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.7.109	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.7.109	0.00 kVA	---	---

TOD/SLAB 8

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.8.109	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.8.109	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.8.109	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.8.109	0.00 kVA	---	---

History 10

TOD/SLAB 1

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.1.110	4.04 kW	13/05/2025 11:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.1.110	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.1.110	4.06 kVA	13/05/2025 11:30 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.1.110	0.00 kVA	---	---

TOD/SLAB 2

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.2.110	11.12 kW	16/05/2025 03:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.2.110	13.06 kW	11/05/2025 12:30 PM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.2.110	12.34 kVA	16/05/2025 03:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.2.110	13.06 kVA	11/05/2025 12:30 PM	---

TOD/SLAB 3

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.3.110	9.94 kW	27/05/2025 12:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.3.110	11.86 kW	11/05/2025 12:00 PM	---

	XB485951 - Readings			EMF (Applied)		
	Source: XB48595120260228150730.cdf			Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12			1.00	1.00	1.00

Apparent-Active(I) - type 2 (Channel 3) 1.0.9.6.3.110 10.44 kVA 27/05/2025 12:00 PM ---

Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.3.110	11.88 kVA	11/05/2025 12:00 PM	---
---	----------------	-----------	---------------------	-----

TOD/SLAB 4

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.4.110	7.62 kW	14/05/2025 06:30 PM	---
Active(E) Total (Channel 2)	1.0.2.6.4.110	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.4.110	7.76 kVA	14/05/2025 06:30 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.4.110	0.00 kVA	---	---

TOD/SLAB 5

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.5.110	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.5.110	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.5.110	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.5.110	0.00 kVA	---	---

TOD/SLAB 6

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.6.110	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.6.110	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.6.110	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.6.110	0.00 kVA	---	---

TOD/SLAB 7

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.7.110	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.7.110	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.7.110	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.7.110	0.00 kVA	---	---

TOD/SLAB 8

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.8.110	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.8.110	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.8.110	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.8.110	0.00 kVA	---	---

History 11

TOD/SLAB 1

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.1.111	4.02 kW	24/04/2025 10:30 PM	---
Active(E) Total (Channel 2)	1.0.2.6.1.111	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.1.111	4.02 kVA	22/04/2025 12:00 AM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.1.111	0.00 kVA	---	---

TOD/SLAB 2

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.2.111	12.86 kW	03/04/2025 05:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.2.111	13.18 kW	06/04/2025 01:30 PM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.2.111	14.08 kVA	03/04/2025 05:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.2.111	13.20 kVA	06/04/2025 01:30 PM	---

TOD/SLAB 3

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.3.111	8.12 kW	01/04/2025 10:30 AM	---
Active(E) Total (Channel 2)	1.0.2.6.3.111	11.80 kW	13/04/2025 11:30 AM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.3.111	8.34 kVA	01/04/2025 10:30 AM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.3.111	11.82 kVA	13/04/2025 11:30 AM	---

TOD/SLAB 4

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.4.111	9.56 kW	02/04/2025 06:30 PM	---
Active(E) Total (Channel 2)	1.0.2.6.4.111	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.4.111	10.26 kVA	02/04/2025 06:30 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.4.111	0.02 kVA	27/04/2025 06:30 PM	---

TOD/SLAB 5

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.5.111	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.5.111	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.5.111	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.5.111	0.00 kVA	---	---

TOD/SLAB 6

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.6.111	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.6.111	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.6.111	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.6.111	0.00 kVA	---	---

TOD/SLAB 7

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.7.111	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.7.111	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.7.111	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.7.111	0.00 kVA	---	---

TOD/SLAB 8

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.8.111	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.8.111	0.00 kW	---	---

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.8.111	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.8.111	0.00 kVA	---	---

History 12

TOD/SLAB 1

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.1.112	4.60 kW	24/03/2025 11:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.1.112	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.1.112	4.58 kVA	24/03/2025 11:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.1.112	0.00 kVA	---	---

TOD/SLAB 2

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.2.112	8.28 kW	31/03/2025 06:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.2.112	13.58 kW	09/03/2025 01:30 PM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.2.112	8.44 kVA	31/03/2025 06:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.2.112	13.60 kVA	09/03/2025 01:30 PM	---

TOD/SLAB 3

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.3.112	2.12 kW	31/03/2025 09:30 AM	---
Active(E) Total (Channel 2)	1.0.2.6.3.112	11.82 kW	09/03/2025 12:00 PM	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.3.112	2.98 kVA	27/03/2025 10:30 AM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.3.112	11.84 kVA	09/03/2025 12:00 PM	---

TOD/SLAB 4

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.4.112	7.60 kW	25/03/2025 07:00 PM	---
Active(E) Total (Channel 2)	1.0.2.6.4.112	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.4.112	7.66 kVA	25/03/2025 07:00 PM	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.4.112	0.00 kVA	---	---

TOD/SLAB 5

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.5.112	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.5.112	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.5.112	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.5.112	0.00 kVA	---	---

TOD/SLAB 6

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.6.112	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.6.112	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.6.112	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.6.112	0.00 kVA	---	---

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

TOD/SLAB 7

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.7.112	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.7.112	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.7.112	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.7.112	0.00 kVA	---	---

TOD/SLAB 8

Parameter	Obis Code	Value	Date Time	MD/Trigger
Active(I) Total (Channel 1)	1.0.1.6.8.112	0.00 kW	---	---
Active(E) Total (Channel 2)	1.0.2.6.8.112	0.00 kW	---	---
Apparent-Active(I) - type 2 (Channel 3)	1.0.9.6.8.112	0.00 kVA	---	---
Apparent-Active(E) - type 6 (Channel 4)	1.0.10.6.8.112	0.00 kVA	---	---

Flags

Description	Value
Memory failure	No
Over current	No
Current without Voltage	No
Reverse run	Yes
Clock failed	No
Low power factor	No
Current imbalance	No
Voltage imbalance	No
Neutral disturbance	No
Meter cover open	No
Battery out of order	No
Current terminal shorting	No
Current terminal open	No
Neutral removal (Loss of neutral)	No
Invalid voltage	No
Magnetic tamper	No
Current missing	Yes
Meter power off	Yes

Tariff Information

Period	Tariff Name
Current	R1TOD25
History 1	R1TOD25
History 2	R1TOD25
History 3	R1TOD25
History 4	R1TOD25

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

History 5	R1TOD25
History 6	BESMSEB
History 7	BESMSEB
History 8	BESMSEB
History 9	BESMSEB
History 10	BESMSEB
History 11	BESMSEB
History 12	BESMSEB

Counters

Current

Description	Value	Value in period
Cumulative Billing Count	110	---
Reads On Priority Port Count	118	---
Reads On Non Priority Port Count	0	---
Meter Read Count	118	---
Cumulative Tamper Count	5527	28

History 1

Description	Value	Value in period
Cumulative Tamper Count	5499	26

History 2

Description	Value	Value in period
Cumulative Tamper Count	5473	16

History 3

Description	Value	Value in period
Cumulative Tamper Count	5457	27

History 4

Description	Value	Value in period
Cumulative Tamper Count	5430	58

History 5

Description	Value	Value in period
Cumulative Tamper Count	5372	0

History 6

Description	Value	Value in period
Cumulative Tamper Count	5372	39

History 7

Description	Value	Value in period
-------------	-------	-----------------

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Cumulative Tamper Count	5333	35
-------------------------	------	----

History 8

Description	Value	Value in period
Cumulative Tamper Count	5298	5

History 9

Description	Value	Value in period
Cumulative Tamper Count	5293	31

History 10

Description	Value	Value in period
Cumulative Tamper Count	5262	83

History 11

Description	Value	Value in period
Cumulative Tamper Count	5179	117

History 12

Description	Value	Value in period
Cumulative Tamper Count	5062	---

Duration

Current

Description	Value (YY DDD HH MM)
Billing Power ON duration(During billing period)	00 027 06 17
Billing Power OFF duration(During billing period)	00 000 09 15

History 1

Description	Value (YY DDD HH MM)
Billing Power ON duration(During billing period)	00 030 19 49
Billing Power OFF duration(During billing period)	00 000 04 11

History 2

Description	Value (YY DDD HH MM)
Billing Power ON duration(During billing period)	00 030 22 44
Billing Power OFF duration(During billing period)	00 000 01 16

History 3

Description	Value (YY DDD HH MM)
Billing Power ON duration(During billing period)	00 029 14 41
Billing Power OFF duration(During billing period)	00 000 09 19

History 4

	XB485951 - Readings		EMF (Applied)		
	Source: XB48595120260228150730.cdf		Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12		1.00	1.00	1.00

Description	Value (YY DDD HH MM)
Billing Power ON duration(During billing period)	00 030 16 39
Billing Power OFF duration(During billing period)	00 000 07 21

History 5

Description	Value (YY DDD HH MM)
Billing Power ON duration(During billing period)	00 000 00 00
Billing Power OFF duration(During billing period)	00 000 00 00

History 6

Description	Value (YY DDD HH MM)
Billing Power ON duration(During billing period)	00 029 21 03
Billing Power OFF duration(During billing period)	00 000 02 57

History 7

Description	Value (YY DDD HH MM)
Billing Power ON duration(During billing period)	00 030 18 22
Billing Power OFF duration(During billing period)	00 000 05 38

History 8

Description	Value (YY DDD HH MM)
Billing Power ON duration(During billing period)	00 030 21 44
Billing Power OFF duration(During billing period)	00 000 02 16

History 9

Description	Value (YY DDD HH MM)
Billing Power ON duration(During billing period)	00 029 09 52
Billing Power OFF duration(During billing period)	00 000 14 08

History 10

Description	Value (YY DDD HH MM)
Billing Power ON duration(During billing period)	00 030 21 08
Billing Power OFF duration(During billing period)	00 000 02 52

History 11

Description	Value (YY DDD HH MM)
Billing Power ON duration(During billing period)	00 029 19 28
Billing Power OFF duration(During billing period)	00 000 04 32

History 12

Description	Value (YY DDD HH MM)
Billing Power ON duration(During billing period)	00 030 23 11
Billing Power OFF duration(During billing period)	00 000 00 49

Midnight Snapshots

45 of 47

Meter Location:

Generated on: 28/02/2026 15:08:25

Authentic

	XB485951 - Readings				EMF (Applied)		
	Source: XB48595120260228150730.cdf				Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12				1.00	1.00	1.00

Param 1: Active(I) Total (1.0.1.8.0.255)

Param 2: Active(E) Total (1.0.2.8.0.255)

Param 3: Reactive(I)-Active(I) (1.0.5.8.0.255)

Param 4: Reactive(I)-Active(E) (1.0.6.8.0.255)

Param 5: Reactive(E)-Active(E) (1.0.7.8.0.255)

Param 6: Reactive(E)-Active(I) (1.0.8.8.0.255)

Param 7: Apparent-Active(I) - type 2 (1.0.9.8.0.255)

Param 8: Apparent-Active(E) - type 6 (1.0.10.8.0.255)

Date	Param 1 kWh	Param 2 kWh	Param 3 kVArh	Param 4 kVArh	Param 5 kVArh	Param 6 kVArh	Param 7 kVAh	Param 8 kVAh
15/01/2026	225608.60	85864.20	23275.20	20568.60	5440.60	37370.60	232989.40	94314.40
16/01/2026	225677.00	85900.20	23277.60	20577.60	5440.60	37373.20	233058.80	94353.40
17/01/2026	225757.20	85918.80	23289.40	20594.20	5440.60	37376.40	233143.60	94379.20
18/01/2026	225829.60	85945.60	23295.80	20608.00	5440.60	37380.00	233218.20	94410.40
19/01/2026	225892.00	86007.80	23296.00	20608.20	5442.00	37383.80	233280.60	94472.60
20/01/2026	225967.40	86027.00	23304.60	20626.20	5442.00	37387.80	233359.60	94500.40
21/01/2026	226046.60	86045.00	23315.20	20642.20	5442.00	37391.20	233443.20	94525.20
22/01/2026	226133.60	86060.20	23329.40	20656.20	5442.00	37393.20	233535.20	94546.60
23/01/2026	226217.40	86073.60	23341.80	20671.00	5442.00	37395.40	233624.20	94567.40
24/01/2026	226283.20	86121.80	23342.20	20671.00	5442.60	37398.20	233690.00	94615.60
25/01/2026	226360.20	86131.60	23351.20	20679.60	5442.60	37400.80	233770.40	94629.20
26/01/2026	226422.80	86178.20	23351.40	20679.80	5444.00	37405.00	233833.20	94675.80
27/01/2026	226485.80	86212.00	23351.40	20679.80	5445.20	37409.60	233896.00	94709.60
28/01/2026	226579.40	86222.60	23369.20	20689.80	5445.20	37413.60	233995.60	94724.80
29/01/2026	226659.80	86239.60	23380.40	20703.80	5445.20	37417.20	234080.00	94747.80
30/01/2026	226743.40	86247.80	23399.20	20714.80	5445.20	37420.20	234171.20	94762.00
31/01/2026	226831.60	86254.00	23414.80	20723.00	5445.20	37423.60	234265.40	94772.80
01/02/2026	226911.20	86264.40	23425.60	20732.80	5445.20	37428.40	234349.20	94787.80
02/02/2026	226972.60	86309.60	23425.60	20733.60	5446.00	37434.40	234410.60	94833.00
03/02/2026	227058.40	86317.20	23443.40	20744.20	5446.00	37439.20	234504.20	94846.80
04/02/2026	227149.00	86325.60	23458.60	20755.40	5446.00	37443.60	234599.80	94861.40
05/02/2026	227232.60	86337.40	23472.00	20768.00	5446.00	37447.20	234688.80	94879.40
06/02/2026	227316.80	86347.20	23487.40	20781.60	5446.00	37449.00	234779.00	94897.20
07/02/2026	227396.60	86360.20	23499.80	20795.20	5446.00	37450.40	234863.00	94916.80
08/02/2026	227469.20	86389.60	23506.20	20809.00	5446.00	37453.80	234938.20	94950.40
09/02/2026	227531.60	86457.00	23506.40	20809.00	5447.00	37457.40	235000.80	95017.80
10/02/2026	227614.80	86473.20	23520.00	20826.60	5447.00	37459.60	235089.20	95042.60
11/02/2026	227692.20	86489.60	23530.20	20842.80	5447.00	37461.60	235170.60	95066.80
12/02/2026	227770.80	86509.00	23540.20	20861.20	5447.00	37463.80	235252.60	95094.40
13/02/2026	227845.40	86529.00	23549.60	20880.00	5447.00	37466.00	235331.40	95122.80

	XB485951 - Readings				EMF (Applied)		
	Source: XB48595120260228150730.cdf				Voltage	Current	Energy
	Read on: 28/02/2026 15:02:12				1.00	1.00	1.00

16/02/2026	228988.80	86379.80	23588.20	20928.00	5449.20	37468.80	236409.80	95458.00
17/02/2026	228991.00	86378.20	23589.60	20908.80	5449.20	37492.00	236487.80	95482.40
18/02/2026	228056.80	86818.80	23769.40	20908.80	5449.20	37506.80	236568.80	95808.80
17/02/2026	228136.00	86646.80	23576.80	20923.80	5448.40	37478.80	235633.40	95258.80
18/02/2026	228125.00	86656.40	23591.40	20936.80	5448.40	37480.20	235726.00	95276.00
19/02/2026	228312.60	86666.00	23687.40	20960.20	5448.40	37482.20	235822.20	95292.20
20/02/2026	228406.00	86674.00	23635.00	20960.20	5448.40	37484.40	235916.80	95306.40
21/02/2026	228479.60	86687.20	23636.00	20974.40	5448.40	37487.20	235994.40	95327.00
22/02/2026	228546.80	86705.00	23646.20	20987.40	5448.40	37490.00	236073.40	95350.40
23/02/2026	228618.20	86728.00	23652.40	20987.60	5449.20	37493.80	236138.00	95393.80
24/02/2026	228791.20	86757.60	23661.00	21001.60	5449.20	37496.00	236233.60	95410.80
25/02/2026	228770.00	86761.60	23666.20	21012.80	5449.20	37496.80	236305.40	95424.60

Load Factor

Param 1: Active(I) Total (Channel 1) (1.0.1.8.0.255)
Param 2: Active(E) Total (Channel 2) (1.0.2.8.0.255)
Param 3: Apparent-Active(I) - type 2 (Channel 9) (1.0.9.8.0.255)
Param 4: Apparent-Active(E) - type 6 (Channel 10) (1.0.10.8.0.255)

Period	Param 1 Wh	Param 2 Wh	Param 3 VAh	Param 4 VAh
Current	0.35	0.07	0.34	0.09
History 1	0.37	0.08	0.37	0.10
History 2	0.37	0.08	0.36	0.11
History 3	0.34	0.08	0.33	0.10
History 4	0.35	0.08	0.35	0.09
History 5	1.00	---	---	---
History 6	0.36	0.05	0.36	0.06
History 7	0.22	0.04	0.20	0.04
History 8	0.42	0.01	0.40	0.01
History 9	0.35	0.05	0.27	0.06
History 10	0.30	0.06	0.28	0.07
History 11	0.22	0.08	0.21	0.10