

INSTANTANEOUS PARAMETERS (1.0.94.91.0.255)

Meter Serial Number (0.0.96.1.0.255) M22515215561 Download time(RTC) 26/06/2026 12:02:20 (DD/MM/YYYY HH:MM)

Consumer name	N A			Mobile No.	N A
Consumer Id	N A	Connection No.	N A	Location Name	N A
Type of Connection	N A	Circle	N A	City	N A
Sub Station	N A	Division	N A	State	N A
Sanctioned Load	N A	Sub Division	N A	Pin Number	N A
Feeder Loaction	N A	DT Location	N A	Pole Location	N A

Meter Type (0.0.94.91.9.255) 6(1P Direct Connected Watthour Smart Meter) Manu. Name (0.0.96.1.1.255) HPL Electric & Power Ltd.

Internal CT Ratio (1.0.0.4.2.255) N A Firmware Version (1.0.0.2.0.255) 1078.04

Internal PT Ratio (1.0.0.4.3.255) N A Meter Year of Manufacture (0.0.96.1.4.255) 2025

Parameter Name	OBIS Code - Attribute	Value
RTC - Date & Time	0.0.1.0.0.255-2	26/06/2026 12:02:15 DD/MM/YYYY HH:MM:SS
Voltage	1.0.12.7.0.255-2	241.48 V
Ph Current	1.0.11.7.0.255-2	1.26 Amp
Neutral Current	1.0.91.7.0.255-2	1.261 Amp
Power Factor - PF	1.0.13.7.0.255-2	0.944
Frequency	1.0.14.7.0.255-2	50 Hz
Apparent Power - kVA	1.0.9.7.0.255-2	0.29 kVA
Signed Active Power - kW (+I;-E)	1.0.1.7.0.255-2	0.274 kW
Cumulative Energy - kWh(I)	1.0.1.8.0.255-2	1491.05 kWh
Cumulative Energy - kVAh(I)	1.0.9.8.0.255-2	1578.14 kVAh
MD - kW(I)	1.0.1.6.0.255-2	2.534 kW
MD kW(I) Date&Time	1.0.1.6.0.255-5	02/06/2026 07:30 DD/MM/YYYY HH:MM
MD kVA(I)	1.0.9.6.0.255-2	2.578 kVA
MD kVA(I) Date&Time	1.0.9.6.0.255-5	02/06/2026 08:30 DD/MM/YYYY HH:MM
Cumulative Power on Hrs.(Min.)	0.0.94.91.14.255-2	147023
Cumulative Tamper Count	0.0.94.91.0.255-2	0002
Cumulative Billing Count	0.0.0.1.0.255-2	6
Cumulative Programming Count	0.0.96.2.0.255-2	3
Cumulative Energy - kWh(E)	1.0.2.8.0.255-2	0 kWh
Cumulative Energy - kVAh(E)	1.0.10.8.0.255-2	0 kVAh
Cumulative Energy - kVArh - Q1	1.0.5.8.0.255-2	394.08 kVArh
Cumulative Energy - kVArh - Q2	1.0.6.8.0.255-2	0 kVArh
Cumulative Energy - kVArh - Q3	1.0.7.8.0.255-2	0 kVArh
Cumulative Energy - kVArh - Q4	1.0.8.8.0.255-2	54.93 kVArh
Defraud kWh	1.0.181.8.0.255-2	0.01 kWh
Load Limit Function Status(Connect/Disconnect)	0.0.96.3.10.255-2	Relay Connect
Load Limit Value in kW	0.0.17.0.0.255-3	10.8 kW
Temperature	0.0.96.9.128.255-2	25 °C
Number of load switch (Connect/Disconnect)	0.0.96.50.1.255-2	0001
Voltage% THD	1.0.12.128.124.255-2	0.00 %
Current% THD	1.0.128.128.124.255-2	0.00 %
RSRP	0.1.96.12.6.255-2	-100
RSRQ	0.1.96.12.7.255-2	-9
SNR	0.1.96.12.8.255-2	2
Signal strength (CSQ value)	0.1.96.12.5.255-2	22
Cell ID	0.0.96.57.38.255-2	249632008
RAT & BAND	0.0.96.99.124.255-2	5