

Table 4 – Experimental uncertainties of measured heat fluxes and pool boiling heat transfer coefficients at all saturation temperatures tested.

		R-134a			R-236fa		
		δ_{min}	δ_{max}	δ_{avg}	δ_{min}	δ_{max}	δ_{avg}
Turbo-B5	q	14.49%	47.3%	21.90%	16.08%	31.92%	20.21%
	h_{pb}	26.50%	84.11%	40.73%	18.20%	55.95%	33.27%
Gewa-B5	q	7.75%	25.16%	13.69%	12.33%	34.64%	19.52%
	h_{pb}	18.12%	85.72%	40.88%	19.27%	85.64%	37.98%