

Table 5 – Experimental uncertainties of falling film heat transfer coefficients during falling film evaporation.

q		R-134a		R-236fa	
		$\delta_{\max}$	δ_{avg}	$\delta_{\max}$	δ_{avg}
Turbo-B5	20 kW m ⁻²	44.97%	31.01%	43.51%	32.72%
	40 kW m ⁻²	26.01%	19.53%	25.95%	20.27%
	60 kW m ⁻²	21.91%	15.73%	23.73%	18.77%
Gewa-B5	20 kW m ⁻²	—	—	—	—
	40 kW m ⁻²	35.41%	25.53%	35.95%	24.27%
	60 kW m ⁻²	25.91%	18.73%	23.73%	21.77%