

Table 2 Measured values of critical heat flux (CHF) for HFE-7300 in boiling tests

Surface	$q''_{w,CHF}$ (W/cm ²)	$\Delta T_{w,CHF}$ (K)	CHF enhancement (%)	Wall superheat reduction at CHF (%)
Bare copper	18.1	23.4	—	—
CNT-enhanced	18.9	16.4	4.4	29.9
Sintered copper	24.2	38.6	33.7	−65.0
Sintered copper + CNTs ^a	26.4	18.1	>45.9	22.6

^aPoint of maximum measured heat flux (not CHF).