

Table 1. Measured values of critical heat flux (CHF) for HFE-7300 in boiling tests.

Surface	$q''_{w,CHF}$ [W/cm ²]	$\Delta T_{w,CHF}$ [K]	CHF enhancement [%]	Wall superheat reduction at CHF [%]
Bare copper	18.1	23.4	—	—
CNT-enhanced	18.9	16.4	4.4	29.9
Sintered copper	24.2	38.6	33.7	- 65.0
Sintered copper + CNTs [*]	26.4	18.1	> 45.9	22.6

* Point of maximum measured heat flux (not CHF)