




Fortescue Transformation

$$\begin{pmatrix} I_0 \\ I_1 \\ I_2 \end{pmatrix} = \frac{1}{3} \begin{pmatrix} 1 & 1 & 1 \\ 1 & a & a^2 \\ 1 & a^2 & a \end{pmatrix} \begin{pmatrix} I_a \\ I_b \\ I_c \end{pmatrix}, \quad a = e^{j2\pi/3}$$

SLG Connection:

$$I_1 = I_2 = I_0 = \frac{E}{Z_1 + Z_2 + Z_0}$$

LL Connection:

$$I_2 = -I_1, \quad I_0 = 0$$

$$I_1 = \frac{E}{Z_1 + Z_2}$$

Sequence Estimator

Fit 6-param model to I_1, I_2, I_0 separately

Relay adaptation uses $\hat{\theta}_{pos}$ (positive sequence)