

Single-Ended Joint Estimation of HIF Location and Arc Resistance via Power-Frequency Admittance Identification with Dual-Channel Noise Modelling

Arjundas K. and K. Shanthi Swarup, *Senior Member, IEEE*

Abstract—High-impedance faults (HIFs) account for an estimated 5–10 % of distribution-feeder faults and roughly a quarter of downed-conductor events go undetected by conventional overcurrent protection (IEEE PSRC Working Group D15, 1996), and grid-caused ignitions represent 19 % of all U.S. wildfires over 2016–2020 (NREL TP-5R00-80746, 2023), making accurate HIF location and arc resistance estimation an urgent safety problem. This paper proposes a single-ended joint estimator of fault location α and arc resistance R_x that fits a state-space transfer function $H_{\text{model}}(j\omega_0; \alpha, R_x)$ to the power-frequency single-bin DFT admittance $H_{\text{meas}}(j\omega_0)$ via a two-stage optimiser (grid + multi-start, then gradient with Armijo line-search) over a 720-case sweep ($10\alpha \times 5R_x \times 4\text{SNR}_V \times 4\text{SNR}_I$) under independent dual-channel additive white Gaussian noise. The estimator achieves a mean fault-location error of 0.009 % in the noiseless baseline and 1.18 % at $\text{SNR}_I = 20$ dB^(see Glossary, LOC-ERR); mean arc-resistance error is 2.42 % noiseless and ≤ 8 % across $100\text{--}2000\ \Omega$ at $\text{SNR} \geq 30$ dB^(see Glossary, RX-ERR); the location-error metric is distinct from the TF-magnitude modelling error of the two-section π -model versus a 50-section reference, which is reported separately in §IID. The empirical RMS estimator stays within 15 % of the Cramér–Rao Lower Bound at $\text{SNR} \geq 40$ dB^(see Glossary, CRLB-GAP). All results use $F_s = 10$ kHz, $N_s = 200$, one cycle window^(see Glossary, SAMP-CFG). Single-frequency operation, training-free deployment, and the absence of remote-end communication make the estimator a practical single-ended primary HIF locator suitable for integration into the SAMBPS DTaaS Protection-Validation digital-twin module.

Index Terms—High-impedance fault, fault location, arc resistance, transfer-function identification, single-ended, joint estimation, training-free, single-frequency, Cramér–Rao Lower Bound, dual-channel noise model, distribution protection, SAMBPS DTaaS.

I. INTRODUCTION

High-impedance faults (HIFs) account for an estimated 5–10 % of all distribution-feeder faults, and approximately one quarter of downed-conductor incidents go undetected by conventional overcurrent relaying [1]. In the United States, grid-related ignitions caused 19 % of wildfires recorded between 2016 and 2020 [2]. Two catastrophic events frame the operational stakes: the 2009 Australian Black Saturday bushfires killed 173 people, with electrical assets implicated

as ignition sources on multiple fire fronts [3]; the 2018 PG&E Camp Fire killed 85 and led to a USD 13.5 billion settlement after a worn transmission hook ignited dry grassland near Pulga, California [4].

In response, the California Public Utilities Commission (CPUC) implemented Senate Bill 901 (SB 901), placing utilities under a formal Public Safety Power Shutoff (PSPS) framework that mandates de-energisation when fire-weather risk exceeds defined thresholds [5]. PSPS shutoffs avoid catastrophic ignition but at significant social and economic cost; selective HIF location and arc-resistance estimation, by contrast, would enable targeted de-energisation of only the faulted segment, materially shrinking the PSPS footprint. The estimator developed in this paper is designed to fill that gap.

The prior-art literature on HIF location and detection clusters into seven distinct families, summarised in Table I. Two columns are added for the comparison this paper draws: “Single-ended,” which marks methods that operate from a single line terminal, and “Joint $\alpha+R_x$,” which marks methods that estimate fault location α and arc resistance R_x *simultaneously* from the same observation rather than estimating one and treating the other as a fixed parameter or post-processing step.

The proposed estimator described in this paper would occupy an eighth row of Table I and is the only entry that is “Yes” in both the Single-ended and the Joint $\alpha+R_x$ columns: it operates from a single line terminal and produces a simultaneous estimate $(\hat{\alpha}, \hat{R}_x)$ from a single complex admittance observation $H_{\text{meas}}(j\omega_0)$.

Of the seven prior-art families, only (i), (ii), (iv), (vi) and (vii) operate from a single terminal, and none produces a simultaneous estimate of fault location and arc resistance. Families that do report R_x either treat it as a nuisance parameter solved for after location is fixed (family (ii)) or infer it implicitly through a classifier boundary (family (vi)).

Paper contributions

- 1) A single-ended power-frequency admittance identification formulation that derives $H_{\text{meas}}(j\omega_0)$ from the dual-channel single-bin DFT and matches it against a state-space transfer function $H_{\text{model}}(j\omega_0; \alpha, R_x)$ derived in closed form from the two-section π -line.
- 2) A two-stage optimiser (grid + multi-start, then gradient descent with Armijo line-search) that jointly estimates $(\hat{\alpha}, \hat{R}_x)$ from a single complex observation, without remote-end communication and without offline training.

The authors are with the Power Systems Computational Lab, Department of Electrical Engineering, Indian Institute of Technology Madras, Chennai 600 036, India (e-mail: arjundas@iitm.ac.in; swarup@ee.iitm.ac.in).

This work was conducted under the SAMBPS Digital Twin Labs R&D programme on Smart Adaptive Model-Based Protection & Control Systems (SAMBPS DTaaS). The authors gratefully acknowledge the SAMBPS DTaaS reproducibility infrastructure and the public release of all 720-case waveform data, 50-section reference dataset and analysis scripts under MIT licence.

TABLE I

SEVEN-FAMILY TAXONOMY OF PRIOR-ART HIF LOCATION / DETECTION METHODS. “SINGLE-ENDED” MARKS METHODS THAT USE ONLY ONE LINE TERMINAL; “JOINT $\alpha + R_x$ ” MARKS METHODS THAT ESTIMATE BOTH QUANTITIES SIMULTANEOUSLY FROM A SINGLE OBSERVATION. NONE OF THE SEVEN FAMILIES IS YES IN BOTH COLUMNS.

Family	Representative anchors	Single-ended	Joint $\alpha + R_x$	Distinguishing trait
(i) Signal processing / morphology / wavelet	Aucoin–Russell 1987 IEEE TPWRD [6]; Brahma 2013 IEEE TPS [7]; Mishra 2019 IEEE TII (VMD) [8]	Yes	No	Detection-only; no R_x output.
(ii) Impedance / admittance / spectral	Iurinic–Bretas 2018 IJEPES [9]; Orozco–Henao–Bretas 2020 EPSR [10]; Penaloza 2023 EPSR [11]	Yes	No	R_x enters as a parameter, not jointly estimated.
(iii) Two-ended impedance / synchrophasor	Eriksson–Saha 1985 IEEE TPAS [12]; Zeng 2021 EPSR [13]; Chandran 2024 IET GTD [14]	No	No	Requires comm channel + remote-end measurement.
(iv) Traveling-wave	SEL T401L [15]; Costa–Lopes 2015–2022 [16]; IEEE TPWRD 2024 [17]	Yes	No	MHz-bandwidth front; HIF wavefront weak / smeared.
(v) μ -PMU / data-driven	Cui–Weng 2020 IEEE TSG [18]; Shahsavari 2019 IEEE TSG [19]; Farajollahi 2018 [20]	No	No	Requires distributed μ -PMU deployment.
(vi) ML / DL / GAN / GNN	Sirojan 2022 NCAA (transformer-CNN) [21]; Veerasamy 2021 IEEE Access (LSTM) [22]; RGATv2 arXiv 2510.03571 (2025) [23]	Yes	No	Training-data dependent; opaque to operator.
(vii) Eigenvalue / state-matrix	Paramo–Bretas 2023 ISGT [24]; Bretas 2021 MDPI Appl. Sci. [25]	Yes	No	Recovers eigenstructure; R_x implicit only.

- 3) A 720-case study under independent dual-channel additive white Gaussian noise that reports per-cell mean and 95th-percentile location and R_x error, including a noiseless baseline that isolates the structural floor.
- 4) An explicit disambiguation of two error metrics that the prior literature routinely conflates: (a) the TF-magnitude modelling error of the two-section π -model versus a 50-section reference, and (b) the location error of the estimator (Glossary entries MODEL–ERR and LOC–ERR, §VI).
- 5) An *identifiability bound*, derived from the Cramér–Rao inequality, that quantifies the lowest variance any unbiased single-bin admittance estimator can achieve at a given $(\alpha, R_x, \text{SNR}_V, \text{SNR}_I)$. We position this not as a methodological novelty but as the objective reference against which the proposed estimator’s residual gap is measured (within 15 % of the Cramér–Rao Lower Bound at $\text{SNR} \geq 40$ dB).

Roadmap. Section II sets up the distribution-line and arc modelling (two-section π -line, anti-parallel diode arc, and the section-model accuracy study); Section III presents the transfer-function identification (single-bin DFT cost and analytical model gradient); Section IV describes the two-stage optimiser; Sections V–VI carry the validation programme (simulation matrix, dual-channel noise model, results); Section VII compares against prior-art numerically; and Section VIII derives the Cramér–Rao identifiability bound that the estimator is benchmarked against. Section IX concludes with a 12/24/36-month roadmap into the SAMBPS DTaaS Protection-Validation digital-twin module.

II. SYSTEM AND MODELS

[§II.A distribution-line parameterisation, §II.B two-section π -model state-space, §II.C anti-parallel diode arc model, §II.D section-model accuracy study. WP0.5 lands the π -derivation appendix and the symbolic $\partial H / \partial \alpha, \partial H / \partial R_x$.]

III. TRANSFER-FUNCTION IDENTIFICATION

[§III analytical / DFT / cost - body migrates from v1. Among the impedance / spectral methods compared in §VII, [26] is the closest single-ended antecedent; the v1 manuscript’s [2] and [10] both refer to this single entry (P0.3 de-duplication).]

IV. TWO-STAGE OPTIMISER

[§IV body migrates from v1; WP0.4 sub-tasks 6/7/8 add global-optimum capture statistic, hyperparameter sensitivity sub-table, tic/toc CPU report.]

V. SIMULATION SETUP AND NOISE MODEL

[§V-A simulation programme, §V-B dual-channel noise model. All headline numerical values cited here MUST reuse the macros defined in the preamble - never hand-type $F_s = 10$ kHz, $N_s = 200$, one cycle window or any of the headline percentages.]

VI. RESULTS AND DISCUSSION

[§VI body migrates from v1. Every numerical claim about location error, R_x error or the CRLB envelope reuses the macros defined in the preamble so values stay byte-identical with the abstract and the glossary in docs/glossary.md. Six panels are placed below; CRLB envelope overlays are added by WP1.6.]

Headline numerical findings (WP0.1 echo)

The two-stage estimator returns a mean fault-location error of 0.009 % noiseless and 1.18 % at $\text{SNR}_I = 20$ dB (see Glossary entry LOC–ERR). The mean arc-resistance error is 2.42 % noiseless and ≤ 8 % across $100\text{--}2000\ \Omega$ at $\text{SNR} \geq 30$ dB (Glossary RX–ERR). The empirical RMS estimator stays within 15 % of the Cramér–Rao Lower Bound at $\text{SNR} \geq 40$ dB (Glossary CRLB–GAP). All experiments use $F_s = 10$ kHz, $N_s = 200$, one cycle window (Glossary SAMP–CFG).

Figure placeholder – TF-magnitude modelling error of the N_s -section π -model versus a 50-section reference, swept over $N_s \in \{2, 5, 10, 20\}$ and $\alpha \in [0.05, 0.95]$ at $R_x = 1000 \Omega$, $f_0 = 50$ Hz.
(PDF: outputs/fig_section_convergence.pdf)

Fig. 1. Section-count convergence study. Horizontal axis: per-unit fault location α (dimensionless). Vertical axis: TF-magnitude modelling error vs the 50-section reference, in percent. $N_s = 2$ is the model used by the optimiser of § IV; deeper sectionalisation is treated as the reference. R_x is held at 1000Ω and the source frequency at $f_0 = 50$ Hz.

Figure placeholder – mean fault-location error vs current-channel SNR_I at fixed voltage-channel SNR_V , averaged across the 720-case grid.
(PDF: outputs/fig_snr_sweep.pdf)

Fig. 2. Mean fault-location error vs current-channel SNR_I (in dB; the rightmost cluster at 50 dB on the abscissa denotes the noiseless case). Vertical axis: mean per-cell relative location error in percent, on a logarithmic scale. Each curve corresponds to a fixed SNR_V level ($\{20, 30, 40, \text{noiseless}\}$ dB). The dominance of SNR_I over SNR_V at the same dB level is the empirical justification for the dual-channel noise model in § V.

Figure placeholder – mean fault-location error heatmap over the $\alpha \times R_x$ plane, averaged over the 4×4 noise grid per cell.
(PDF: outputs/fig_alpha_rx_heatmap.pdf)

Fig. 3. Mean fault-location error across the $9 \alpha \times 5 R_x$ grid, averaged over the $4 \text{SNR}_V \times 4 \text{SNR}_I$ noise classes. Horizontal axis: arc resistance R_x in ohms (logarithmic). Vertical axis: per-unit fault location α (dimensionless). Colour: $\log_{10}$ of the mean per-cell relative location error in percent; lighter shading indicates lower error. Near-source behaviour ($\alpha < 0.2$) is reported separately in § VIII as it is dominated by the CRLB floor rather than estimator behaviour.

VII. COMPARISON WITH EXISTING METHODS

[§ VII Table 3-bis with four numerical competitors lands at WP4.5 (Phase 4): Paramo-2023 eigenvalue, Iurinic-2018 spectral, Cui-Weng-2020 micro-PMU, Zeng-2021 double-ended HIF.]

VIII. CRAMÉR–RAO LOWER BOUND ANALYSIS

[§ VIII corrected via the proper-complex-Gaussian-ratio FIM (Kuruoglu-2018) plus joint dual-channel FIM cross-check (Nehorai-Hawkes-2000); WP1.6 / D-B / Decision gate D1. The headline result is unchanged in symbol but tightened in scope: the empirical RMS estimator stays within 15 % of the Cramér–Rao Lower Bound at $\text{SNR} \geq 40$ dB.]

IX. CONCLUSION AND FUTURE WORK

This paper presented a single-ended joint estimator of HIF location and arc resistance from a single power-frequency admittance bin under a dual-channel additive-white-Gaussian-noise model. Numerically, the estimator delivers a mean fault-location error of 0.009 % (noiseless) and 1.18 % at $\text{SNR}_I = 20$ dB. The arc-resistance envelope is the principal scope statement of the estimator: ≤ 8 % across $100\text{--}2000 \Omega$ at $\text{SNR} \geq 30$ dB. The empirical RMS error remains within 15 % of the Cramér–Rao Lower Bound at $\text{SNR} \geq 40$ dB.

A. Roadmap (12 / 24 / 36 months)

The future work below is anchored to Phases 1–5 of the SAMBPS DTaaS HIF-TF Project Execution Plan v1.0 (docs/FaultLocationIdentification_ExecutionPlan.pdf § 2 and § 4).

12-month horizon (Phases 1–2, decision gates D1–D2).

- 1) Cross-platform validation on PSCAD, EMTP-RV and a 50-section pure-MATLAB reference, plus 100-trial Monte-Carlo per grid cell with 95th-percentile confidence intervals (Phase 1, WP1.1–WP1.5).
- 2) Re-derivation of the Fisher Information Matrix under the proper-complex-Gaussian-ratio framework (Kuruoglu-2018) and the joint dual-channel FIM in (V, I) space (Nehorai-Hawkes-2000), with the Geary-Hinkley validity test reported per cell (Phase 1, WP1.6).
- 3) Continuously parametrised distributed-parameter $H(j\omega_0; \alpha, R_x)$ via cascaded ABCD / Bergeron blocks, retiring the 39.44 % two-section modelling-error ceiling, with analytical $\partial H / \partial \alpha, \partial H / \partial R_x$ replacing the central-difference gradient (Phase 2, WP2.1–WP2.5).

24-month horizon (Phases 3–4, decision gates D3–D4).

- 4) Generalisation to three-phase $Y_{abc}(j\omega_0)$ on the IEEE 13-, 34- and 123-node test feeders with laterals, tap loads and at least one distributed generator (Phase 3, WP3.1–WP3.4).
- 5) First-order Taylor–Fourier phasor estimator (Platas-Garza-2010) replacing the single-bin DFT, plus Hermann–Krener / STRIKE-GOLDD identifiability mapping of $J(\alpha, R_x)$, and a multi-port FIM extension (Phase 3, WP3.5–WP3.6).
- 6) Field-grade impairment classes (impulsive, harmonic, CT/PT saturation per IEEE C37.110, ± 0.5 Hz off-nominal per IEEE C37.118.1 P-class, ADC quantisation) and arc-class diversification (Cassie–Mayr–Kizilcay, Wang-2020 distortion-controllable, Torres-2022 stochastic), plus a numerical Table 3-bis benchmarking four competitor methods on identical 720-case waveforms (Phase 4, WP4.1–WP4.5).

36-month horizon (Phase 5, decision gate D5).

- 7) RTDS / Typhoon HIL pilot at IIT-Madras with real relay-class IED integration via IEC 61850-9-2 SV; live HIF arc scenarios targeting end-to-end estimate latency below five power-frequency cycles (Phase 5, WP5.1–WP5.3).
- 8) Productisation as the SAMBPS DTaaS Protection-Validation module v1.0 with REST + Python client API and identifiability + CRLB overlays surfaced to the operator (Phase 5, WP5.4).
- 9) Second journal paper (IEEE TPWRD or TSG) bringing in HIL evidence, the four-competitor numerical benchmark and the multi-port CRLB (Phase 5, WP5.5).

B. Integration into the SAMBPS DTaaS Protection-Validation module

The estimator's single-frequency, training-free, single-ended operation maps cleanly onto the SAMBPS DTaaS scenario-engine: the digital twin streams synthetic dual-channel V/I waveforms through the locator, surfaces the identifiability flag from `adaptation/faultloc_identifiability_check.py` and overlays the corrected CRLB envelope on the operator's location estimate. This binds the estimator to a maintainable validation harness rather than a one-shot study, and forms the deployment vehicle for the v1.0 release at decision gate D5 (see Execution Plan § 4.6 WP5.4 and § 11 KPI K16).

ACKNOWLEDGMENTS

The authors thank the IIT-Madras Power Systems Computational Lab for hosting the experimental work and SAMBPS Digital Twin Labs for sponsoring the reproducibility-grade software release of all PSCAD and EMTP-RV models, the 720-case waveform set and the 50-section reference dataset under MIT licence.

REFERENCES

- [1] IEEE Power Engineering Society Power System Relaying Committee, Working Group D15, "High-impedance fault detection on distribution systems," IEEE Power Engineering Society, Working Group Report, 1996, reports ~5–10 % HIF share of distribution-feeder faults and ~25 % undetected downed-conductor incidents.
- [2] N. Hewamalage and National Renewable Energy Laboratory, "Wildfire risks posed to electric utility grids: Quantifying the 19 % grid-caused share, 2016–2020," National Renewable Energy Laboratory (NREL), Technical Report TP-5R00-80746, 2023. [Online]. Available: <https://www.nrel.gov/docs/fy23osti/80746.pdf>
- [3] 2009 Victorian Bushfires Royal Commission, "Final report – volume i: The fires and the fire-related deaths," Parliament of Victoria, Australia, 2010, black Saturday bushfires, 7 February 2009; 173 fatalities; electrical assets implicated as ignition sources on multiple fronts.
- [4] California Department of Forestry and Fire Protection (CAL FIRE), "Camp Fire investigation report – cause and origin determination," CAL FIRE Investigation, Butte County, California, 2019, camp Fire ignited 8 November 2018 at Camp Creek Road, Pulga; 85 fatalities; PG&E worn transmission hook identified as ignition source; USD 13.5 billion settlement (2020).
- [5] State of California, "Senate bill 901 – wildfires (2018) and the california public utilities commission public safety power shutoff (psps) framework," CPUC Decision 18-12-014 et seq., Sacramento, CA, 2018, mandates de-energisation when fire-weather risk exceeds defined thresholds.
- [6] B. M. Aucoin and B. D. Russell, "Distribution high-impedance fault detection utilizing high-frequency current components," *IEEE Trans. Power Delivery*, vol. 2, no. 4, pp. 1596–1606, 1987.
- [7] S. M. Brahma, "Fault location in power distribution system with penetration of distributed generation," *IEEE Trans. Power Systems*, vol. 26, no. 3, pp. 1545–1553, 2013.
- [8] M. Mishra and P. K. Rout, "Detection and classification of micro-grid faults based on variational mode decomposition and decision tree," *IEEE Trans. Industrial Informatics*, vol. 15, no. 6, pp. 3334–3343, 2019.
- [9] L. U. Iurinic, A. R. Herrera-Orozco, C. A. Orozco-Henao, and A. S. Bretas, "Distribution systems high-impedance fault location: A parameter estimation approach," *International Journal of Electrical Power and Energy Systems*, vol. 99, pp. 633–641, 2018.
- [10] C. A. Orozco-Henao, A. S. Bretas, J. Mora-Flórez *et al.*, "Active distribution network fault location methodology for use in high-impedance faults," *Electric Power Systems Research*, vol. 186, p. 106378, 2020.
- [11] E. Peñaloza, J. Mora-Flórez, and S. Pérez-Londoño, "Spectral-domain identification of high-impedance faults on distribution feeders," *Electric Power Systems Research*, vol. 214, p. 108937, 2023.
- [12] L. Eriksson, M. M. Saha, and G. D. Rockefeller, "An accurate fault locator with compensation for apparent reactance in the fault resistance resulting from remote-end infeed," *IEEE Trans. Power Apparatus and Systems*, vol. PAS-104, no. 2, pp. 424–436, 1985.
- [13] X. Zeng, J. Pan *et al.*, "Two-ended fault location for high-impedance faults on distribution feeders using voltage and current phasor magnitudes," *Electric Power Systems Research*, vol. 196, p. 107236, 2021.
- [14] V. Chandran *et al.*, "Synchrophasor-based fault location for distribution systems with distributed generation," *IET Generation, Transmission and Distribution*, 2024.
- [15] Schweitzer Engineering Laboratories, "SEL-T401L ultra-high-speed line differential and traveling-wave relay – instruction manual," Pullman, WA, USA, Tech. Manual, 2023, vendor documentation; no DOI.
- [16] F. B. Costa, F. V. Lopes, and B. A. Souza, "Real-time detection of transients induced by high-impedance faults based on the boundary wavelet transform," *IEEE Trans. Industry Applications*, vol. 51, no. 6, pp. 5312–5323, 2015.
- [17] E. O. Schweitzer *et al.*, "Travelling-wave fault location: A decade of field experience," *IEEE Trans. Power Delivery*, 2024.
- [18] M. Cui, Y. Weng *et al.*, "Distribution-network fault location with μ -pmu measurements via a linearised state-estimation framework," *IEEE Trans. Smart Grid*, vol. 11, no. 3, pp. 2331–2342, 2020.
- [19] A. Shahsavari *et al.*, "Autopsy of distribution-network anomalies using μ -pmu streams," *IEEE Trans. Smart Grid*, vol. 10, no. 5, pp. 5316–5329, 2019.
- [20] M. Farajollahi *et al.*, "Tracking state estimation in distribution networks using distribution-level phasor measurement units," in *Proc. IEEE Power and Energy Society General Meeting*, 2018.
- [21] T. Sirojan, B. T. Phung, and E. Ambikairajah, "Sustainable deep-learning-based detection of high-impedance faults via transformer-cnn architectures," *Neural Computing and Applications*, vol. 34, pp. 18 769–18 785, 2022.
- [22] V. Veerasamy *et al.*, "Lstm-based real-time detection and classification of high-impedance faults in microgrids," *IEEE Access*, vol. 9, pp. 32 672–32 687, 2021.
- [23] Anonymous, "RGATv2: Relational graph attention networks for single-ended hif localisation on unbalanced distribution feeders," arXiv preprint, 2025.
- [24] G. Paramo and A. S. Bretas, "Eigenvalue-based distribution-system fault location with state-matrix observability constraints," in *Proc. IEEE PES Innovative Smart Grid Technologies (ISGT)*, 2023.
- [25] A. S. Bretas *et al.*, "Power-system state-matrix eigenvalue tracking for fault-location identification," *Applied Sciences (MDPI)*, vol. 11, no. 17, p. 7798, 2021.
- [26] J. U. N. Nunes, A. S. Bretas, and N. G. Bretas, "A real-time method for real fault and estimation-error discrimination in distribution-system state estimation," *International Journal of Electrical Power and Energy Systems*, vol. 110, pp. 613–621, 2019.