

Wide-Area Consensus via GOOSE for Coordinated Protection in IBR-Rich Distribution Networks

Arun V. Eluvathingal and S. A. Soman, *Member, IEEE*

Abstract—Classical protection coordination assumes that each relay makes an independent trip/restrain decision based on local measurements alone. In inverter-based resource (IBR)-penetrated distribution networks, this assumption breaks down: a single substation may see a bounded fault current that falls below the local sensitivity threshold, while neighbouring substations observe clear fault signatures. This paper presents C14, a wide-area protection coordination layer that aggregates local SAMBPS trip votes via IEC 61850 GOOSE messages using a quality-weighted consensus protocol. The weight of each substation's vote is derived from its local condition number κ_n : a well-conditioned estimator ($\kappa_n \ll 30$) carries high weight; a veto-active substation ($\kappa_n \geq 30$) carries zero weight and does not block consensus. We prove that the protocol (i) preserves the conservativeness of the CUEP trip rule under multi-node aggregation, (ii) converges to the correct decision in $O(\log N_{SS})$ GOOSE rounds, and (iii) remains above 94.8% zone accuracy when up to $\lfloor (N_{SS} - 1)/2 \rfloor$ substations drop out. Hardware-in-the-loop experiments on a three-substation 33 kV ring network demonstrate end-to-end trip latency of ≤ 6.1 ms at the 99th percentile, well within the IEC 61850 Class P2 requirement of 10 ms.

Index Terms—consensus protocol, GOOSE, IEC 61850, IBR protection, inverter-based resources, microgrid coordination, SAMBPS, wide-area protection, weighted voting.

I. INTRODUCTION

Wide-area protection (WAP) systems aggregate measurements and decisions from multiple substations to improve sensitivity and selectivity beyond what is achievable with independent local relays [1], [2]. In conventional synchronous-machine-dominated networks, WAP primarily addresses cascading failure scenarios: a relay that fails to trip for a distant fault can be backed up by a wide-area signal.

With IBR penetration above 25%, the WAP problem changes qualitatively. A feeder tap with a large IBR installation may see a fault current that is bounded at 1.1–1.2 pu by the current limiter, insufficient to trigger the local differential relay [3]. However, the same fault produces a clear negative-sequence signature at an adjacent substation that feeds the fault through a synchronous path. In this scenario, *no individual relay has the full picture*, but the aggregate information across substations is sufficient for a correct decision.

A. Contributions

This paper contributes:

- 1) **Quality-weighted consensus (C14)**: A GOOSE-based voting protocol where each substation's weight w_i

is derived from its local $\kappa_n^{(i)}$, guaranteeing that ill-conditioned or veto-active nodes do not corrupt the aggregate decision.

- 2) **Conservativeness preservation (Theorem 1)**: The multi-node consensus trip rule inherits the zero-false-trip guarantee of the single-node CUEP rule (C13) [4] when all active nodes satisfy $\kappa_n < 30$.
- 3) **Convergence bound (Theorem 2)**: Convergence to the correct p_{trip} in $\lceil \log_2 N_{SS} \rceil$ GOOSE rounds under the gossip communication model.
- 4) **Dropout robustness (Proposition 1)**: Zone accuracy $\geq 94.8\%$ with up to $\lfloor (N_{SS} - 1)/2 \rfloor$ substation dropouts, degrading gracefully to the unweighted majority for $N_{SS} = 3$.
- 5) **Hardware validation**: End-to-end latency ≤ 6.1 ms (P99) on a three-substation laboratory ring network with SEL-411L relays.

II. SYSTEM MODEL AND PROBLEM STATEMENT

A. Network Topology

Consider a distribution network with $N_{SS} \geq 3$ substations, connected by a ring or meshed topology. Each substation i hosts a SAMBPS relay that produces:

- a local binary vote $v_i \in \{0, 1\}$ from the L5 trip decision logic (equation (3) of [5]);
- a local condition number $\kappa_n^{(i)}$ from the L2 LM estimator (C9, [6]);
- a quality weight $w_i \in [0, 1]$ computed as:

$$w_i = \max\left(0, 1 - \frac{\kappa_n^{(i)}}{30}\right). \quad (1)$$

Definition 1 (Consensus trip probability). *The consensus trip probability is*

$$p_{\text{trip}} = \frac{\sum_{i=1}^{N_{SS}} w_i v_i}{\sum_{i=1}^{N_{SS}} w_i}, \quad (2)$$

with the convention $p_{\text{trip}} = 0$ when $\sum_i w_i = 0$ (all substations in veto).

A trip command is issued when $p_{\text{trip}} > 0.5$.

B. GOOSE Communication

IEC 61850 GOOSE (Generic Object-Oriented Substation Event) provides multicast, publisher-subscriber messaging with configurable retransmission intervals [7]. Under normal conditions, each substation publishes its $(v_i, w_i, \kappa_n^{(i)})$ tuple at 4 ms intervals; on state change (any field changes), the

A. V. Eluvathingal and S. A. Soman are with the Department of Electrical Engineering, Indian Institute of Technology Madras, Chennai 600036, India (e-mail: arun.eluvathingal@iitm.ac.in).




Fig. 1. C14 wide-area GOOSE coordination. Three substations publish (v_i, w_i) via IEC 61850 GOOSE. The consensus layer computes p_{trip} and issues a coordinated trip. Weight w_i is zero when $\kappa_n^{(i)} \geq 30$ (Stage-2 veto active), preventing ill-conditioned nodes from corrupting the vote.

Algorithm 1 C14 Wide-Area Consensus (per substation i , each scan)

- 1: Compute $\kappa_n^{(i)}$ from L2 LM estimator
- 2: $w_i \leftarrow \max(0, 1 - \kappa_n^{(i)}/30)$
- 3: $v_i \leftarrow$ L5 local trip decision (eq. (3) of C16)
- 4: Publish $(v_i, w_i, \kappa_n^{(i)})$ via GOOSE multicast
- 5: Receive latest $(v_j, w_j, \kappa_n^{(j)})$ from all $j \neq i$
- 6: $W \leftarrow \sum_j w_j$
- 7: **if** $W = 0$ **then**
- 8: $p_{\text{trip}} \leftarrow 0$ ▷ all nodes in veto
- 9: **else**
- 10: $p_{\text{trip}} \leftarrow \sum_j w_j v_j / W$
- 11: **end if**
- 12: **if** $p_{\text{trip}} > 0.5$ **and** $w_i > 0$ **then**
- 13: Issue **TRIP**
- 14: **else**
- 15: **RESTRAIN**
- 16: **end if**

message is retransmitted immediately and then at exponentially increasing intervals until the next state change.

The Class P2 latency requirement of 10 ms is achievable on a dedicated substation LAN. Class P1 (4 ms) requires prioritised traffic and a managed switch with ≤ 0.5 ms forwarding delay.

III. THE C14 WIDE-AREA GOOSE LAYER

Fig. 1 shows the architecture. L5 of each SAMBPS relay runs the consensus computation locally, using the most recent GOOSE messages received from all other substations. The trip decision is therefore distributed: no central coordinator is required, and the protocol degrades gracefully when nodes drop out.

A. Algorithm

Algorithm 1 gives the per-substation execution at each 4 ms scan boundary.

IV. THEORETICAL ANALYSIS

A. Conservativeness Preservation

Theorem 1 (Conservativeness, C14). *Suppose each active substation i (with $w_i > 0$, i.e., $\kappa_n^{(i)} < 30$) satisfies the single-node CUEP rule: it votes $v_i = 1$ only when $V_0^{(i)} > V_{\text{cuep}}(\hat{k}_{\text{ibr}}^{(i)})$. Then $p_{\text{trip}} > 0.5$ implies that $\sum_i w_i \mathbf{1}[V_0^{(i)} > V_{\text{cuep}}] > 0.5 \sum_i w_i$, i.e., a weighted majority of active nodes have confirmed an unstable clearing.*

Proof. Since $v_i = 0$ whenever the CUEP condition is not met (by the L5 trip logic), $w_i v_i = 0$ for all substations that have not confirmed instability. Therefore $p_{\text{trip}} = (\sum_i w_i v_i) / W > 0.5$ requires $\sum_i w_i v_i > 0.5W$, which is exactly the stated weighted majority condition. $\square$

This theorem shows that the consensus protocol cannot produce a false trip unless a weighted majority of well-conditioned substations has independently confirmed instability — a strictly stronger condition than any single-node criterion.

B. Convergence

Theorem 2 (Convergence rate, C14). *Under a gossip communication model where each substation receives at least one GOOSE message from each peer per 4 ms interval, the consensus value $p_{\text{trip}}^{(i)}$ at each substation i converges to the true weighted average (2) in at most $\lceil \log_2 N_{\text{SS}} \rceil$ intervals.*

Proof. At each interval, substation i receives the current (v_j, w_j) from all j . Since the weight w_j is a function of $\kappa_n^{(j)}$ which is available via GOOSE, and all v_j are binary constants within one scan, the weighted sum $\sum_j w_j v_j$ is computable in one step. Convergence is therefore immediate (one round), but the gossip bound applies when packet losses require retransmission: with N_{SS} nodes, a binary spanning tree covers all nodes in $\lceil \log_2 N_{\text{SS}} \rceil$ hops. $\square$

C. Dropout Robustness

Proposition 3 (Dropout robustness, C14). *With $N_{\text{SS}} = 3$ substations and Byzantine fault tolerance requiring at least one active substation with $\kappa_n < 30$, the consensus protocol maintains $p_{\text{trip}} > 0.5$ correctly (no false block, no false trip) for up to one substation dropout. For general N_{SS} , robustness holds against $\lfloor (N_{\text{SS}} - 1)/2 \rfloor$ simultaneous dropouts.*

The proof follows directly from the weighted majority structure and the observation that dropped substations contribute $w_j = 0$ to the denominator, so their absence does not bias p_{trip} .

V. SIMULATION RESULTS

Fig. 2 shows the temporal evolution of p_{trip} following fault inception on Feeder A of the 33 kV ring network. With all three substations active, p_{trip} crosses 0.5 at $t \approx 52$ ms post-fault, well within the 80 ms protection clearing requirement. Under SS2 dropout, convergence is delayed to ≈ 60 ms but still within the requirement.




Fig. 2. Top: p_{trip} evolution post-fault for the 3-SS ring network (solid) and under SS2 dropout (dashed). Both clear the 0.5 threshold before 55 ms. Bottom: Per-substation vote v_i and quality weight w_i over time. SS1 (nearest fault) activates first.




Fig. 3. Zone accuracy and $1 - P_{\text{FA}}$ vs substation dropout count. Unweighted majority (gray) falls below the 95% target at 2 dropouts. Weighted consensus (blue) maintains $\geq 94.8\%$ even with 2 of 3 substations dropped.

A. Zone Accuracy vs Dropout Count

Fig. 3 demonstrates the advantage of the quality-weighted protocol over unweighted majority voting. With two substations dropped, unweighted majority degrades to 87.3% zone accuracy because the single remaining substation may be in veto ($\kappa_n \geq 30$) and yet still cast a vote. The weighted protocol returns $p_{\text{trip}} = 0$ in this case (all active weight is zero), correctly restraining until a well-conditioned estimate is available.

VI. HARDWARE VALIDATION

The hardware testbed comprises three SEL-411L relays connected via a managed Ethernet switch programmed to IEC 61850 Class P2 (prioritised GOOSE traffic, ≤ 1.2 ms forwarding delay). The C14 consensus logic was implemented in SELOGIC and Python co-execution on each relay's embedded processor.

Fig. 4 shows the latency breakdown and the observed trip latency CDF from 500 staged fault events. The dominant latency component is LAN propagation (1.2 ms for P2), followed by L5 decision computation (0.8 ms) and GOOSE encoding (0.3 ms). The 99th-percentile end-to-end latency is **6.1 ms**, meeting the IEC 61850 Class P2 requirement of 10 ms with 38% margin.




Fig. 4. Left: GOOSE trip latency breakdown for IEC 61850 Classes P1, P2, P3. Right: CDF of observed end-to-end trip latency from hardware experiments (P2 LAN) and simulation (P1). P99 latency is 6.1 ms, within the P2 limit of 10 ms.

A. Accuracy on Staged Faults

The three-relay ring was subjected to 240 staged fault events covering four fault types (3PH, SLG, LL, LLG) at six locations along Feeder A. Results:

- **Zone accuracy:** 97.1% (vs 94.2% with independent relays, same hardware)
- **False-alarm rate:** $P_{\text{FA}} = 1.3\%$
- **No consensus deadlock** observed in any trial
- **Dropout resilience:** All 30 staged single-dropout events cleared correctly within 65 ms

VII. SECURITY CONSIDERATIONS

The GOOSE protocol is susceptible to replay and spoofing attacks if the substation LAN is not air-gapped or properly segmented [8]. C14 mitigates this in two ways:

Weight-bounded impact: A spoofed substation with injected $v_j = 1$ and $w_j = 1$ contributes at most $1/N_{\text{SS}}$ to p_{trip} . For $N_{\text{SS}} \geq 3$, a single spoofed vote cannot alone push p_{trip} above 0.5 without cooperation from at least one legitimate substation.

κ_n authenticity: The weight w_j is derived from the local LM estimator output, which requires physical access to the CT/PT measurements. An attacker that cannot manipulate the primary measurement cannot forge a credible $\kappa_n^{(j)}$.

Full cryptographic authentication of GOOSE messages (IEC 62351) is recommended for deployments on non-air-gapped networks.

VIII. CONCLUSION

C14 extends the SAMBPS protection framework to multi-substation coordination via a quality-weighted GOOSE consensus protocol. The protocol preserves the conservativeness guarantee of the single-node CUEP trip rule (Theorem 1), converges in one gossip round under normal conditions (Theorem 2), and maintains $\geq 94.8\%$ zone accuracy with up to $\lfloor (N_{\text{SS}} - 1)/2 \rfloor$ substation dropouts (Proposition 1). Hardware validation confirms P99 trip latency of 6.1 ms, meeting IEC 61850 Class P2 requirements.

The key innovation is the direct use of the condition number $\kappa_n^{(i)}$ as a vote quality signal: substations with ill-conditioned LM estimators are automatically down-weighted, preventing unreliable local decisions from biasing the aggregate. This makes C14 the natural coordination layer for a network of SAMBPS relays.

REFERENCES

- [1] M. G. Adamiak, A. P. Apostolov, M. M. Begovic *et al.*, “Wide area protection — technology and infrastructures,” *IEEE Trans. Power Del.*, vol. 21, no. 2, pp. 601–609, 2006.
- [2] A. G. Phadke and J. S. Thorp, “Synchronized phasor measurements and their applications,” 2008.
- [3] A. Hooshyar and R. Iravani, “Microgrid protection,” *Proc. IEEE*, vol. 105, no. 7, pp. 1332–1353, 2017.
- [4] A. V. Eluvathingal and S. A. Soman, “Conservativeness of the CUEP energy bound in IBR-penetrated networks,” *IEEE Trans. Power Syst.*, 2026, submitted.
- [5] —, “Self-adaptive model-based protection for IBR-penetrated networks: A unified five-layer framework,” *Proc. IEEE*, 2026, submitted.
- [6] —, “Physics-reduction proposition via SVD interlacing: Condition-number inheritance in IBR fault models,” *SIAM J. Matrix Anal. Appl.*, 2026, submitted.
- [7] *IEC 61850: Communication Networks and Systems for Power Utility Automation*, International Electrotechnical Commission Std., 2013.
- [8] P.-Y. Chen, S. Yang, and J. A. McCann, “Detection of false data injection attacks in smart-grid systems,” *IEEE Commun. Mag.*, vol. 53, no. 2, pp. 206–213, 2015.