



Grid-Following (GFL)

$k_{ibr} = 0.20$ 40m SLG fault



Grid-Forming (GFM)

$k_{ibr} = 0.20$, transient (100 ms)



GFM negative-sequence ratio $I_2/I_1 = 0.40$ ($4\times$ GFL). 67Q directional element activates at $k_{ibr} \geq 0.10$ for GFM vs $k_{ibr} \geq 0.40$ for GFL.