

L1

CT Waveforms  
3-phase, 1 kHz



L2

Conventional Baseline  
% differential / operate-restrain

$I_{op}, I_{rst}$



L3

Reduced-Parameter  
Zone Model  
2-pass Levenberg-Marquardt

$\hat{\theta}$



L4

$\kappa_n$  &  $f_{int}$   
condition no. + integrity index

$\kappa_n, f_{int}$



L5

Stage-2 Confidence Gate  
model-veto / pass-through

conv. trip flag



Pass Through  
conventional

no

$\kappa_n < \kappa^*$  and  
 $f_{int} < f^*$ ?

yes

Model Veto  
restrain

$\kappa^* = 30$  (87T/87L/87B), 50 (OC)  
 $f^* = 0.60$