26 April 2022
Endeavour Energy Ref: ARP4983

WSP Australia Pty Ltd
Level 27, 680 George St
SYDNEY NSW 2000

Attention: Richard Saliba

Dear Sir/Madam

ARP4983 – LOT DP Asset Relocation Application: Package 3 Elizabeth Street, CECIL PARK

Your Proposed Method of Supply has been assessed, and Endeavour Energy has determined the method of supply requirements as outlined in the enclosed Design Brief. Please use this Design Brief in preparation of the design package which you will submit for certification.

The design must comply with all the conditions specified in this document, the Terms and Conditions of Endeavour Energy's Model Standing Offer for a Standard Connection Service and all relevant Endeavour Energy standards and instructions.

This Design Brief is valid for three (3) months from the date of issue.

A final Determination of Funding and a Payment Advice for Ancillary Network Services Fees applicable to this phase of the project are attached.

Land Interests as specified in the Land Interest Guidelines ("LIG") are required for this project:

☐ NA

Should you have any enquiries regarding your application please contact the undersigned.

Yours faithfully,
Tri Minh Truong
Customer Network Engineer
Ph: 02 9853 7922
Email: CWTech@endeavourenergy.com.au

26 April 2022
Endeavour Energy Ref: ARP4983

Design Brief

Method Of Supply Requirement:
Method of Supply
The following asset relocation works are for this development:
Substation & Switching Station Works
• Remove Pole Sub at ref ‘29’ at Elizabeth Dr.
• Install New Pole Sub at ref ‘9’ at Elizabeth Dr.
HV Works
• Remove OH HV cable between pole at ref ‘1’ and pole at ref ‘20’ along southern side Elizabeth Dr as shown on sketch.
• String new OH HV cable between pole at ref ‘1’ and pole at ref ‘20’ along northern side
Elizabeth Dr as shown on sketch.
LV Works
• Remove OH LV cable between pole at ref ‘23’ and pole at ref ‘20’ along southern side
Elizabeth Dr as shown on sketch.
• String new OH HV cable between pole at ref ‘3’ and pole at ref ‘20’ along northern side
Elizabeth Dr as shown on sketch.

SL Works
• Remove SL and install new SL as shown on the sketch.
General
• Pole location, pole number, and pole loading calculation to be carried out during detail
design.
• New OH road crossing service connection proposed to maintain existing service connection
Duct Works
• Lay new as per EE standard.

Design Brief:
Design’s MOS is generally acceptable except for changes as shown on mark ups below.



Design drawing must comply with MDI0031, MCI0005 and relevant standards.

The scope of works is to be undertaken in accordance with Connection Policy and Model Standing Offers and must comply with all relevant policies, regulations and network standards.

All service works are to comply with the requirements of the NSW Service and Installation Rules

Determination of Funding

Endeavour Energy Supplied Materials:

Nil

Endeavour Energy Funded and Constructed:

Nil

Endeavour Energy Funded and Customer (ASP L1) Constructed – Reimbursement Paid by Endeavour Energy:

Capital contribution:

- Spare HV duct as per Fact Sheet 11

Reimbursements to be paid to Endeavour Energy by Customer:

- Duct usage charge as required

Customer Funded Non-Contestable Works:

Network switching, substation commissioning, contract inspection

Customer Funded Contestable Works:

All other works required.

PAYMENT ADVICE/PRO FORMA TAX INVOICE

ABN 11 247 365 823

ANCILLARY NETWORK SERVICES FEES

Applicant: WSP Australia Pty Ltd
Address: Level 27, 680 George St
SYDNEY NSW 2000

Project Address: PACKAGE 3 Elizabeth Street
CECIL PARK NSW

Fees and Charges quoted in this letter are valid for 3 months Endeavour Energy reserves the right to amend the fees and charges at any time subject to any regulatory approval.

The required AER Monopoly fees and charges consist of:-

Standard Connection Offer Fee	09-02-2022	$271.61
Design Information Fee	09-02-2022	$1448.65
Design Certification Fee	09-02-2022	$2897.31
Administration Fee	09-02-2022	$359.27
Total		$4976.84

Total Amount Due: $ 4976.84 GST inclusive

Please follow the payment instructions below to avoid unnecessary delay in processing your payment.

Endeavour Energy's preferred method of payment is EFT.
BSB: 012-003 Account Number: 8376 89858

Please quote our reference ***ARP4983A2*** in the EFT transaction reference field
Please email a copy of the remittance to **remittances@endeavourenergy.com.au**

Payment by credit cards and cheques will not be accepted

Your Tax Invoice will be forwarded to you upon the receipt of your payment.