

Comfort-Constrained Operation of Multi-Mode HVAC in a Saudi Apartment Building under a Volume Tariff and Parameter Uncertainty

Hamzah Faraj

Department of Sciences and Technology, Ranyah University College, Taif University
P.O. Box 11099, 21944 Taif, Saudi Arabia

E-mail: f.hamzah@tu.edu.sa – ORCID: 0009-0009-8832-0407

Abstract

Air-conditioning dominates Saudi household electricity. We ask which lever lowers it in apartment buildings under the volume tariff households pay: setpoint, operating mode, envelope, equipment or timing. A four-storey building meeting the Saudi Building Code is modelled room by room, with coupled two-node rooms, split heat pumps as installed (thermostats, inverter and fixed-speed compressors, cycling and standby losses), typical-year Riyadh and Jeddah weather and per-apartment meters, and checked against EnergyPlus. The code envelope saves 38–56% of HVAC electricity against the pre-code envelope, raising the cooling and heating setpoints from 22 and 20.5 to 23.5 and 22.5 °C saves 9.8–12.4%, and inverter units replacing fixed-speed ones save 11–15% on assumed part-load data; the lowest mode that holds the room is cheapest. In the base model none of the 48 thermostat pre-cooling settings saves, and 2 K before the peak costs 3.4–4.3%. A perfect-foresight linear program bounds what any schedule of an idealised loss-free model saves at 1.9% of sensible cooling electricity within the band and 3.6% down to 20 °C (design days of every case). An illustrative time-of-use tariff makes pre-cooling save 2–27%, locating the null result in the tariff. A global uncertainty analysis of 17 assumed inputs (128 Latin-hypercube samples per city) keeps the lever ordering in every comparison within the safe set, and no pre-cooling setting tested saves in any sample. The results hold for an energy-only tariff, every room occupied and conditioned at all hours, a hard 24 °C ceiling and coverage-sized units.

Keywords: multi-mode HVAC; setpoint; building envelope; pre-cooling; uncertainty analysis; Saudi Building Code

1 Introduction

Air-conditioning dominates residential electricity use in Saudi Arabia. Space cooling takes about two-thirds (66%) of household consumption in the national stock model [1] and more than 70% in recent building studies [2, 3]. A large literature, and a growing range of “smart” thermostats, propose to reduce it by *scheduling* the air-conditioners (pre-cooling rooms before the afternoon, shifting load to cheaper hours, coordinating the units of neighbouring rooms) and report double-digit reductions in peak demand or cost [4–6]. These savings, however, are obtained under particular envelopes, particular setpoints and, above all, particular tariffs, most often prices that vary with the time of day.

Motivation. Before households, builders or regulators invest in scheduling, they need to know whether it pays under the conditions that Saudi households actually face and, if it does not, which lever does. Three features of these conditions make the question pressing. First, the residential tariff is a two-tier *volume* tariff: it prices how much energy a household uses, not when [7]. Second, the summer climate and a hard comfort ceiling leave no room to let occupied rooms warm up, so the only temporal action available is to pre-cool. Third, many urban households live in apartment buildings. Every room is coupled to its neighbours through walls, slabs and open doors, a third of the floor area (baths, corridors, halls) has no air-conditioner, and every apartment has its own meter, so a saving must be computed room by room and meter by

meter. For a single room at constant conditions it is intuitive that pre-cooling cannot pay when only energy is priced. For such a building it is not: rooms are coupled, a third of them have no unit, the coefficient of performance (COP) changes with the hour and the mode, and a study of Saudi homes under the same tariff reports coordination savings of several percent [8]. We are not aware of a study that separates the scheduling, setpoint and envelope levers under these three conditions together (Section 2). This paper asks: for a representative Saudi apartment building, with its floor plan, its air-conditioners and the tariff its households pay, how much can heating, ventilation and air-conditioning (HVAC) save, in summer and in winter, and through which of five levers: the setpoint, the operating mode of the units, the envelope, the equipment, or the timing of operation?

We answer with a simulation-based analysis, supported by theory, of one building in two climates, hot-dry Riyadh and hot-humid Jeddah, and in three cases: Case 1, one apartment; Case 2, the typical floor of two apartments; and Case 3, the whole four-storey building. The building meets the residential envelope requirements of the Saudi Building Code (SBC) for climate Zone 1, and the same building with the envelope of the existing uninsulated stock serves as the comparison. Throughout, the bill is minimised over the policies that keep every conditioned room within the safe set $[20, 24]$ °C, which contains the 22–24 °C comfort band (Section 5.8).

The contributions are:

- (1) *Evidence.* A decomposition of the achievable saving by lever across the three cases, two cities and two seasons,

for an energy-only (volume) tariff, every room occupied and conditioned at all hours (A4), the hard 24 °C ceiling and catalogue units sized by coverage. The savings come from the envelope (38–56%), the setpoint (9.8–12.4%, raising the cooling setpoint from 22 to 23.5 °C and the heating setpoint from 20.5 to 22.5 °C) and the equipment (inverter units in place of the fixed-speed ones, 11–15%; sizing by load alone, 0.2–2.1%); the cheapest mode is the lowest mode that holds the room. Timing is worth little in the base model: no thermostat pre-cooling setting saves, even after correcting for the smaller extra heat that EnergyPlus finds for a setback, and a perfect-foresight benchmark bounds what any schedule of an idealised loss-free model could gain (Section 9.3). An illustrative time-of-use tariff makes pre-cooling save in the same model, which locates the null result in the tariff. A factorial decomposition of the levers with Shapley attribution separates their interactions (Section 9.4), and a global uncertainty analysis over 17 assumed inputs tests whether the conclusions survive parameter uncertainty (Section 9.7).

- (2) *Model and method.* A room-resolved heating-and-cooling model of a four-storey building built directly from a representative floor plan, with two-node rooms, wall, slab and open-door coupling, measured weather with angle-dependent window gains and long-wave sky exchange, an ISO 13370 ground, a latent load from the measured humidity, catalogue units as installed (thermostats with a differential, inverter and fixed-speed compressors, cycling losses, standby power, capacity derating) and per-meter billing, compared with EnergyPlus, including its response to setbacks, and with the stock energy use. The method uses one optimisation, a perfect-foresight optimal-control linear program over an idealised form of the problem: with a COP that depends on the outdoor air only it gives an upper bound on the saving of any schedule of that model, and with the engine’s COP an achievable saving below that bound. Against it, the pre-cooling settings that a thermostat can realise are evaluated by annual simulation on normal and hard instances.
- (3) *Theory.* An energy accounting for multi-mode units under a hard ceiling, which adapts the storage-efficiency view of energy flexibility [9, 10] to the multi-mode framework of Mousa et al. [11, 12] (timed actions, leaps, runs and limit-average costs), instantiated with the Saudi tariff. A room’s mean power over a leap cycle is its heat gain at the cycle’s mean temperature divided by the COP of the mode used, so the optimal stationary schedule holds the highest level whose cycle stays under the ceiling in the lowest mode that holds the room (Theorem 1); for a thermostat this places the comfort frontier half its differential below the ceiling. For every tariff that prices energy alone, pre-cooling adds cost wherever it admits more heat than it gains in efficiency, and a bound limits what it can gain elsewhere (Theorems 2 and 3); savings can come only from removing less heat or removing it more efficiently (Proposition 1). Conditioned neighbours at a common level exchange no net heat (Section 6.1), and a heat budget bounds what the rooms without a unit can reach (Section 6.1).

Section 2 positions the work and Section 3 outlines the methodology (Fig. 1). Section 4 describes the case study, Section 5 the model and the problem, and Section 6 the theory. Section 7 sets out the experiments, Section 8 verifies and validates the model, Section 9 reports the results, Section 10 discusses them and their limits, and Section 11 concludes. Appendices A and B give the symbols and the proofs, and Appendices C–J the supporting analyses and tables: the passive zones, the benchmark on every design day, the room schedule and weather, the formal definitions, the validation details, the full sensitivity analysis, the uncertainty analysis and the calculation time. The repository regenerates every number in the paper.

2 Related Work and Positioning

HVAC control: from thermostats to policy-level scheduling. Residential HVAC control has progressed from bang-bang thermostats, through programmable setback and setpoint scheduling, to model-predictive and learning-based controllers and, in the systems literature, to multi-mode and green scheduling of the plant. Each step adds control sophistication, but none by itself answers the economic question of *how much* a household’s bill can fall and *through which lever*.

Scheduling of multi-mode and hybrid systems. HVAC control is a hybrid system of discrete switching and continuous dynamics [13]. Optimal scheduling has been solved for constant- and linear-rate multi-mode systems [14, 15], where a system is schedulable from the interior of the safe set exactly when dwell times exist whose rate vectors sum to zero, and for bounded-rate systems [16]; optimal control was extended to simple linear hybrid systems and to discrete switching costs by Mousa et al. [11, 12]. Green scheduling recasts peak reduction as the scheduling of coupled zones with periodic or event-based schedules [17–19]. We adopt this formalism for the plant: Definition 1 specialises the zero-sum condition to a single room, and the coupled-zone dynamics of Nghiem et al. [17] carry the thermal shift between rooms. We then embed it in a floor plan, catalogue equipment, the actual tariff and a latent-load model, where the economic content of a saving lies.

Predictive and learning-based control. Model predictive control (MPC) is the most studied advanced approach (reviewed by Drgoña et al. [20]), from Oldewurtel et al. (2010) [21], Ma et al. (2012) [22] and Moroşan et al. (2010) [23] to the decentralised formulation of Chandan and Alleyne (2014) [24]. Zheng et al. (2024) [25] extend it to reduced-order resistance–capacitance (RC) economic MPC, and Wang et al. (2024) [26] to machine-learning surrogates for demand response. Statistical model checking and reinforcement-style synthesis, as in the tool of David et al. (2015) [27], handle continuous state at the cost of large state spaces. For the same Saudi residential setting, a recent study (2026) [8] developed a reinforcement-learning coordinator based on physics-informed proximal policy optimisation (PI-PPO) that learns a stationary scheduling policy for multi-zone split units under the two-tier tariff. That work and the present

paper are complementary. It contributes a learning-based controller; Section 10 relates its savings to the levers separated here. More broadly, the savings reported across this literature vary widely and are seldom decomposed by lever or tested for their dependence on the tariff.

Pre-cooling and passive thermal storage. A large demand-side-management literature promotes *pre-cooling*, that is, driving zone temperatures down during off-peak hours so that the building’s thermal mass stores “coolth” and daytime cooling is reduced. It began with the optimal thermal-storage control of Braun (1990) [4] and has developed through decades of simulation and field trials, including simplified optimal strategies [28], predictive control of active and passive storage [29] and residential field tests [30]. The reviews and rate-structure studies of this literature find that the cost savings come mainly from time-of-use prices and demand charges, and that pre-cooling usually raises the energy used [30–32]. Recent studies by Naderi et al. (2022) [5] and Mayes et al. (2024) [6] confirm that its value depends on time-of-use pricing and thermal mass. The premises of this literature matter. Braun lists the opportunities of pre-cooling as (i) reducing coincident *peak demand*, (ii) exploiting cheaper *night-time rates*, (iii) offsetting mechanical cooling with *free night cooling*, and (iv) improving the *efficiency of mechanical cooling* through cooler night-time condensing conditions and part-load operation. These opportunities depend on the tariff and the climate. Under a residential volume tariff the first two do not apply (see below), and night temperatures in the Saudi cooling season are far too high for free cooling, so only the fourth, a diurnal COP swing, remains. Theorem 2 bounds what it can yield, and a perfect-foresight linear program bounds what an idealised schedule can attain (Section 9.3). The present study formalises and quantifies this known mechanism for the Saudi tariff and building; it does not claim it as new.

Energy flexibility and pre-cooling in hot climates. The energy-flexibility literature treats the thermal mass as a store and accounts for what it costs. Le Dréau and Heiselberg [9] quantify the flexibility that short-term storage in the thermal mass gives residential buildings and the extra energy it entails, and Reynders et al. [10] review the definitions and indicators of flexibility, among them the capacity and the efficiency of structural thermal storage. In hot climates, Arababadi et al. [33] show that envelope efficiency measures make residential pre-cooling more effective in a hot arid climate, and Cole et al. [34] coordinate the air-conditioners of a residential community to relieve the grid, both with the aim of moving load away from the peak. The theory of Section 6 adapts this storage-efficiency accounting to multi-mode units under a hard ceiling: pre-cooling pays only where the efficiency it gains outweighs the extra heat it admits.

Tariffs, demand response, and the value of flexibility. The tariff, rather than the controller, creates the economic value of shifting load. Time-of-use, critical-peak and real-time prices, or demand charges, reward temporal flexibility, whereas a pure volume tariff does not. Tariff-aware and peak-aware control, such as the price-responsive MPC of Oldewurtel et al. (2010) [21] and the peak-reduction green

scheduling of Nghiem et al. (2011, 2013) [17, 19], therefore presupposes a price or peak signal to exploit. Saudi residential customers face a two-tier *volume* tariff with no time signal, as published by SERA (2026) [7], so this premise does not hold for their bill (Theorem 3).

Saudi envelope, stock and simulation studies. Work on the SBC envelope and the existing stock provides the envelope requirements, construction U-values and stock energy use on which we build (2019–2022) [35–38]. The stock model of Krarti et al. (2020) [1] puts the residential energy use intensity (EUI) at 125.6–182.4 kWh/m²yr across the four regions and uses it to evaluate national retrofit programmes. Building-scale simulations report that combined passive measures cut the cooling demand of a Saudi villa by 68% (IES-VE; Rodrigues et al. (2025) [2]) and that retrofit packages save 25–66% in a low-rise Jeddah apartment building (DesignBuilder/EnergyPlus; Felimban et al. (2023) [3]), with cooling accounting for more than 70% of residential electricity in both. Aldubyan and Krarti (2022) [39] show that operation matters: stay-home living by itself raised residential demand materially during 2020. Krarti and Aldubyan (2022) [40] optimise retrofits for the electrical peak demand of the housing stock, Alaidroos and Krarti [41] optimise residential envelopes for Saudi cities, and Krarti and Howarth [42] evaluate the costs and benefits of moving Saudi homes to high-efficiency air-conditioners. Outside the Kingdom, Hoyt et al. [43] show by simulation that extending the cooling and heating setpoints saves a substantial share of HVAC energy. This literature establishes the magnitudes and the levers one at a time and treats the envelope largely in isolation. It does not decompose the levers under the same comfort ceiling against the actual tariff. Nor does it test whether the temporal-scheduling lever that dominates the demand-response literature carries any value under the volume tariff these customers face.

Research gap and positioning. Three gaps recur across these strands. (G1) *Lever conflation*: reported savings mix envelope, setpoint and schedule, so a headline percentage cannot be attributed to a cause that a policymaker can act on. (G2) *Tariff-blindness*: the value of temporal flexibility is assumed rather than tested against the customer’s actual tariff, even though it is the tariff that creates or removes that value. (G3) *Weak grounding*: envelope parameters and comfort targets are often assumed rather than derived from the governing code and climate. This study addresses all three with a code-grounded, room-resolved model with the equipment and thermostats as installed, compared with EnergyPlus on identical inputs; a decomposition by lever under the same comfort ceiling; and a test of scheduling under the tariff that Saudi households pay, with a theoretical bound for every energy-only tariff and a perfect-foresight benchmark. The Saudi retrofit studies of Krarti et al. [1] and Krarti and Aldubyan [40] quantify *how much* envelope and equipment upgrades save; the contribution here is a controlled *decomposition* of the operational levers, which shows that, in the base model, moving cooling in time is worth little under the prevailing tariff, and nothing in the form thermostats offer, whereas the setpoint, the equipment and the envelope pay. Table 1 places the study against these strands; the advance

lies in the study design rather than in the optimiser.

3 Methodology

The study proceeds in six stages (Fig. 1), each described in the section named in the figure. The timing lever is pre-cooling, the only re-timing that the hard 24 °C ceiling permits when every room is occupied (A4). One optimisation method is used: a perfect-foresight optimal-control linear program over an idealised form of the bill-minimisation problem, which bounds what any schedule of that model can save and, with the engine’s COP, finds an achievable saving below that bound (Section 7.2). The thermostat policies a household can choose are not optimised but evaluated: each is simulated for a year with the realistic controller and billed per meter, and the cheapest admissible one is kept (Algorithm 1 and Section 7.2). Each lever (setpoint, mode, envelope, equipment, timing) is then changed on its own against a stated baseline in three cases, two cities and both seasons; a factorial decomposition and a global uncertainty analysis test the interactions between the levers and the robustness of the conclusions (Section 9). One reproducible pipeline carries the inputs to every number in the paper.

4 Case Study: Climate, Comfort and the Building

This section describes the case study: the two climates, the comfort band, and the building with its air-conditioners, its two envelopes and the three cases in which it is analysed. The model of Section 5 is built on it, and all results are computed for it.

4.1 Climate of Riyadh and Jeddah

The SBC divides the Kingdom into climate zones, and all Saudi cities are cooling-dominated [1, 35]. Riyadh and Jeddah are the two largest cities and represent the two main residential climates, interior hot-arid and coastal hot-humid. Riyadh has large daily and seasonal swings, a small winter heating need and shoulder months close to the comfort band. Jeddah is warm and humid all year, so it needs cooling and dehumidification throughout, and its latent load is large where Riyadh’s is negligible. Riyadh’s cool winter also shows the winter side of the envelope, since insulation that helps in summer keeps internal gains in the building in winter. The pair therefore tests the levers in two different ways and shows whether the results hold across climates.

The model is driven by hourly weather for Riyadh and Jeddah from typical meteorological years (TMYx) assembled from measured records. The files give dry-bulb and dew-point temperature, pressure, and global, direct and diffuse solar radiation, and they are the same files read by the EnergyPlus benchmark (Section 8.2). Fig. 2 plots the three components that drive the model: air temperature against the comfort band, relative humidity, and solar radiation; the monthly values are tabulated in Appendix E. Riyadh is hot and dry: its monthly mean rises from 14.7 °C in January

to 36.4 °C in July, with daily maxima above 43 °C and relative humidity near 12% in summer. Jeddah is milder but humid: its mean never falls below 23.5 °C and its relative humidity stays between 54% and 70% all year. Both receive 4–8 kWh/m² of solar radiation per day.

4.2 Comfort range: ASHRAE, SBC, and the one-sided ceiling

ASHRAE 55 defines comfort through the predicted mean vote (PMV): a space complies when the PMV stays within ± 0.5 , that is, at most 10% predicted percentage dissatisfied (PPD) [44, 45]. For summer clothing (0.5 clo), light activity (1.1–1.2 met), still air and 50% relative humidity, this spans roughly 23–27 °C of *operative* temperature, and about 19–24 °C in winter clothing (1.0 clo). The SBC regulates the building fabric (Section 4.3) rather than the setpoint, which is left to the occupant and to efficiency guidance.

We adopt a comfort band $[V_{\text{low}}, V_{\text{high}}] = [22, 24]$ °C of air temperature and treat its upper bound as a *hard* ceiling rather than the centre of a symmetric deadband. There are three reasons for this choice in Saudi homes. First, in sunlit construction with warm inner surfaces the operative temperature exceeds the air temperature on summer afternoons, most in rooms under an uninsulated roof; in the insulated building studied here the excess is small (Section 9.1), so a 24 °C ceiling sits in the lower half of the ASHRAE summer zone, but in the uninsulated stock and under a roof it moves a 24 °C room towards the upper part of that zone, and letting rooms coast above the ceiling during the peak would take them towards its edge. The hard ceiling is therefore a conservative choice for the insulated building and a protective one for the stock. Second, at Jeddah’s 54–70% relative humidity (Fig. 2b) evaporative cooling of the body is suppressed and the comfortable dry-bulb ceiling is lower still. Third, in the summer heat conditioned rooms are refuges for vulnerable occupants. The ceiling also matches the lower end of the 24–26 °C range recommended by efficiency guidance in the neighbouring Gulf state of Qatar [46]. This choice ensures that no saving is gained at the expense of comfort; the operative temperature it implies is checked in Section 9.1. The safe set is imposed on the conditioned rooms, where occupants stay; the band is their comfort target. The passive zones, the rooms without a unit (Section 4.3), are compared with the band but not constrained by the safe set, and Appendix C reports how the controller brings them close to it.

Flexibility is therefore *one-sided*. Both bounds of the safe set $[V_{\text{min}}, V_{\text{max}}] = [20, 24]$ °C are hard (Section 5.8), so a controller may pre-cool into $[20, 22]$ °C, below the band, but never let an occupied room rise above the ceiling. Every re-timing of cooling in this paper is therefore a pre-cooling action (cool into the headroom, then return to the setpoint) and never an upward coast (illustrated in Section 5.5). Since every room is taken to be occupied at all hours (A4), no room is allowed to float.

Table 1: State-of-the-art comparison: positioning against representative prior work. ✓: yes; ○: partly; –: no. Param.: envelope parameters derived from the code and cited sources; EUI: energy use checked against the stock; Tariff: the real tariff is used; Levers: savings decomposed by lever (E: envelope only); Tariff dep.: dependence of the saving on the tariff (A: one tariff or price signal assumed, not tested; T: compared across tariffs; B: bounded for every energy-priced tariff, with a perfect-foresight benchmark and a time-of-use contrast).

Ref.	Method (study strand)	Years	Param.	EUI	Tariff	Levers	Tariff dep.
[4–6, 9, 10, 28–34]	Pre-cooling, thermal storage, flexibility	1990–2024	○	–	○	–	T
[20–23, 25, 26]	Building MPC	2010–24	○	○	○	–	A
[1–3, 36, 38, 41]	Saudi envelope and code	2015–25	✓	✓	–	E	–
[8]	Learning-based coordination (Saudi homes)	2026	○	–	✓	○	A
This work	Multi-mode theory, optimal control, room-resolved simulation	2026	✓	✓	✓	✓	B




Figure 1: Methodology. The inputs (Section 4) define a room-resolved model of the building (1), which is written as a multi-mode system and a bill-minimisation problem within a hard safe set (2, Section 5). The theory (3, Section 6) characterises the optimal schedule and bounds what pre-cooling can gain; the computation (4, Section 7) solves an idealised form of the problem once, as a perfect-foresight optimal-control program, and evaluates by annual simulation the pre-cooling settings a thermostat can realise. After the model is verified and validated (5, Section 8), the experiments (6, Section 9) change one lever at a time and check the theory’s conditions.

4.3 The building: layout, air-conditioners, envelope and analysis cases

The study object is a four-storey apartment building with two apartments per floor, a common housing type in Saudi cities (Fig. 3). The building was designed for this study as a set of layered DXF drawings (plans, section and elevation), with room sizes, wall types, storey height and stair dimensions that follow the Saudi Building Code (Fig. 3a). Each apartment has a master bedroom reached through a lobby that also serves its bath, two further bedrooms (Bed 2 and Bed 3), a living room open to a dining area and joined to an enclosed west balcony, a kitchen, a guest room, three further baths, a maid room, and a corridor, hall and entrance; the room dimensions are listed in Appendix E. The two apartments of a floor mirror each other about a common stair (4.25 × 9.05 m) on the south side, on a 19.15 × 28.00 m footprint (Fig. 3b). Four floors of 3.40 m (3.00 m clear) form the building, entered from the south (Fig. 3c). The top of the plan faces north. Apartments are numbered by storey, from 1 (ground) to 4 (top), with A on the west and B on the east.

Each room is one thermal zone of the model (Section 5.2), a rectangle (or union of rectangles) on the wall centrelines of the drawing, so that each zone’s clear size is that of the drawing; the enclosed balcony is an unconditioned zone. Each

window enters with its own width and orientation, which gives a window-to-wall ratio of 17.3% for the building. The model derives each zone’s floor area, its exterior walls and their orientations, and every shared wall and slab from the rectangles, so no adjacency is entered by hand. An apartment covers 231 m² on wall centrelines (without the balcony), a floor has 33 zones and the building has 132.

Every bedroom, the living room, the dining area, the kitchen and the guest room has its own split unit, chosen from a four-model product catalogue by rated coverage (Table 2; 1 ton = 3.517 kW of cooling). The drawing gives the living room and the dining area a unit each; together they cover 36 m², the upper limit of the largest unit’s coverage, so one unit would have no margin. They are modelled as two zones joined by a 5.00 m opening. The baths, the maid room, the lobby, the corridor, the hall and the balcony have no unit. Interior doors are open, with the widths of the drawing (0.70–0.90 m) and the 2.032 m height that SBC 201 sets for egress doors [47]; the wall-free openings of the open plan (corridor and hall to the living and dining area, living to dining) are 2.20–5.00 m wide and 3.00 m high. The apartment entrance and balcony doors are closed. The stair is conditioned and billed on a common meter, and each apartment has its own meter, to which the tariff applies. Each apartment therefore has seven units (14.0 tons), and the building has 60 units on




Figure 2: Annual weather of Riyadh and Jeddah (TMYx typical years). (a) Monthly mean air temperature and mean daily range against the comfort band: Riyadh crosses the band seasonally and exceeds 43 °C on summer afternoons, while Jeddah's monthly mean never falls below it. (b) Relative humidity: Riyadh is dry in summer and Jeddah humid all year, which drives its latent load. (c) Daily solar irradiation, 4–8 kWh/m² in both cities, which drives the solar gains.

nine meters.

The 1.5-, 2.0- and 2.5-ton units are inverter split heat pumps, modelled with four operating modes numbered 0–3: off and three on modes, low, medium and high. The 3-ton unit is a fixed-speed rotary-compressor heat pump; its three fan speeds do not modulate the compressor, so it is modelled as an on/off unit that runs at full capacity whenever it runs. Sizing by rated coverage is how such units are chosen in practice; with the SBC envelope it leaves them several times larger than the peak load, and a right-sized alternative is tested in Section 9.7. Their efficiency is anchored to the air-conditioner standard of the Saudi Standards, Metrology and Quality Organization (SASO), SASO 2663, whose 2014 edition set a minimum split-unit energy efficiency ratio (EER) of 11.5 (Btu/h)/W at test condition T1 [48]; the 2021 edition moved to seasonal ratings [49]. At full load and the T1 rating condition (35 °C outdoors, 27 °C indoors) the modelled COP is 3.37, which equals an EER of 11.5; at the 23.5 °C reference setpoint it is 3.13. The higher efficiency of the low and medium modes follows the assumed part-load ratios of Eq. (1) (Section 5.2). The heating capacity of each unit is taken as 1.14 times its cooling capacity (6.0 kW for the 1.5-ton unit), an assumed value.

Passive zones. About a third of each apartment's floor area has no unit: the four baths, the maid room, the lobby, the corridor and the entrance hall. These *passive zones* are cooled in summer and heated in winter only by the thermal shift from their neighbours (Section 5.3). Their temperatures are therefore outputs of the model, not controlled quantities. Section 6.1 states what they can reach, and Section 9.1 reports them.

Envelope. SBC 602 is the Kingdom's energy-conservation code for low-rise residential buildings [50]. It sets the envelope performance (wall, roof and glazing U-values and the glazing solar heat gain) for three climate zones [1, 35]. The earlier SBC 601 of 2007, which did not cover low-rise

residential buildings, specified the less strict wall and roof U-values of 0.53 and 0.31 W/m²K [35]. The walls, roof and glazing of the building meet the residential requirements for climate Zone 1 (SBC 602, as tabulated by Krarti et al. [1]), the hottest zone, which includes Riyadh. We apply the same requirements in both cities as a common reference: a wall U-value of 0.34 W/m²K [1, 35, 50], roof and window U-values of 0.20 and 2.67 W/m²K and a glazing solar heat-gain coefficient (SHGC) of 0.25 [1], with the windows of the drawing (window-to-wall ratio 17.3%). Partitions and floor slabs keep the uninsulated U-values of the existing stock, and the ground slab is uninsulated (Table 3). This SBC-compliant building is the main case of the study. To quantify the value of the code, the same building is also simulated with the envelope of the existing, largely uninsulated stock: wall, roof and window U-values of 2.146, 2.123 and 5.778 W/m²K and an SHGC of 0.62, taken from the calibrated model of an existing Riyadh residence [37]. Nothing else is changed, so the difference isolates the envelope.

Analysis cases. The same building is analysed as three cases of increasing extent (Fig. 3). *Case 1* is one apartment, A of an intermediate storey, on its own (Fig. 3a). This is the unit that receives a household bill. Its walls and slabs shared with the other apartment, the core and the storeys above and below face conditioned space and are treated as adiabatic. *Case 2* is the typical floor (Fig. 3b): both apartments side by side and the core, with the heat exchange between them. Its slabs remain adiabatic. *Case 3* is the whole building (Fig. 3c): four storeys of two apartments, with ground contact on the lowest storey, the roof above the highest, and heat exchange through every slab. The representative apartment is 2A, on the first storey above the ground, which is neither in contact with the ground nor under the roof. Each case is run in both cities, for both envelopes (SBC-compliant and pre-code, Section 4.3), over the whole TMYx year, so both summer cooling and winter heating are simulated.

Table 2: Air-conditioner catalogue and the rooms each unit serves. All units are split heat pumps for heating and cooling. The 1.5- to 2.5-ton units are inverter units with four operating modes (off, low, medium, high; capacity fractions 0, 0.35, 0.65 and 1); the 3-ton unit has a fixed-speed rotary compressor and runs on/off at full capacity. Heating capacity: 1.14 times the cooling capacity (assumed). The stair (38.5 m^2) lies just above the rated coverage of its unit, and the dining area (11.0 m^2) below that of the smallest unit.

Unit	Cooling / heating capacity	Rated coverage	Rooms served
1.5 ton	5.28 / 6.0 kW	16–18 m^2	Bed 2, Bed 3, kitchen, dining area
2.0 ton	7.03 / 8.0 kW	19–22 m^2	none (no room of the plan falls in this range)
2.5 ton	8.79 / 10.0 kW	22–30 m^2	master bedroom, living room
3.0 ton	10.55 / 12.0 kW	30–36 m^2	guest room, stair




Figure 3: The building analysed in the three cases (drawings generated as layered DXF files; clear dimensions in metres). (a) Apartment A, analysed alone in Case 1. (b) The typical floor: two mirror-image apartments around the common stair; north is up. (c) South elevation (top) and section A–A through the stair (bottom) of the four-storey building (floor-to-floor height 3.40 m, 3.00 m clear; windows from 0.90 to 2.40 m above each floor). The zone rectangles of the model follow the wall centrelines of (b).

5 Model and Problem Formulation

This section turns the building of Section 4 into a formal model and states the optimisation problem. It uses the multi-mode formalism of Alur et al. [14], Wojtczak [15] and Mousa et al. [12] and the coupled-zone model of Nghiem et al. [17]; only the parts the theory needs are stated here, and the full formal definitions (zone network, multi-mode system, timed actions, schedules, runs and their costs, schedulability) with the continuations of the running example are in Appendix F.

5.1 Modelling assumptions

The theory of Section 6 rests on five assumptions, of which the simulation relaxes the first three. **(A1)** Each zone is well mixed; the theory reads it as one lumped temperature V_i , the simulation as two nodes, air and structure (Section 5.3). **(A2)** The COP is quasi-static, a function of mode and ambient temperature (Eq. 1) with no cycling loss; the simulation adds its dependence on the indoor air, cycling losses, standby power and capacity derating (Section 5.4). **(A3)** Within one leap cycle the heat gain L and the ambient temperature are constant. This holds only roughly for a lightly loaded room,

whose cycle can last hours (about 4.580 h for the running example), so applying the cycle results hour by hour is an approximation; the simulation does not use **(A3)**. **(A4)** Every apartment is occupied and every room is occupied and conditioned at all hours, with every conditioned zone following the same policy, so adjacent conditioned zones operate at the same level; the conclusions inherit this idealisation (Section 10.4). **(A5)** Building properties that are uncertain in practice (window sizes and U-values, solar absorptance, internal gains, interior doors all open) are held at the values of the drawing and of Table 3; they are varied in Section 9.7.

5.2 Zones, units and the multi-mode system

The building is a finite set of zones $\mathcal{Z} = \{1, \dots, N\}$ (rooms). The *conditioned* zones $\mathcal{Z}_c$ each have their own unit; the *passive* zones $\mathcal{Z}_u$ (baths, maid room, lobby, corridor and hall) have none. Zone i has a thermal capacitance C_i and a temperature $V_i(t)$; adjacent zones $i \neq j$, sharing a partition or slab, are coupled by the conductance $K_{ij} = K_{ji}$ (U-value times area, zero otherwise), and each zone exchanges heat with the outdoors through K_i^{env} (infiltration alone for interior zones).

Each conditioned zone is served by a split heat-pump unit with four modes $M = \{0, 1, 2, 3\}$ (off, low, medium, high; a fixed-speed unit has only 0 and 3). In mode m it removes heat at the rate $f_m \psi(T_a) Q_i$ when cooling and adds $f_m Q_i^h$ when heating, where Q_i is its rated cooling capacity, $\psi(T_a) = [1 - 0.01(T_a - 35)]_{0.8}^{1.1}$ derates it with the outdoor temperature, $Q_i^h = 1.14 Q_i$, and $0 = f_0 < f_1 < f_2 < f_3 = 1$ are the capacity fractions (0.35, 0.65, 1). It draws $f_m \psi Q_i / \text{COP}_m$ when cooling and $f_m Q_i^h / \text{COP}_m$ when heating, with

$$\text{COP}_m^{\text{cool}}(T_a, V_i) = c_m \varphi(T_a) g(V_i), \quad \text{COP}_m^{\text{heat}} = h_m, \quad (1a)$$

$$\varphi(T_a) = [1 - 0.02(T_a - 27)]_{0.60}^{1.15}, \quad (1b)$$

$$g(V_i) = [1 - \gamma(27 - V_i)]_{0.8}^{1.1}, \quad \gamma = 0.02 \text{ K}^{-1}, \quad (1c)$$

where $[x]_a^b = \min\{b, \max\{a, x\}\}$, $c_1 = 5.81 > c_2 = 4.98 > c_3 = 4.01$ and $h_1 = 4.6 > h_2 = 4.0 > h_3 = 3.2$: a unit is most efficient at low output. The cooling coefficients are anchored to the Saudi efficiency minimum (Section 4.3); φ lowers the COP as the outdoor air warms and g as the room's air falls below the 27 °C rating condition ($g = 0.93$ at 23.5 °C; γ is assumed and varied in Section 9.7). The building is then a multi-mode system [12] with one mode per unit, the heat balance of Eq. (2) as rate function, a cost $\pi_i(m)$ per unit time for each unit and mode, the safe set $\mathcal{S} = [V_{\min}, V_{\max}]$ and an initial state V_0 .

5.3 Thermal dynamics: inter-zone coupling and latent load

Following Nghiem et al. [17] and the two-node simplification of ISO 13790 [51], each zone has an air node V_i , which the thermostat senses and the unit acts on, and a structure node W_i , the inner layers of its walls and slabs:

$$C_i^a \dot{V}_i = K_i^w(T_a - V_i) + K_i^{\text{am}}(W_i - V_i) + \sum_{j \in \mathcal{D}_i} q_{ji} + (1 - f_r)G_i - S_i^{\text{sky}} - s_i \beta_i f_{u_i} \hat{Q}_i, \quad (2a)$$

$$C_i^m \dot{W}_i = q_i^{\text{env}} + \sum_{j \neq i} K_{ij}(W_j - W_i) + K_i^{\text{am}}(V_i - W_i) + S_i^w + f_r G_i, \quad (2b)$$

$$q_i^{\text{env}} = K_i^o(T_a - W_i) + S_i^o + K_i^{\text{grd}}(T_g - W_i). \quad (2c)$$

Here K_i^w covers windows and infiltration ($n_{\text{ach}} = 0.4$ air changes per hour, ACH), K_i^{am} joins air and structure, $\mathcal{D}_i$ are the rooms joined by an open door (Eq. (3)), G_i are the internal gains with radiant share f_r , S_i^{sky} is the long-wave loss of the windows, S_i^w the window solar gain (SHGC with angle-dependent transmission [52]), and S_i^o the sol-air excess of walls and roof, net of the sky loss $\varepsilon F_{\text{sky}}(\sigma T_a^4 - I_{\text{IR}})$ with the measured infrared radiation I_{IR} , $\varepsilon = 0.9$ and $F_{\text{sky}} = 1$ (roof) or 0.5 (walls, windows) [51]. T_a and T_g are the ambient and ground temperatures ($K_i^{\text{grd}} \neq 0$ on the ground storey only), $u_i(t) \in M$ is the unit's mode ($u_i \equiv 0$ in passive zones), $s_i = \pm 1$ for cooling or heating, $\beta_i \in [0, 1]$ the fraction of the step the unit runs, and $\hat{Q}_i$ is $\psi(T_a) Q_i$ in cooling and Q_i^h in heating. Apart from the door exchange the rates are affine in the temperatures, so the building is close to a linear-rate multi-mode system [15].

Through a door of width W_d and height H_d , buoyancy carries the heat [53]

$$q_{ji} = \rho c_p \frac{C_{\text{dis}}}{3} W_d \sqrt{\frac{g H_d^3}{T}} (V_j - V_i) |V_j - V_i|^{1/2} \quad (3)$$

from room j into room i ($C_{\text{dis}} = 0.6$, $\bar{T} = 297 \text{ K}$); at 1 K a 0.90 m door carries about 110 W, several times more than a partition wall. We call the exchange through walls, slabs and doors the *thermal shift* between rooms; because $K_{ij} = K_{ji}$ and $q_{ji} = -q_{ij}$, it moves heat between rooms without creating or removing it.

Humid infiltration air imposes a latent load on each conditioned zone whenever the outdoor humidity ratio ω_a exceeds the indoor target $\omega^* = 9.6 \text{ g/kg}$ (55% relative humidity at 23 °C, below 60% anywhere in the band, and independent of the setpoint):

$$L_i^{\text{lat}} = \frac{n_{\text{ach}}}{3600} \rho \text{Vol}_i \max(\omega_a - \omega^*, 0) h_{fg}, \quad (4)$$

with the zone's air volume Vol_i and the latent heat h_{fg} . The target is assumed met, the latent electricity is priced at a fixed latent COP, internal moisture is omitted and passive zones are not dehumidified; these assumptions are tested in Section 9.7.

5.4 Parameters and their provenance

Every parameter is fixed a priori from the code, the product catalogue, the floor plan, the measured weather, cited statistics or a stated nominal value (Table 3); none is fitted to the quantities against which the model is later checked. Each conductance is a U-value times an area from the plan (storey height 3.40 m, clear height 3.00 m), and capacitance, internal gains and latent air mass scale with floor area. The capacitance, 270 kJ/(m²K) of floor, lies at the heavy-class default of ISO 13790 (260) [51], whose reduced-order room model remains the usual choice at this scale although the standard has been superseded by ISO 52016-1; 5% of it sits on the air node (our choice, since the standard's air node is massless), the air-structure coupling is the ISO surface coefficients in series, and half of the internal gains are radiant. Internal gains average 5.4 W/m² with an afternoon peak, derived from the Saudi end-use split [1], raised in the kitchen and reduced in baths and circulation. The ground slab follows ISO 13370 [54] against the monthly ground temperature of the weather file. Each unit draws 3 W on standby, and its hourly electricity is divided by the part-load factor $\text{PLF} = 1 - C_d(1 - \text{RTF})$, where RTF is the fraction of the hour it runs, with $C_d = 0.25$ for the fixed-speed units, the rating default for single-speed equipment [55], and an assumed $C_d = 0.15$ for the inverter units, which cycle at or below their minimum speed (both varied in the sensitivity and uncertainty analyses, Section 9.7). The rated COPs include the indoor fan, which runs only with the compressor.

5.5 Leap cycles, levels and the comfort frontier

A unit's operation is a *schedule* of *timed actions* (m, t) , each keeping the unit in mode m for a time t ; it is *safe* if its run, the sequence of states it produces from the initial state, stays in $\mathcal{S}$, and its cost is the energy price times its long-run mean

Table 3: Parameters and their provenance. Compliant envelope: Saudi residential requirements for climate Zone 1 [1, 35, 50]; pre-code: calibrated model of an existing Saudi residential building [37]. Each conductance is $K = UA/1000$ [kW/K] with A from the floor plan.

Quantity	SBC	Pre-code	Source / justification
Wall / roof / window U [W/m ² K]	0.34 / 0.20 / 2.67	2.146 / 2.123 / 5.778	SBC Zone 1 [1]; existing stock [37]
Glazing SHGC	0.25	0.62	SBC Zone 1 [1]; existing stock [37]
Exterior wall incl. 17.3% glazing [W/m ² K]	0.74	2.78	derived (area-weighted, building mean)
Partition / slab U [W/m ² K]		1.728 / 2.047	existing stock [37]
Ground slab U [W/m ² K]; ground temperature		0.40; monthly, 2 m	ISO 13370 [54], uninsulated slab; TMYx ground record
Capacitance C [kWh/K per 20 m ²]		1.5 (270 kJ/m ² K)	heavy class of ISO 13790 [51]; block/concrete construction
Air-node share of C ; air-structure coupling		5%; 9.9 W/m ² K of floor	ISO 13790 two-node simplification, heavy class [51]
Infiltration n_{ach} [ACH]		0.4	nominal, new construction (stock: 0.8 [1]); sensible and latent
Interior doors / openings $W_d \times H_d$ [m]; C_{dis}	0.70–0.90 $\times$ 2.032 / 2.20–5.00 $\times$ 3.00; 0.6		drawing; height SBC 201 [47]; Brown and Solvason [53]
Internal gains [W/m ²]: continuous + daytime half-sine; mean	3.5 + 0–6.0 (08:00–20:00, peak 14:00); 5.4		end-use split [1]; times a room factor of 0–1.5 by use, assumed (Appendix E)
Opaque solar absorptance		0.7	nominal (idealised, A5)
Exterior film / ground reflectance		17 W/m ² K / 0.2	nominal (sol-air temperature and diffuse gains)
Sky long-wave: ϵ ; F_{sky} roof / walls, windows		0.9; 1 / 0.5	ISO 13790 [51]; hourly infrared radiation of the TMYx file
Window solar		angle-dependent	normalised SHGC curve of double glazing [52]
Unit sizes [ton]		1.5 / 2.0 / 2.5 / 3.0	catalogue, by coverage (Table 2)
Mode capacity fractions $f_1/f_2/f_3$		0.35 / 0.65 / 1.0	inverter units (Eq. (1)); fixed-speed: f_3 only
Cycling degradation C_d : inverter / fixed-speed		0.15 / 0.25	part-load factor per hour; inverter assumed, fixed-speed Air-Conditioning, Heating, and Refrigeration Institute [55]
Standby power; capacity derating	3 W per unit; $\pm 1\%/K$ about 35 °C, [0.8, 1.1]		nominal
Restart delay; mode escalation	3 min; 0.4/1.0 K, full if lagging		anti-short-cycle timer; nominal
Thermostat differential; setpoint step		1.0 K; 0.5 K	typical room thermostat; state updated every 3 min
Cooling COP (modes 1/2/3)		5.81/4.98/4.01 $\times \varphi(T_a) g(V)$	SASO 2663 minimum at full load [48]; ratios and γ assumed, Eq. (1)
Heating COP (modes 1/2/3)		4.6 / 4.0 / 3.2	nominal heat-pump values
Heating / cooling capacity Q_i^h/Q_i		1.14	nominal inverter heat pump (6.0 vs 5.28 kW at 1.5 t)
Latent (dehumidification) COP, COP_{lat}		3.4	nominal, all modes (Eq. (4))
Reference setpoints: cooling / heating [°C]		23.5 / 22.5	ceiling and band floor $\mp$ half the differential
Indoor humidity target ω^*		9.6 g/kg	55% RH at 23 °C; within the 12 g/kg applicability limit of the ASHRAE 55 graphic method [44]
Weather		TMYx hourly	measured (Fig. 2; Appendix E)

electrical power J_∞ [11, 12, 14]. The theory needs one kind of schedule (Fig. 4).

Definition 1 (Leap cycle, level, schedulability and comfort frontier). Let a conditioned zone in the cooling season have heat gain $L(V)$, the net heat entering it per unit time with its unit off. A *leap cycle* of amplitude $\Delta > 0$ under a top temperature $V^\top$ is a drift $(0, t_{off})$ from $V^\top - \Delta$ up to $V^\top$ followed by a cooling leap (m, t_{on}) back down; repeated for ever, it is an infinite schedule. Its *level* $\bar{V}$ is its time-mean temperature, about $V^\top - \Delta/2$. The zone is *schedulable* in mode m if $f_m \psi Q_i > L(\bar{V})$, so that the mode can bring it back; this is the zero-sum dwell-time condition of Alur et al. [14] for one zone, with *duty* $d_m = L/(f_m \psi Q_i) < 1$

and utilisation $U_i = L/Q_i$. The *comfort frontier* $\bar{V}^*$ is the highest level whose cycle stays at or below V_{high} . In the heating season drift and leap exchange roles.

Running example. Bed 2 of the representative apartment 2A (Section 4.3, Fig. 3a), 18 m² on the north side next to the party wall, has one exterior wall and a 1.5-ton unit ($Q = 5.28$ kW). With the SBC envelope, $C = 1.33$ kWh/K and $K^{env} = 19.0$ W/K (wall and window 11.8, infiltration 7.1), while its six neighbours are coupled to it by 138 W/K, about 7 times its envelope conductance. In mean July conditions in Riyadh ($T_a = 36.4$ °C), read as one lumped room at a level of 23.5 °C, it gains $L = 0.363$ kW (conduction and infiltration 0.245, internal gains 0.096, solar minus sky loss 0.022; the




Figure 4: Leap cycles (schematic). The comfort band $[V_{\text{low}}, V_{\text{high}}]$ lies inside the safe set $[V_{\text{min}}, V_{\text{max}}]$ with a hard ceiling, $V_{\text{high}} = V_{\text{max}}$. The labels $V_0, \dots, V_5$ are successive states of one zone’s run, starting from the initial state V_0 , the thermostat’s lower switching point: drifts $(0, t_{\text{off}})$ (red) and cooling leaps (m, t_{on}) (blue) form a leap cycle of amplitude Δ under the ceiling. Pre-cooling lowers the setpoint by δ (dashed), at most to the floor V_{min} .

conditioned neighbours, at the same level, add no net heat). Unit off it warms at 0.27 K/h; mode 1 removes 1.82 kW and cools it at 1.10 K/h, with duty $d_1 = 0.20$. For the 1 K differential one leap cycle is $\langle (0, 220 \text{ min}), (1, 55 \text{ min}) \rangle$.

5.6 The Saudi two-tier tariff

The electrical power of unit i is $P_i(t) = f_{u_i(t)} \hat{Q}_i / \text{COP}_{u_i(t)}$ (Eq. (1)) plus its latent share. A metering map μ assigns every unit to the meter that bills it, one per apartment and one common meter for the stair, and meter r uses $E_{r,k} = \int_{\text{month } k} \sum_{i:\mu(i)=r} P_i(t) dt$ in month k . The residential tariff, set by the Saudi Electricity Regulatory Authority and billed by the Saudi Electricity Company, is a two-tier *volume* tariff applied to each meter separately [7]:

$$\Pi^{\text{vol}} = 1.15 \sum_{r=1}^R \sum_{k=1}^{12} b(E_{r,k}), \quad (5a)$$

$$b(E) = 0.18 \min(E, 6000) + 0.30 (E - 6000)^+, \quad (5b)$$

in SAR a year, where $(x)^+ = \max(x, 0)$ and 1.15 adds the 15% value-added tax. The tariff prices energy alone: it has no time-of-use component, no demand charge and, unlike the multi-mode costs of Mousa et al. [12], no charge per switch; the energy a unit loses by cycling is counted through the part-load factor. Fixed meter charges are excluded. For a meter in tier 1, as every meter of the SBC-compliant building is (Section 9.1), the price is $\lambda = 0.207$ SAR/kWh (US\$0.055 at the pegged rate of SAR 3.75 per US\$, used throughout), the cost of unit i in mode m is $\pi_i(m) = \lambda f_m \psi(T_a) Q_i / \text{COP}_m(T_a)$, and the bill is the sum of the costs of the units’ schedules.

Running example (continued). Apartment 2A of the SBC-compliant building in Riyadh (Case 3) uses 5,527 kWh of

HVAC electricity a year at the reference setpoints, never more than 935 kWh in a month, so even if HVAC were only a third of its use the meter would stay in tier 1. Its HVAC bill is $5,527 \times 0.207 \approx 1,144$ SAR, and any policy’s bill is proportional to its energy.

5.7 Controller

Rather than choosing every unit’s timed actions directly, a combinatorial problem over $|M|^{|Z_c|}$ mode vectors per step, every unit applies one compact *policy* $\theta = (V^{\text{cool}}, V^{\text{heat}}, \delta_{\text{night}}, \delta_{\text{peak}})$ to its zone: cooling and heating setpoints and the depth pair $\delta = (\delta_{\text{night}}, \delta_{\text{peak}})$ by which the cooling setpoint is lowered from 22:00 to 06:00 (night pre-cooling) and from 10:00 to 13:00 (pre-peak pre-cooling). Setpoints and depths move in 0.5 K steps. Each unit is an on/off thermostat with a 1 K differential centred on its active setpoint (in cooling: on at the setpoint plus 0.5 K, off at the setpoint minus 0.5 K), the switching instant resolved within the 3-minute step and at most one change of state per step, which also gives the usual 3-minute restart delay. While on, an inverter unit chooses its mode from the rise its room’s air would make within the step without cooling: low, medium if that rise would reach 0.4 K above the switch-on point, high if 1.0 K, and full capacity if its room is still above the switch-on point at the start of a step; a fixed-speed unit runs at full capacity. Heating works in the same way about the heating setpoint.

The units follow the usual seasonal changeover. In months whose mean air temperature is below the band floor V_{low} (November to March in Riyadh; none in Jeddah) they heat and cool automatically, with the active heating setpoint at least 1 K below the active cooling setpoint. In the other months they cool, and heat only as a *floor guard*: a low-limit heating setpoint of 21 °C (on at 20.5, off at 21.5 °C), capped at 1 K below the active cooling setpoint. Pre-cooling acts only in cooling mode, with depths capped so that the cooling setpoint never falls below $V_{\text{min}} + 0.5$ K; the controller therefore never cools a room below V_{min} . At the reference and the ordinary policies the guard holds the floor: without it, rooms of the uninsulated pre-code building fall below V_{min} (0.12 K·h a year in Riyadh; 41 K·h and down to 18.2 °C in Jeddah); it never acts in the SBC-compliant building at the reference policy. During deep night pre-cooling (cooling setpoint 20.5–21.5 °C), however, the cap moves the guard’s switch-on point below 20.5 °C, and a room can still drift below 20 °C on a cool night, as some deep night pre-cooling policies of the pre-code building in Jeddah do, while other pre-cooling policies of the pre-code building, in both cities, let a room pass the ceiling; all such policies are inadmissible and excluded. Each unit needs only its own zone temperature and the clock, and the policy induces for every unit an infinite schedule of leap cycles. With $\delta = (0, 0)$ the controller is an ordinary thermostat.

5.8 The optimisation problem, feasibility and admissibility

The problem, in the form of Mousa et al. [12], is to choose the policy that minimises the annual bill:

$$\begin{aligned} \min_{\theta} \quad & \Pi(\theta) = \Pi^{\text{vol}}(\{E_{r,k}(\theta)\}) \\ \text{s.t.} \quad & \text{(C1) Eqs. (2)–(4) hold } \forall i \in \mathcal{Z}, \\ & \text{(C2) } V_i(t) \leq V_{\text{high}} = 24^\circ\text{C } \forall i \in \mathcal{Z}_c, \\ & \text{(C3) } V_i(t) \geq V_{\text{min}} = 20^\circ\text{C } \forall i \in \mathcal{Z}_c, \\ & \text{(C4) } u_i(t) \in M \forall i \in \mathcal{Z}_c; \quad u_i \equiv 0 \forall i \in \mathcal{Z}_u, \end{aligned} \quad (6)$$

for all times t . (C2) is the comfort ceiling, (C3) the safe floor and (C4) the finite modes.

Admissibility. The safe set $[V_{\text{min}}, V_{\text{high}}] = [20, 24]^\circ\text{C}$ is hard for every policy, at its ceiling and at its floor. A policy is *admissible* if every conditioned zone stays within it at every step of the simulated year: the excursions above the ceiling, $\sum_i \int \max(V_i - V_{\text{high}}, 0) dt$, and below the floor, $\sum_i \int \max(V_{\text{min}} - V_i, 0) dt$, must both be zero up to floating-point round-off; every other policy is excluded, and problem (6) asks for the cheapest admissible policy. The band floor $V_{\text{low}} = 22^\circ\text{C}$ is the comfort target rather than a constraint: in the heating months it is held by the heating setpoint, $V^{\text{heat}} = 22.5^\circ\text{C}$ (the band floor plus half the differential), and in the cooling months by the building’s own gains, while pre-cooling may use $[V_{\text{min}}, V_{\text{low}})$, an allowance that can only favour scheduling.

Feasibility. Each conditioned zone is a *task* demanding cooling at the rate of its heat gain $L_i(t)$ [14, 18]; each unit serves one zone and no power budget is shared, so schedulability (Definition 1) applies zone by zone. A zone is *feasible* if its unit has the hourly capacity to hold it at the ceiling whatever the weather; a sufficient condition is

$$\max_t L_i(t) < \psi(T_a) Q_i \quad \text{at } V_i = V_{\text{high}}, \quad (7)$$

(not necessary, since the capacitance can carry a zone through a short peak). A building is feasible if every conditioned zone is. Feasibility is a property of the envelope and the unit sizes; admissibility is a property of a policy’s simulated run. An infeasible building saturates on the hottest afternoons and has no admissible policy, and the instance is reported as infeasible; a feasible building can still have no admissible policy at a given setpoint, when the controller’s escalation lag lets a room pass the ceiling within a step (Section 9.5). Section 9.1 evaluates both.

6 Theoretical Results

This section states what the structure of problem (6) implies before any computation. The results are energy accounting adapted to multi-mode units under a hard comfort ceiling, in the spirit of the storage-efficiency accounting of the energy-flexibility literature [9, 10]: they follow from the conservation of energy and the ordering of the mode efficiencies, and they reduce the computation of Section 7 to checking the conditions they state. The proofs read a zone as one lumped node

with constant rates over a cycle (A1–A3); the simulation does not (two nodes, nonlinear door flows, a COP that follows the outdoor and indoor air hour by hour, cycling with a differential, a restart delay and cycling losses), so Section 9 tests the theory beyond the conditions under which it is proved. Proofs are in Appendix B.

6.1 The thermal shift between rooms

Coupled neighbours. Under (A4) the net heat a conditioned zone exchanges with its conditioned neighbours vanishes in the mean, up to the difference in their thermostat cycles, whatever the coupling conductances: the exchange $K_{ij}(V_j - V_i)$ has zero mean when both zones are held at a common level. The thermal shift therefore changes a zone’s load only through neighbours at a different temperature: passive zones, the roof, the ground and the outdoors.

Passive zones. Averaging the heat balance of a passive zone over a month, over which its stored heat changes negligibly, gives its heat budget (Appendix F): in the cooling season a passive zone with any exposure or gain is warmer than the conditioned rooms that take its heat; its temperature depends on the temperatures the units hold, not on their capacity; and it stays the closer to their setpoint, the more of its heat it sheds to them through walls or open doors. Section 9.1 and Appendix C test these statements.

6.2 The cheapest stationary operation of a room

Theorem 1 (Optimal leap and level). Under (A1)–(A4), let a conditioned zone run a periodic leap cycle in mode m at level $\bar{V}$ (Definition 1). Then

$$\bar{P}(\bar{V}, m) = \frac{L(\bar{V})}{\text{COP}_m(T_a)}. \quad (8)$$

(i) The amplitude Δ enters only through the level; for a cycle that reaches the ceiling, $\bar{V} = V_{\text{high}} - \Delta/2$ to first order. Hence a leap $(\bar{V}^*, m^*)$ is optimal if and only if $\bar{V}^*$ is the comfort frontier and $m^* = \min\{m : f_m \psi Q_i > L(\bar{V}^*)\}$ is the lowest mode that holds the room; for a thermostat whose differential Δ_{th} is centred on its setpoint, $\bar{V}^* = V_{\text{high}} - \Delta_{\text{th}}/2$, the highest admissible setpoint. (ii) If the ambient conditions are also constant over the horizon, every safe infinite schedule σ satisfies $J_\infty(\sigma) \geq L(V_{\text{high}})/\text{COP}_1(T_a)$ (with COP_1 replaced by that of the lowest mode that holds the room if mode 1 does not hold it at the ceiling), a bound approached by low-mode cycles of vanishing amplitude at the ceiling; with a given differential the optimal leap repeated for ever attains the least long-run power, so the optimal infinite-horizon control is stationary. With a diurnal swing of the COP this bound no longer holds, and Theorem 2 bounds what re-timing can gain instead.

The identity is exact because L is affine in V , so the mean gain over a cycle is the gain at the mean temperature. The indoor factor g of Eq. (1), which the theorem omits, makes a warmer level cheaper still and so strengthens part (i).

Corollary 1 (What a cycle costs). Under (A2), which has no cycling loss, and with no charge per switch (Section 5.6), the cost of a safe schedule depends only on the level at which it holds each zone and on the modes it uses: the number of cycles does not enter, and reassigning heat removal between units (“coordination”) lowers the cost only if it lets a unit use a lower mode. With cycling losses, $\bar{P} = L/(\text{COP}_m \text{ PLF})$ with $\text{PLF} = 1 - C_d(1 - L/f_m \psi Q_i)$, which also favours the lowest mode that holds the room, since it runs longest.

With the 1 K differential and 0.5 K steps of the modelled thermostats, Theorem 1 places the frontier at 23.5 °C, the reference setpoint; a finer thermostat would move it towards the ceiling (Section 9.1).

Running example (continued). For Bed 2 in July ($L = 0.363 \text{ kW}$ at 23.5 °C, $\varphi = 0.81$; evaluated without the indoor factor g , i.e. $\gamma = 0$, which narrows every difference below), Eq. (8) gives 0.077 kW in mode 1, 0.090 kW in mode 2 and 0.112 kW in mode 3: the same comfort costs 45% more in the highest mode, and $m^* = 1$. The cycle durations give the same value, $(1.82 \text{ kW} \times 0.913 \text{ h}/4.72)/4.580 \text{ h} = 0.077 \text{ kW}$. At the 22 °C of current practice the gain rises to 0.391 kW and the mean power to 0.083 kW. A cycle across the whole comfort band averages 23.01 °C and draws 2.6% more than the thermostat cycle; one across the whole safe set, as the deepest pre-cooling does, averages 22.05 °C and draws 7.7% more, although it switches far less often.

6.3 What re-timing can gain under a volume tariff

Under a tariff of monthly energy alone, the timing of the leaps within a month affects the cost only through the heat removed and the mean efficiency at which it is removed (Eq. (5)). Pre-cooling trades these two terms.

Theorem 2 (Pre-cooling bound). Let a conditioned zone be pre-cooled by $\delta > 0$ in the cooling season, removing the extra stored heat $C_i \delta$ in a window at a mean COP COP_w and displacing removal that would otherwise occur at a mean COP no lower than COP_p , and let $\Delta H \geq 0$ be the extra heat the colder zone admits. Under a hard comfort ceiling the change in electrical energy satisfies

$$\Delta E \geq C_i \delta (\eta_w - \eta_p) + \Delta H \min(\eta_w, \eta_p), \quad (9)$$

with $\eta_w = 1/\text{COP}_w$ and $\eta_p = 1/\text{COP}_p$. Pre-cooling cannot save if it is done less efficiently than the removal it displaces; otherwise it saves at most $C_i \delta (\eta_p - \eta_w)$, and nothing when the fraction of stored coolth lost as extra heat, $\Delta H/(C_i \delta)$, is at least the relative COP gain $\text{COP}_w/\text{COP}_p - 1$.

Theorem 3 (Optimal level and conditional optimality of no pre-cooling). Under (A1)–(A5), let the tariff be any non-decreasing function of the meter energies alone (the Saudi two-tier tariff, a linear or any tiered price). (i) Among the policies of problem (6) without pre-cooling, the cheapest is the frontier policy $(\bar{V}^*, V^{\text{heat}}, 0, 0)$, with every unit at the comfort frontier. (ii) A pre-cooling policy costs at least as much as the frontier policy wherever its pre-cooling satisfies the no-gain condition of Theorem 2, strictly so if the tariff is strictly increasing; elsewhere its saving is at most the bound

of Theorem 2. Tariffs that weight energy by the time of use or by a coincident peak lie outside the theorem; neither applies to Saudi households.

Part (ii) is an accounting statement, not a prediction: it excludes a saving where pre-cooling admits more heat than it gains in efficiency and bounds it elsewhere, so whether a saving exists is decided by measuring the two terms. The condition fails mainly when pre-cooling stays in the lowest mode at an hour whose COP is well above the afternoon COP. For the whole building in July, ignoring the extra heat, the bound for a 2 K pre-cool is 3.8% of the day’s HVAC electricity in the night window, 4.7% in the four coolest hours around dawn (04:00–08:00) and 0.8% before the peak in Riyadh, and 2.4, 3.0 and -0.3% in Jeddah. Section 9.3 measures the two terms for the thermostat, and Section 9.3 computes, with perfect foresight, how much of the bound an idealised schedule attains.

6.4 Where the savings come from

Proposition 1 (Sources of saving). Under (A1)–(A5) and a tariff of Theorem 3, the annual HVAC energy is $E = \sum_{i \in \mathcal{Z}_c} \int L_i(t)/\text{COP}_{u_i(t)}(T_a) dt$ plus the latent and standby loads, and the bill is non-decreasing in E . A policy therefore saves only if it (a) lowers the heat to be removed, $\sum_i \int L_i dt$, or (b) removes it at a higher COP. A warmer level and a better envelope do (a); a lower mode does (b); with cycling losses, (c) a higher part-load factor, from longer runs in the lowest mode that holds the room, is a third source (Corollary 1). Moving heat removal in time can raise (b) only through the ambient swing of φ , lowers it through g because the room is colder, and raises the heat in (a); Theorem 2 bounds the net effect.

7 Experimental Setup

This section sets out how the results of Sections 8 and 9 are obtained: baselines and test instances, policy evaluation and the single optimisation method, selection and full-year re-evaluation, and the experiments.

7.1 Baselines and test instances

Every saving is measured against a stated baseline, with everything else held equal:

- (B1) *current practice*: cooling at 22 °C and heating at 20.5 °C without scheduling, the baseline of the setpoint lever. In a survey of Jeddah households 45% preferred 22–24 °C and about 43% 21 °C or less [38], so 22 °C is representative rather than extreme. Its cycle takes rooms below the band floor in summer and lets them cool to 20 °C in winter, so it is a practice reference, not a policy that meets the band. The setpoint lever therefore moves the cooling setpoint from 22 to 23.5 °C and the heating setpoint from 20.5 to 22.5 °C; the ablation of Section 9.4 changes the cooling setpoint alone;
- (B2) *the reference policy*: cooling at 23.5 °C and heating at 22.5 °C without scheduling, whose 1 K cycle just fills the band; the baseline of every scheduling feature;

- (B3) the *pre-code envelope* at the reference policy, the baseline of the envelope lever;
- (B4) each scheduling feature switched on alone, for the decomposition by lever;
- (B5) *isolated rooms*, with no walls, slabs or doors between them, the baseline of the thermal shift;
- (B6) *EnergyPlus* 26.1 on the same inputs, the external benchmark (Section 8.2).

For the timing lever, the perfect-foresight benchmark (Section 7.2) gives what an idealised schedule could achieve beyond the thermostat policies.

Test instances. The problem is tested on instances of two kinds, both for the whole building (Case 3). An instance is *normal* if every unit holds the ceiling with capacity to spare, its peak hourly sensible load staying below 85% of its rated capacity, and *hard* otherwise, or if the reference policy is not admissible (Section 5.8). The instances cross the two envelopes and the two cities with two weather years: the TMYx year, and a heat-wave year with the measured air temperature raised by 3 K in every hour (humidity, radiation and ground unchanged; the seasonal changeover follows the warmer months, so Riyadh’s heating season shrinks to December–February). Four further instances (TMYx year) replace the catalogue units by units sized to each building’s own peak hourly sensible load with a 15% margin. In each of the twelve instances the thermostat policies are compared as described below.

7.2 Policy evaluation and optimisation

The thermostat policies a household can choose are evaluated by annual simulation and compared, not optimised; the theory of Section 6 locates their optimum beforehand. The study uses one optimisation method, the perfect-foresight optimal control of Algorithm 2, which computes the least-cost schedule of every unit for an idealised, linear form of the problem. Algorithm 1 evaluates a policy: it integrates the coupled sensible dynamics and the latent load over five days per month sampled evenly from the TMYx year (3-minute steps, monthly energies scaled), starting from 23 °C in January and carrying the state from one sampled day to the next, accrues cost per meter through the tariff and records the excursions that decide admissibility. Many policies are evaluated in one vectorised run.

Thermostat policies. The setpoints are fixed at the reference values and the pre-cooling windows at 22:00–06:00 and 10:00–13:00, and every unit applies the same depth pair $\delta = (\delta_{\text{night}}, \delta_{\text{peak}})$. Because the thermostat moves in 0.5 K steps, the realisable pairs form the lattice $\Theta = \{0, 0.5, \dots, 3\}^2$ K of 49 settings, 48 pre-cooling pairs and $\delta = (0, 0)$, no pre-cooling; the rest of the paper refers to this lattice. All 49 settings are evaluated by Algorithm 1 in one vectorised run, only the admissible ones are kept, and the cheapest of them wins (none, if no setting is admissible). This exhaustive comparison is exact, deterministic and free of tuning parameters, so a search heuristic would add nothing at this size. The setpoint is not part of it: by Theorem 1 its optimum is the

comfort frontier, found by the sweep of Section 7.4. The *selected policy* θ^* combines the frontier setpoint with the winning depth pair. Per-room depths and other windows are not compared, apart from the top-floor and west-room subsets of Appendix H; because this class could hide a better schedule, the optimisation is posed over every schedule.

Optimisation: perfect-foresight optimal control. To find what *any* schedule could save, an idealised form of problem (6) is posed on design days as the linear program

$$\begin{aligned} \min_{q,x} \quad & \sum_t \Delta t \sum_{i \in \mathcal{Z}_c} P_i(q_{it}, T_a(t)) / g_{it} \\ \text{s.t.} \quad & \mathbf{C} \frac{x_t - x_{t-1}}{\Delta t} = b_t - \mathbf{G}x_t - \mathbf{B}q_t, \quad x_0 = x_T, \\ & v_{\min} \leq V_{it} \leq V_{\text{high}}, \quad 0 \leq q_{it} \leq \psi(T_a)Q_i, \end{aligned} \quad (10)$$

over the heat removal q_{it} of every unit and the air and structure temperatures $x_t = (V_t, W_t)$ of every zone, with the weather known in advance (Algorithm 2). $\mathbf{G}$, $\mathbf{C}$, b and $\mathbf{B}$ are the conductances, capacitances, drives and unit inputs of Eq. (2); P_i , the convex hull of the four modes, is piecewise linear with slopes rising with the mode; and g_{it} is the indoor COP factor of Eq. (1). The program may run any mode at any time, pre-cool any room down to $v_{\min}$ (22 °C, the band floor, or 20 °C, the floor of the safe set) at the hours of highest COP, and coordinate the rooms. Its units, like those of the reference that holds the ceiling, modulate continuously, without cycling losses, standby or a differential, so a gain from bunching run-time to cut cycling losses is not represented (the simulated thermostat policies include it). The schedule-independent latent load is excluded. With $\gamma = 0$ the gap is a rigorous upper bound on the saving that any schedule of the idealised model can achieve at any $\gamma \geq 0$: since $g(V) \leq g(V_{\text{high}})$ for $V \leq V_{\text{high}}$ and the reference holds V_{high} , scaling the cost by $1/g$ raises every schedule’s electricity at least as much as the reference’s. With $\gamma = 0.02$ the program is not linear. It is searched by sequential linear programming: from two starts (the program re-solved with g at its previous solution, and a schedule without pre-cooling), the cost is linearised about the incumbent schedule in both q and V , a step is taken within a trust region on V , and the step is kept only if the schedule, priced exactly with its own indoor factor, is cheaper; the region widens after a kept step and shrinks otherwise, for at most eight steps from each start. Every schedule kept is one the idealised units can follow, so the best one found gives an achievable saving. On every periodic horizon solved the optimal saving at $\gamma = 0.02$ lies between that achievable saving, which is at least zero (the reference itself) and, down to 20 °C, at least the saving of the schedule found within the band, and the $\gamma = 0$ bound. Case 1 is solved for the mean day of every month from May to September, the hottest July day and the 31 days of July as one horizon (heat may be stored across days), and Case 2, which adds the coordination between apartments and the core, for the mean and hottest July day and the mean August day. The top floor under the roof is solved as the typical floor with the roof above it and an adiabatic slab below, for the same design days. The whole building (Case 3, 264 nodes) is solved for the same days, for the bound ($\gamma = 0$) only: the interior-point solver used elsewhere (HiGHS [56]) is very slow on its program, so the Clarabel interior-point solver [57] is used for it and for the

Algorithm 1: EVALUATEPOLICY($\theta, \mathcal{D}, \Delta t$) for a given case, city, envelope and tariff

Input: policy $\theta = (V^{\text{cool}}, V^{\text{heat}}, \delta_{\text{night}}, \delta_{\text{peak}})$; case (zones $\mathcal{Z}$, meters r); climate; envelope; tariff; sampled days $\mathcal{D}$; step $\Delta t = 3 \text{ min}$

Output: annual bill Π (SAR), energy E (kWh), excursions above V_{high} and below V_{min} (K·h; admissible iff both are zero)

```
1 initialise  $V, W \leftarrow 23^\circ\text{C}$  in every zone; all units off;  $E_{r,k} \leftarrow 0$ ;  
2 for each hour  $h$  of the days in  $\mathcal{D}$  do  
3   set  $T_a, T_g, G, S^o, S^w, S^{\text{sky}}, \omega_a$  from the climate; add each unit's standby energy;  
4   if seasonal changeover: the month's mean  $T_a < V_{\text{low}}$  then  
5     automatic heating and cooling:  $V^c \leftarrow V^{\text{cool}}, V^h \leftarrow \min(V^{\text{heat}}, V^c - 1 \text{ K})$ ; no pre-cooling;  
6   else  
7      $V^c \leftarrow \max(V^{\text{cool}} - \delta_{\text{night}}\mathbb{1}_{22-06}(h) - \delta_{\text{peak}}\mathbb{1}_{10-13}(h), V_{\text{min}} + 0.5 \text{ K})$ ;  
8     floor guard:  $V^h \leftarrow \min(21^\circ\text{C}, V^c - 1 \text{ K})$ ;  
9   for each substep of length  $\Delta t$  do  
10    compute the door exchange (Eq. (3)) and the air temperature each zone would reach with its unit off;  
11    apply each thermostat's 1 K deadband: cooling on at  $V^c + 0.5 \text{ K}$  and off at  $V^c - 0.5 \text{ K}$ ; heating on at  
     $V^h - 0.5 \text{ K}$  and off at  $V^h + 0.5 \text{ K}$ ; resolve the switching instant  $\beta_i \Delta t$  within the step, at most one change of  
    state per unit and step (the 3-min restart delay);  
12    choose the mode from the rise the step would cause without the unit (inverter: low; medium from 0.4 K and  
    high from 1.0 K above the switch-on point; full capacity if a running unit's room starts the step above its  
    switch-on point; fixed-speed: full);  
13    update  $V$  (Eq. (2a)), then  $W$  (Eq. (2b)); accumulate electricity with the cooling COP  $c_m \varphi(T_a) g(V_i)$  or heating  
    COP  $h_m$  (Eq. (1)) and each unit's runtime; accrue the excursions of the conditioned zones above  $V_{\text{high}}$  and  
    below  $V_{\text{min}}$ ;  
14    divide each unit's energy of the hour by  $1 - C_d(1 - \text{RTF})$ ; add the latent energy  $\sum_i L_i^{\text{lat}} / \text{COP}_{\text{lat}}$  (Eq. (4));  
    accrue  $E_{r,k}$ , scaled from the sampled days to the month;  
15  $\Pi \leftarrow$  tariff over  $\{E_{r,k}\}$  (Eq. (5));  
16 return  $\Pi, E$ , excursions;
```

31-day horizon; on the typical floor it reproduces HiGHS's optimum.

7.3 Policy selection, full-year re-evaluation and cost

No surrogate or learned model is trained: every policy is evaluated by the annual physics simulation. The only fitted quantity is the policy itself. *Selection*: the policy is selected on 60 days, five per month sampled evenly from the TMYx year. *Full-year re-evaluation*: the selected policy and all its competitors are re-simulated on all 365 days of the year, which include the 60 selection days; we report whether the optimum and the ranking survive and the errors of the sampled-year estimates (Section 9.6).

Computational complexity. One annual evaluation costs $O(n_p(N^2 + D)T/\Delta t)$ for n_p policies, N zones and D doors (28,800 steps), so comparing the 49 policies costs one batch run; the optimal-control program is a sparse linear program with $O(NT/\Delta t_{\text{LP}})$ variables, solved to optimality in polynomial time at $\gamma = 0$; the search at $\gamma = 0.02$ solves at most 19 such programs. The controller in the building needs $O(N)$ comparisons per step. Measured times are in Section 9.6 and Appendix J.

7.4 Experimental design

Besides the three cases of Section 4.3 and the test instances, the experiments comprise the following. *The comfort frontier* is found by raising the cooling setpoint in 0.5 K steps and keeping the highest admissible value; a *fine thermostat* (0.1 K differential, 0.05 K steps) shows how it depends on the control precision. A *ramped pre-peak setback* lowers the setpoint by 0.5 K per hour up to 13:00, sparing the higher modes; a *pre-specified dawn setback* applies the timing the benchmark selects under the realistic controller (2 K at 03:00, returned in 0.5 K steps by 09:00, every cooling-month day, Case 3). *The passive zones* are compared with and without the controller: all units off, interior doors closed, the reference setpoint, current practice, and a 1-ton unit, a size below the catalogue range, in every bath (Appendix C). *Sizing*: units are sized by load at the first of the margins 1.15, 1.5, 2.0, 2.5 and 3.0 times each zone's peak hourly load at which no room leaves the safe set (0.25-ton steps from 0.75 ton), also with a controller that starts each unit at full capacity. *One-at-a-time sensitivity runs* vary the equipment (cycling loss, unit type, standby, derating, part-load COP, indoor fan), the controller (differential, escalation thresholds, modes), the zone model (nodes, air share and coupling, capacitance, the COP's indoor slope γ), the envelope and air (thermal bridges, absorptance, internal gains, infiltration, door schedules, ground model, wall coupling, latent and humidity models) and the weather (a wider daily swing, a heat wave, an imposed day-night COP swing), as well as the tariff; the full list, apart from the capacitance and imposed COP-swing runs reported in the

Algorithm 2: PERFECTFORESIGHTBENCHMARK(case, H , $v_{\min}$, γ)

Input: case (zones, units); design day or horizon H with its weather; pre-cooling floor $v_{\min}$; indoor COP slope γ

Output: gap = $(E_{\text{hold}} - E_{\text{best}})/E_{\text{hold}}$

- 1 build the linear two-node model of Eq. (2): implicit Euler, 15-min steps, periodic horizon ($x_0 = x_T$), door exchange linearised about $\Delta T_0 = 0.5$ K;
- 2 build the convex mode-hull cost $P_i(q, T_a)$ of each unit;
- 3 $g_{it} \leftarrow g(V_{\text{high}})$ for all i, t ; solve the LP (10) by interior point $\rightarrow (V, q, E)$; $E_{\text{best}} \leftarrow \text{cost of } (V, q)$ priced with $g(V)$;
- 4 **if** $\gamma > 0$ **then**
 - 5 $g_{it} \leftarrow g(V_{it})$; re-solve the LP; keep the cheaper of the two schedules priced with $g(V)$;
 - 6 **foreach** start in {that schedule, the LP with every $V_{it} \geq V_{\text{high}} - 0.01$ K} **do**
 - 7 $(V^0, q^0) \leftarrow \text{start}$; $\rho \leftarrow 1$ K;
 - 8 **repeat**
 - 9 solve the LP with cost $\sum P_i(q)/g(V^0) - \sum (\partial g / \partial V) P_i(q^0)/g(V^0)^2 V$ and $|V - V^0| \leq \rho \rightarrow (V, q)$;
 - 10 **if** cost of (V, q) priced with $g(V) <$ that of (V^0, q^0) **then**
 - 11 $(V^0, q^0) \leftarrow (V, q)$; $\rho \leftarrow 2\rho$;
 - 12 **else**
 - 13 $\rho \leftarrow \rho/2$;
 - 14 **until** $\rho < 0.02$ K, or 8 steps;
 - 15 $E_{\text{best}} \leftarrow \min(E_{\text{best}}, \text{cost of } (V^0, q^0))$;
 - 16 $E_{\text{hold}} \leftarrow$ same linear model, each room held at V_{high} whenever it needs cooling (active-set solve per step), cost divided by $g(V_{\text{high}})$;
 - 17 **return** gap;

text (Section 9.7), is in Appendix H. The setpoint lever and the 2 K pre-peak cost are also recomputed at 6- and 1-minute steps (the 1-minute step moves the latter by at most 1.5 percentage points). Three further sets test the pre-cooling result where it is most likely to fail (Appendix H): the choices most favourable to pre-cooling combined, the lattice applied to the top-floor or west-facing units only, and a finer controller resolution (1-minute step, minimum on- and off-times, a start-based cycling loss calibrated to the part-load factor). A *global uncertainty analysis* varies 17 assumed inputs jointly over uniform ranges by a Latin hypercube [58] of 128 samples per city (fixed seed); its outputs, the setpoint, envelope and inverter levers, the best admissible pre-cool and the cost of 2 K of pre-cooling, are summarised by the median, the 5–95% range, the share of samples in which any of the pre-cooling settings tested saves, and partial rank correlation coefficients [59] (ranges in Appendix I). The two designs have different roles [60]. One-at-a-time runs isolate each assumption against the base case, and many of them are alternative models rather than values on a range (one or two nodes, unit type, controller resolution, ground and humidity models, heat wave, tariff), which cannot be sampled; but they explore only the neighbourhood of the base case and miss

interactions [61]. The joint analysis covers the continuous inputs over their whole ranges, with their interactions, and the choices most favourable to pre-cooling are also combined in one run. A 2^4 *factorial lever decomposition* crosses envelope, equipment (the 3-ton units as inverter units), setpoint and pre-cooling (2 K pre-peak or none) and attributes the bill saving to the four levers by Shapley values. *External checks*: the operative temperature is estimated from the inner-surface temperatures, and a *stock-equivalent* run gives the pre-code building the equipment efficiency and air-tightness of the Saudi stock model [1] (rated EER 8.5, latent COP 2.49, 0.8 ACH), with nothing fitted.

7.5 Reproducibility

Every parameter, the floor plan and the run matrix are read from configuration files, and every result is written by resumable analysis blocks from which the figures, tables and every number in the text are generated. The pipeline is deterministic: rerunning it reproduces every stored value exactly, except the measured calculation times. A test suite checks the geometry, the engine, the optimal-leap identity, the thermostat result, the passive-zone heat budget, both seasons, the test instances, the full-year re-evaluation, the benchmark and the headline results, and a single command (`make reproduce`) regenerates everything, including the PDF.

8 Model Verification and Validation

No apartment of the modelled building is metered, so the model cannot be calibrated against measurements of its own. It is checked instead by the three approaches used to test building simulation programs [62], on which ANSI/ASHRAE Standard 140 is built [63]: analytical verification, comparative testing against EnergyPlus on identical inputs, and empirical comparison with the energy use of the Saudi housing stock.

8.1 Verification

Physical consistency. With every unit switched off, the top-storey master bedroom of the pre-code Jeddah building averages 38.3 °C in July and peaks at 43.6 °C, so active cooling is required, the premise of Definition 1.

Numerical convergence. All results use a 3-minute step, which also sets how often a unit can switch, so changing it changes the controller as well as the integration. A 1-minute step, at which the 3-minute restart delay spans three steps and binds, changes the annual HVAC energy by at most 2.9%, and a 6-minute step by at most 2.6%; at a 1-minute step the setpoint lever changes by at most 0.6 and the cost of a 2 K pre-peak pre-cool by at most 1.5 percentage points, but the pre-cool costs at least 2.1% at every step tested.

Heat balance. The engine conserves the inter-zone exchanges of Section 5.3 to rounding: the July heat budget of every bath of the representative apartment closes to within 0.6 W (1.3% of its inflow; Section 6.1).




Figure 5: Like-for-like comparison with EnergyPlus 26.1: delivered sensible cooling under ideal control at the reference setpoints. On the same storey-box geometry the two engines agree within a few percent; the room-resolved plan delivers less, because its passive rooms float above the setpoint.

8.2 Validation

Three comparative tests against EnergyPlus 26.1 and a comparison with the housing stock test the model’s physics and magnitudes; the savings are differences between runs of the same model, in which a common bias largely cancels.

BESTEST-style comparative test. On the single-zone cases 600 (lightweight) and 900 (heavyweight) of Standard 140, run in both programs on the Riyadh weather, the engine’s annual cooling differs from that of EnergyPlus by -0.2% and $+4.3\%$ and its peak hourly cooling by -11.3% and -10.4% ; free-floating, its annual maximum temperature is 5.5 and 4.5 K lower. The engine thus reproduces annual loads closely but damps the sharpest peaks, its structure being one node and its exterior film coefficient fixed (Appendix G).

Like-for-like comparison with EnergyPlus. The second test isolates the engine from the zoning. EnergyPlus and the engine are run on the building as one well-mixed zone per storey (the 18.85×27.70 m centreline body with the drawing’s window-to-wall ratios and the storey’s capacitance, gains, infiltration and ground slab), both holding the reference setpoints with ideal equipment (Fig. 5; simulation settings in Appendix G). On the same geometry the two engines differ by -6.0 to $+1.3\%$ in delivered sensible cooling in the four configurations. The room-resolved model delivers 5.8–12.3% less cooling than the storey box, because a third of the floor area is passive and floats above the setpoint, admitting less heat than if it were held there. The envelope effect agrees closely: SBC compliance cuts delivered cooling by 56.1% in Riyadh and 54.1% in Jeddah in EnergyPlus and 50.3% in Riyadh and 49.6% in Jeddah in the room-resolved model.

Response to setbacks. The scheduling result rests on how much extra heat a colder room admits. The third test therefore applies the 2 K pre-peak and night setbacks of the thermostat

Table 4: Response to setbacks on the storey box (ideal control): extra sensible cooling delivered by a 2 K setback relative to the reference setpoint [%]. E+: EnergyPlus 26.1; this: the engine of the model.

Envelope	City	Pre-peak, 2 K		Night, 2 K	
		E+	this	E+	this
SBC	Riyadh	+1.2	+1.5	+3.3	+4.4
SBC	Jeddah	+1.9	+2.2	+5.0	+6.6
Pre-code	Riyadh	+1.6	+1.7	+3.1	+4.7
Pre-code	Jeddah	+2.4	+2.5	+4.5	+7.0

lattice to the storey box in both programs, under ideal control and with the seasonal changeover of the model (Table 4). Both find that every setback removes more heat than holding the reference setpoint, EnergyPlus by 1.2–5.0% and the engine by 1.5–7.0%: the engine overstates this extra heat, EnergyPlus finding 64–96% of it. Section 9.3 tests whether this could change the sign of the scheduling result.

Stock energy use. The stock model of Krarti et al. [1] puts the whole-building energy use intensity (EUI) of Saudi residential buildings at 125.6–182.4 kWh/m²·yr across the four regions, with 136.0 for the Middle region, which contains Riyadh, and 159.6 for the West, which contains Jeddah. With its HVAC energy divided by 0.70, the share of residential electricity that space conditioning takes (Section 1), the pre-code building, with new units at the SASO minimum and 0.4 ACH, uses 82 (Riyadh) and 98 kWh/m²·yr; with the equipment and air-tightness of existing homes (Section 7.4) it uses 121 and 161 kWh/m²·yr, -11% and $+1\%$ against its region’s average (-6% and $+7\%$ with a share of 0.66): agreement in magnitude rather than calibration, since the regional averages mix villas, apartments and traditional houses.

8.3 Absolute and relative errors

Table 5 collects the error of every quantity that the study estimates against a reference; the comparison of the thermostat policies is exhaustive over the lattice, and the optimal-control programs with the indoor COP factor are approximate through their fixed-point iteration. None of these errors is large enough to change the ordering of the levers.

9 Results

All results use the room-resolved model of Section 5, the TMYx weather of Riyadh and Jeddah and the per-meter volume tariff. The main case is the SBC-compliant building; the pre-code envelope (Section 4.3) is reported alongside to show what code compliance is worth. Savings are bill-based and measured against the baselines of Section 7.1; every optimum and every saving attributed to a selected policy is between admissible policies (Section 5.8); runs that leave the safe set are excluded and shown as “–”. Energy is reported as the HVAC energy intensity, the electricity of the units (sensible, latent and standby) per square metre of floor.

Table 5: Absolute and relative errors of the model’s estimates against their references (pairs of values: Riyadh / Jeddah, or case 600 / 900 and 640 / 940; the BESTEST-style cases are detailed in Appendix G).

Quantity	Reference	Absolute error	Relative error
Annual energy, 60 sampled days	full year (365 days)	−1953 / +400 kWh	−3.7% / +0.5%
Annual energy, 3-min step	1-min step	—	≤ 2.89%
Passive-zone heat budget	exact balance	≤ 0.6 W	≤ 1.3%
Annual cooling, BESTEST-style 600 / 900	EnergyPlus	−0.02 / +0.41 MWh	−0.2% / +4.3%
Annual cooling, BESTEST-style 640 / 940	EnergyPlus	−0.01 / +0.41 MWh	−0.1% / +4.3%
Extra heat removed by a 2 K setback, storey box	EnergyPlus	0.1–2.5 points	4–56%
Delivered cooling, storey box	EnergyPlus, same geometry	−11.8 to +1.3 kWh/m ² yr	−6.0 to +1.3%
Stock-equivalent EUI	regional average [1]	−15 / +1 kWh/m ² yr	−11% / +1%

9.1 Comfort and feasibility

Conditioned rooms. At the reference policy every conditioned room of the SBC-compliant building stays at or below 24.0 °C all year. The building is feasible with a wide margin: in its peak hour the busiest unit removes 19% (Riyadh) and 19% (Jeddah) of its rated capacity, because units sized by coverage are several times larger than the loads of an insulated building, and the units are off 77% and 71% of the time. Even the pre-code building holds the ceiling with these units, its busiest unit peaking at 55% of its capacity, so with coverage-sized units the envelope is an energy lever; the comfort margin it buys appears when the units are sized by load (Section 9.5). No meter reaches the 6,000 kWh tier-2 threshold: the busiest meter of the compliant building uses at most 1,137 kWh of HVAC electricity in a month, and no apartment meter of either building would exceed 4,579 kWh even if HVAC were only 66% of the household’s electricity [1].

Comfort frontier. Raising the cooling setpoint by the thermostat’s 0.5 K step to 24 °C lets the rooms rise 0.5 K above the ceiling in every cycle (84,964 and 119,545 K·h a year), so the comfort frontier is the reference setpoint itself, the frontier that Theorem 1 gives for a 1 K differential centred on the setpoint. A finer thermostat (0.1 K differential, 0.05 K steps) at 23.5 °C holds the room lower and costs more, 5.1% in Riyadh and 3.0% in Jeddah; its own frontier is 23.95 °C in both cities, where its bill differs from that of the base thermostat by −0.5% in Riyadh and −0.5% in Jeddah. Finer control moves the setpoint but hardly the time-mean temperature, which is what the theorem prices.

Passive zones. With their doors open the rooms without a unit stay close to their conditioned neighbours (Section 6.1): in apartment 2A (Riyadh) the lobby, corridor and hall average 23.7–23.8 °C over the year, the interior baths and the maid room 23.9–24.0 °C, and the two baths with an exterior wall 24.2 °C, peaking at 25.8–26.2 °C. Isolated from their neighbours (baseline B5) they would average 33.7 °C instead of 24.7 °C (Jeddah); the thermal shift that cools them raises the building’s energy by 13.5%.

Operative temperature. The operative temperature, estimated from the inner-surface temperatures of each room, peaks at 25.0–25.1 °C in the conditioned rooms at the reference setpoint, in the top-floor rooms under the roof, and

exceeds 25 °C in fewer than 0.05% of the room-hours, inside the 23–27 °C operative range of the ASHRAE summer comfort zone (Section 4.2).

9.2 Savings in the three cases

Cases 1 and 2. For one apartment, modelled as an intermediate unit whose shared walls and slabs face conditioned space, the HVAC energy intensity is 23.8 kWh/m²yr in Riyadh and 34.8 in Jeddah, and the setpoint lever, from current practice to the reference setpoints, saves 12.2% in Riyadh and 9.8% in Jeddah (Table 6). Adding the neighbouring apartment and the core (Case 2) changes the representative apartment’s energy by only 0.9% (Riyadh) and 0.6% (Jeddah), since the conditioned rooms on either side of the party wall differ by a fraction of a kelvin (Section 6.1), and moves the setpoint lever by at most 0.2 points. In both cases the best admissible thermostat policy is no pre-cooling: the no-gain condition of Theorem 3 holds for every pre-cooling policy.

Case 3: the whole building. The building adds the roof, the ground and the vertical coupling of four storeys. Its HVAC energy intensity is 25.1 and 37.7 kWh/m²yr, and the setpoint lever saves 12.4% in Riyadh and 10.5% in Jeddah. The insulated roof keeps the top apartment’s HVAC energy within 13% (Riyadh) and 9% (Jeddah) of an intermediate one, whereas in the pre-code building the top apartment uses 1.5–1.7 times as much; this is why the envelope saving of the whole building (56.4%, 45.0%) exceeds that of one apartment (50.5%, 38.3%).

Savings per apartment. Every apartment has its own meter, so the levers can be priced per household (Table 7). The setpoint lever lowers an apartment’s annual HVAC bill by 152–190 SAR (US\$41–51) in Riyadh and 186–234 SAR (US\$50–62) in Jeddah, most on the ground floor, whose rooms at 22 °C also draw heat from the ground. The envelope is worth far more: the same apartment in the pre-code building would cost 1,084–2,612 SAR (US\$289–697) more a year in Riyadh and 998–2,432 SAR more in Jeddah, most of all under the roof. Between the two mirror-image apartments of a storey the bill differs by 2.3–3.2%, the west apartment paying more in Riyadh and the east one in Jeddah, while the setpoint saving differs by at most 9 SAR a year. The lever

Table 6: The three cases (SBC-compliant building; pre-code value in parentheses). HVAC energy intensity: electricity of the units per floor area. Setpoint: saving of the setpoint lever, from current practice (cooling 22, heating 20.5 °C) to the reference setpoints (23.5 and 22.5 °C). Pre-cooling: saving of the best admissible thermostat policy of the lattice. Envelope: SBC versus pre-code at the reference setpoints.

City	Case	HVAC intensity [kWh/m ² yr]	Setpoint	Pre-cooling	Envelope
Riyadh	1: apartment	23.8 (48.0)	12.2%	0%	50.5%
	2: floor	23.3 (46.9)	12.4%	0%	50.4%
	3: building	25.1 (57.5)	12.4%	0%	56.4%
Jeddah	1: apartment	34.8 (56.4)	9.8%	0%	38.3%
	2: floor	35.6 (58.4)	9.8%	0%	38.9%
	3: building	37.7 (68.5)	10.5%	0%	45.0%

percentages of the abstract and Table 6 are for whole cases (one apartment, a floor, the building), not for each apartment.

Seasons. Table 8 splits the setpoint and envelope levers by season. In summer (June–September), which carries the largest share of the energy, the setpoint lever saves 9.8–10.6% in Riyadh and 7.9–8.5% in Jeddah. In winter (December–February) it saves 11.9–26.6% and 16.7–17.6% of the little energy then used, partly heating in Riyadh, where the reference policy holds the band floor. Winter is a substantial heating season only for the pre-code building in Riyadh (11,116 kWh of heating a year, against 1,367 kWh in the SBC-compliant building). The latent load is negligible in Riyadh (0.4% of the HVAC energy) and 26% in Jeddah, where it dilutes the setpoint lever (10.1% for apartment 2A with it, 13.3% without); the seasonal operation and the modes used are in Appendix H.

9.3 The timing lever

Thermostat pre-cooling. None of the pre-cooling settings of the lattice saves anything, in any case, city or envelope (Table 6); over all 365 days, where all of them stay within the safe set in the SBC-compliant building, every one of them raises its bill, by at least 0.52%, and on the sampled days the shallowest step, a 0.5 K pre-peak pre-cool, costs 0.51% in Riyadh and 0.74% in Jeddah. At a depth of 2 K, night pre-cooling costs 4.6% in Riyadh and 5.3% in Jeddah and pre-peak pre-cooling 3.4% in Riyadh and 4.3% in Jeddah. Table 9 splits each feature into the two terms of Theorem 2: every depth run (0.5–2 K, step and ramped setbacks, default controller and low mode only) raises the heat removed, by 0.12–8.67%, because colder rooms admit more heat, while the mean COP rises slightly at night and falls or stays level before the peak: the heat added outweighs the COP gained. Tests where this result is most likely to fail (Appendix H) cover inverter units held in their lowest mode, ramped and dawn setbacks, the extra heat scaled to what EnergyPlus finds, pre-cooling of the top floor or the west rooms alone, and a 1-minute controller with minimum on- and off-times and a cycling loss charged per start (inadmissible in Riyadh, where it is excluded). None of the admissible ones saves, and scaled to EnergyPlus’s extra heat a 2 K pre-peak pre-cool still costs 2.9–3.8%. Apart from the one-node variant (0.08%; Section 9.7), only with every choice most favourable to pre-cooling combined (one node per zone, a COP independent of the indoor air, inverter units held in their lowest mode and no cycling loss) does the best policy save, at most 0.77%.

Because every unit pre-cools at the same time, a 2 K pre-peak pre-cool also raises the building’s largest hourly electrical demand, from 21.4 to 34.1 kW in Riyadh and from 22.0 to 35.3 kW in Jeddah.

Running example (continued). Apartment 2A of the compliant building in Riyadh (Case 3) pays 1,144 SAR (US\$305) a year at the reference policy. A thermostat that pre-cools by 2 K before the afternoon adds about 39 SAR a year to that bill and nothing to comfort: under the Saudi tariff the right setting is to switch night and pre-peak pre-cooling off.

Perfect-foresight benchmark. The linear program of Section 7.2 schedules the idealised units of Cases 1 and 2, of the top floor under the roof and, for the bound only, of the whole building (Case 3) with perfect knowledge of the weather and compares the result with holding the ceiling with the same units (Table 10 shows selected design days; all are in Appendix D, and the ranges below are over all of them). With a COP that depends on the outdoor air only ($\gamma = 0$), its optimum is a rigorous upper bound on what any schedule of the idealised model could save: at most 1.9% of the sensible cooling electricity on a design day with the rooms kept in the comfort band and 3.6% down to the 20 °C floor of the safe set, and 0.58–1.07% and 1.03–2.07% over the season in Case 1. Under the roof the bound is smaller than on the typical floor: 0.75% in Riyadh and 0.35% in Jeddah on the mean July day within the band, against 1.39% in Riyadh and 0.86% in Jeddah for the typical floor. For the whole building it is 0.13–1.34% within the band and 0.22–2.50% down to 20 °C on the design days of Case 2, below the typical floor on every day. With the engine’s indoor COP factor ($\gamma = 0.02$) the program is not linear. The sequential linear programming of Section 7.2 prices every schedule it keeps with its own indoor factor, so each is one that the idealised units can follow. The achievable saving is that of the best valid schedule found: at least zero, since holding the ceiling is itself a valid schedule, and down to 20 °C at least the saving of the schedule found within the band, which is valid there too. It is 0.00–0.63% within the band and 0.00–0.67% down to 20 °C on a design day, and 0.23% in Riyadh and 0.06% in Jeddah within the band over the season in Case 1. On every periodic horizon solved, the optimal saving at $\gamma = 0.02$ therefore lies between its achievable saving and its $\gamma = 0$ bound. With July treated as one 31-day horizon (Case 1), which lets heat be stored across days, the program achieves 0.33% in Riyadh and 0.23% in Jeddah, against 0.28% in Riyadh and 0.10% in Jeddah for the mean July day, with a bound of 1.31% in

Table 7: Annual HVAC bill and savings per apartment in the SBC-compliant building (Case 3; apartments numbered by storey, 1 = ground, 4 = top; A west, B east). Bill: at current practice [SAR/yr]. Setpoint: saving of the setpoint lever [SAR/yr] (% of the bill). Envelope: extra bill of the same apartment in the pre-code building at the reference setpoints [SAR/yr] (% of the pre-code bill). Percentages from unrounded bills.

Apartment	Riyadh			Jeddah		
	Bill	Setpoint	Envelope	Bill	Setpoint	Envelope
1A	1,433	190 (13.2%)	1,132 (47.7%)	2,028	231 (11.4%)	998 (35.7%)
1B	1,394	181 (13.0%)	1,084 (47.2%)	2,076	234 (11.3%)	1,088 (37.1%)
2A	1,306	162 (12.4%)	1,171 (50.6%)	1,869	189 (10.1%)	1,047 (38.4%)
2B	1,266	156 (12.3%)	1,123 (50.3%)	1,920	191 (9.9%)	1,135 (39.6%)
3A	1,307	159 (12.1%)	1,316 (53.4%)	1,871	186 (9.9%)	1,203 (41.7%)
3B	1,268	152 (12.0%)	1,263 (53.1%)	1,921	187 (9.7%)	1,289 (42.6%)
4A	1,462	168 (11.5%)	2,612 (66.9%)	2,044	212 (10.4%)	2,355 (56.2%)
4B	1,423	162 (11.4%)	2,555 (67.0%)	2,095	214 (10.2%)	2,432 (56.4%)

Table 8: Savings of the setpoint and envelope levers by case, city and season (SBC-compliant building; % of the HVAC energy of the case in that season; annual savings in Table 6). Summer: June–September; winter: December–February. Reference: HVAC energy at the reference policy [kWh]. Under the tier-1 volume tariff the bill saving equals the energy saving.

City	Case	Annual			Summer			Winter		
		Reference	Setpoint	Envelope	Reference	Setpoint	Envelope	Reference	Setpoint	Envelope
Riyadh	1	5,484	9.8%	49.2%	3,313	26.6%	77.4%	222		
	2	11,711	10.0%	48.9%	7,126	25.8%	78.5%	459		
	3	50,512	10.6%	54.1%	31,239	11.9%	82.8%	1,971		
Jeddah	1	8,041	7.9%	40.0%	3,758	16.7%	33.6%	1,011		
	2	17,945	7.9%	40.1%	8,352	16.7%	36.5%	2,268		
	3	75,912	8.5%	46.3%	35,610	17.6%	41.1%	9,450		

Riyadh and 0.96% in Jeddah. The program saves in the way Theorem 2 allows: it pulls the rooms down around dawn, when the outdoor air is coolest and the COP highest (the rooms are coldest at 06:00 in the Riyadh July profile), never uses more than the lowest mode, and lets the rooms rise to the ceiling through the hottest hours. Its linearisation and its search are checked in Appendix D. The benchmark’s continuous low-mode modulation without cycling losses is part of what it measures: a dawn setback fixed in advance, which imitates its timing on a simulated thermostat, raises the bill of the whole building (Case 3) by 0.99–1.80% (Appendix H).

9.4 Ablation study

The selected policy θ^* has four components: the frontier setpoint (the 23.5 °C reference), no pre-cooling, units in the lowest mode that holds the room, and the SBC envelope. Table 11 changes one of them at a time (Case 3; the simulation is deterministic, so each variant is a single annual run). The envelope matters most: the pre-code envelope raises the bill by 129.5% in Riyadh and 81.8% in Jeddah. Lowering the cooling setpoint alone to 22 °C costs 14.5% in Riyadh and 11.7% in Jeddah, which differs from the setpoint lever of Table 6 because that lever also moves the heating setpoint and is expressed relative to current practice. Running every inverter unit in its highest mode costs 22.4% in Riyadh and 17.3% in Jeddah; this largely reproduces the assumed ratio of mode efficiencies (Theorem 1) and, since an inverter unit chooses its mode by itself, ranks a property of the controller rather than a household decision. The pre-cooling rows carry the penalties of Section 9.3. No variant is cheaper than θ^* .

Factorial decomposition. The one-at-a-time levers are measured against different baselines. A full 2^4 factorial of four levers (envelope, the 3-ton units as inverter units, the setpoints of current practice or of the reference, and a 2 K pre-peak pre-cool or none; Case 3, all 16 combinations admissible) puts them on one base. Going from the pre-code building with catalogue units, current-practice setpoints and pre-peak pre-cooling to the SBC building with inverter units, the reference setpoints and no pre-cooling lowers the building’s annual HVAC bill from 26,788 to 8,889 SAR (US\$7,143 to US\$2,370) in Riyadh and from 33,616 to 13,924 SAR (US\$8,964 to US\$3,713) in Jeddah, savings of 66.8% and 58.6%. Table 12 attributes this saving to the levers by their Shapley values, the average of each lever’s marginal saving over every order in which the levers can be applied. The envelope takes 74.6% in Riyadh and 68.6% in Jeddah of it, and dropping pre-cooling the least, 2.3% in Riyadh and 3.8% in Jeddah. The levers are sub-additive: each saves less once another has lowered the load, most for the envelope with the equipment in Riyadh and the envelope with the setpoints in Jeddah (an interaction of up to 7.0% of the starting bill), while pre-cooling interacts with the other levers by at most 0.9%. In both cities the envelope comes first and timing last; the equipment saves more than the setpoints in Riyadh, and the two, close to each other, swap places in SAR in Jeddah, as in the one-at-a-time results. The Shapley value of the timing lever is the avoided penalty of its start level, the 2 K pre-peak pre-cool; the mode lever is not part of the factorial, since the controller sets the mode.

Table 9: Why thermostat pre-cooling does not pay (SBC-compliant building, Case 3, volume tariff): change in the annual bill, in the heat removed and in the mean cooling COP when each feature is switched on alone, relative to no scheduling. Default: the controller of Section 5.7; low only: inverter units held in their lowest mode. Every row is admissible: it stays within the safe set, (C2) and (C3).

City	Feature	Bill, default	Bill, low only	Heat removed, low only	Mean COP, low only
Riyadh	Pre-peak, 0.5 K	+0.51%	+0.48%	+0.40%	3.44 → 3.44
	Pre-peak, 2 K	+3.40%	+1.95%	+1.96%	3.44 → 3.44
	Night, 0.5 K	+0.95%	+0.97%	+1.32%	3.44 → 3.45
	Night, 2 K	+4.57%	+3.88%	+5.71%	3.44 → 3.49
Jeddah	Pre-peak, 0.5 K	+0.74%	+0.65%	+0.61%	3.63 → 3.62
	Pre-peak, 2 K	+4.30%	+2.84%	+3.05%	3.63 → 3.60
	Night, 0.5 K	+1.15%	+1.11%	+1.92%	3.63 → 3.64
	Night, 2 K	+5.27%	+4.72%	+8.67%	3.63 → 3.70

Table 10: Perfect-foresight benchmark (SBC-compliant building): saving [%] of the sensible cooling electricity that an ideal schedule achieves over holding the 24 °C ceiling with the same idealised units, with the rooms pre-cooled at most to the band floor (22 °C) or to the floor of the safe set (20 °C), with a COP that depends on the outdoor air only ($\gamma = 0$) or the COP of the engine ($\gamma = 0.02$, falling by 2%/K of indoor air below 27 °C). The $\gamma = 0$ columns are rigorous upper bounds on the saving of any schedule of the idealised model; the $\gamma = 0.02$ columns are achievable savings, those of the best valid schedule found (sequential linear programming, every schedule priced with its own indoor factor): at least the reference, 0, and at 20 °C at least the 22 °C schedule of the same day. Hold: electricity of the reference at $\gamma = 0.02$ [kWh/day]. Season: May–September mean days weighted by the reference energy of their month (Case 1); July, 31 days: the whole month as one horizon (Case 1, band floor only). Case 3: the bound only; the search at $\gamma = 0.02$ is not run. Selected design days; every design day is in Appendix D.

		Riyadh					Jeddah				
			$\gamma = 0.02$ (achievable)		$\gamma = 0$ (bound)			$\gamma = 0.02$ (achievable)		$\gamma = 0$ (bound)	
Case	Day	Hold	22 °C	20 °C	22 °C	20 °C	Hold	22 °C	20 °C	22 °C	20 °C
1: apartment	Jul, mean day	22.3	0.28	0.28	1.26	2.41	16.8	0.10	0.10	0.78	1.43
	Jul, hottest day	25.4	0.46	0.47	1.50	2.86	19.3	0.54	0.54	1.79	3.34
	Season	–	0.23	0.23	1.07	2.07	–	0.06	0.06	0.58	1.03
	July, 31 days	22.3	0.33	–	1.31	–	16.9	0.23	–	0.96	–
2: floor	Jul, mean day	46.6	0.35	0.35	1.39	2.65	35.9	0.13	0.13	0.86	1.58
	Jul, hottest day	53.8	0.54	0.56	1.63	3.09	41.6	0.63	0.67	1.92	3.57
Top floor	Jul, mean day	55.8	0.12	0.12	0.75	1.42	43.5	0.02	0.02	0.35	0.63
	Jul, hottest day	64.5	0.19	0.19	0.96	1.82	50.1	0.25	0.25	1.08	2.02
3: building	Jul, mean day	204.8	–	–	0.94	1.78	157.3	–	–	0.50	0.91
	Jul, hottest day	235.6	–	–	1.16	2.21	181.1	–	–	1.34	2.50

9.5 Generalisation: scale and test instances

Scale and saturation. Across the three cases the model grows from 16 to 33 to 132 zones and from 7 to 15 to 60 units, yet the optimum stays at no pre-cooling in every case, city and envelope: what changes with scale is the load on each unit, not the value of re-timing, and how close the units come to their capacity depends on the envelope and on how they are sized (Table 13).

Normal and hard instances. All eight instances with the catalogue units are normal: even in the heat-wave year, 3 K hotter in every hour, the peak load ratio stays at 0.26 in the SBC-compliant building (Riyadh) and at most 0.62 in the pre-code building, because units sized by coverage leave a wide margin even for the uninsulated envelope. Hard instances arise when the units are sized tightly, each to 1.15 times its room’s largest hourly load, after derating, rounded up to 0.25 ton (at least 0.75 ton). All four such instances are hard. Their peak load ratio rises to 0.57–0.79, so they satisfy the feasibility condition (7) on hourly loads, yet the rooms exceed the ceiling by 18–81 K·h a year. These excursions

are not a shortage of hourly capacity. Starting each unit at full capacity leaves them unchanged, so they do not arise at start-up: they arise while a running unit escalates from a lower mode, with the switch-on point at the ceiling itself (Appendix H). At the reference setpoints no lattice setting, with or without pre-cooling, is admissible in any of the four. A lower cooling setpoint, which moves the switch-on point below the ceiling, restores admissibility: the highest admissible setpoint is 23 °C in all of them, where the tightly sized units still save 10.2–16.7% against the catalogue units at the reference policy, so for these units the optimum moves to a lower setpoint rather than to another lattice setting. In every instance with an admissible reference policy the best thermostat schedule is no pre-cooling.

9.6 Thermostat comparison: full-year re-evaluation and calculation time

Selection and full-year re-evaluation. The comparison is exhaustive over the 49 realisable thermostat policies, and its best policy, no pre-cooling, is the same in all four envelope–climate configurations and in every case and test instance

Table 11: Ablation of the selected policy θ^* (whole building, Case 3, volume tariff). Each variant changes one component and keeps the others, including the heating setpoint. Bill: annual HVAC bill (SAR); Δ : its change relative to θ^* ; Exc.: excursion above the 24 °C ceiling / below the 20 °C floor (K·h), summed over conditioned rooms; every row stays within the safe set, so every variant is admissible. Deterministic simulation, one annual run per variant; lowest bill in bold.

Variant	Changed component	Riyadh			Jeddah		
		Bill ↓	Δ (%)	Exc. above/below	Bill ↓	Δ (%)	Exc. above/below
Full solution (θ^* , SBC)	–	10,456	–	0/0	15,714	–	0/0
Current-practice cooling	23.5 → 22 °C	11,968	+14.5	0/0	17,551	+11.7	0/0
Highest mode	lowest → highest mode	12,801	+22.4	0/0	18,440	+17.3	0/0
Pre-code envelope	SBC → pre-code	23,994	+129.5	0/0	28,566	+81.8	0/0
Night pre-cooling	none → 2 K at night	10,934	+4.6	0/0	16,542	+5.3	0/0
Pre-peak pre-cooling	none → 2 K before peak	10,811	+3.4	0/0	16,390	+4.3	0/0

Table 12: Factorial (2^4) decomposition of the bill saving (Case 3). Levers, from start to end state: pre-code → SBC envelope; fixed-speed → inverter 3-ton units; setpoints 22/20.5 → 23.5/22.5 °C; 2 K pre-peak pre-cool → none. Shapley value: each lever’s marginal saving averaged over all orders (SAR/yr and share of the total); main effect: mean saving of the lever over the eight combinations of the others (% of the bill without it).

Lever	Riyadh			Jeddah		
	SAR	Share	Main	SAR	Share	Main
Envelope	13,346	74.6%	56.0%	13,503	68.6%	45.7%
Inverter 3-ton units	2,395	13.4%	13.5%	2,667	13.5%	11.1%
Setpoints	1,742	9.7%	10.2%	2,774	14.1%	11.0%
No pre-cooling	416	2.3%	2.6%	747	3.8%	3.4%
Total	17,899	100%		19,692	100%	

with an admissible reference policy. Selected on the 60 sampled days and re-evaluated on all 365 days of the year, which include them (Section 7.3), the optimum for the SBC-compliant building is unchanged in both cities, and the policies keep almost the same cost ranking (Spearman rank correlation 0.999 in Riyadh and 0.999 in Jeddah). The sampled-year estimate of the building’s annual HVAC energy at the reference policy differs from the full-year value by -3.7% (Riyadh) and $+0.5\%$ (Jeddah), and the relative cost of every pre-cooling policy by at most 0.56 percentage points; unless labelled as full-year, absolute energies and bills are sampled-year values. Admissibility, checked on the sampled days, also holds on all 365 days for every run the results rely on: the 16 runs of the factorial, the units sized by load at the selected margin and the dawn setback stay within the safe set in both cities.

Calculation time. One annual evaluation of the whole building takes 13.4 s for one policy and 52.5 s for all 49 policies of the lattice together, the optimal-control program for one day 21.2 s in Case 1 and 284.3 s in Case 2, and selecting the modes of all 60 units at one control step $8.4 \mu\text{s}$ (Appendix J).

9.7 Sensitivity analysis

The sensitivity analysis varies, one at a time, the inputs that assumption (A5) idealises: the zone model, the controller, the equipment, the envelope and air, and the weather (37

variants of the SBC-compliant building; Table 14 shows the decisive ones, and the full table is in Appendix H). In 35 of the 36 admissible variants the best thermostat pre-cool saves nothing, and a 2 K pre-peak pre-cool costs 2.0–6.7%; the only exception, a one-node zone whose COP does not depend on the room temperature, saves at most 0.08%, and its 2 K pre-peak pre-cool still costs 1.8%. The variant sized by load, 15% margin, is inadmissible: the reference policy already lets a room pass the ceiling, by 69 K·h a year in Riyadh and 18 K·h a year in Jeddah, so no lever or cost is reported for it (“–” in Table 14). The setpoint lever stays between 8.0 and 17.0%.

Equipment. In the SBC-compliant building the installed equipment matters more than its operation. Without cycling losses the building would use less energy, 15.2% in Riyadh and 11.8% in Jeddah, and replacing the twelve fixed-speed 3-ton units by inverter units of the same size would save 15.0% in Riyadh and 11.4% in Jeddah; these guest-room and stair units, the most oversized, use 39–40% of the units’ electricity for 33% of the conditioned floor area. Units sized by load keep every room within the safe set only with a margin of 2.5 times each room’s peak hourly load (the smallest margin that keeps every room within the safe set lies between 2 and 2.5), a property of the modelled controller, whose switch-on point is at the ceiling, rather than of the units (Appendix H). Against the catalogue’s 124 tons, such units would save 16.5% in Riyadh and 11.2% in Jeddah as inverter units throughout, and 2.1% in Riyadh and 0.2% in Jeddah with the fixed-speed zones keeping fixed-speed units, which isolates the effect of size. Sized tightly, with a 15% margin, they are inadmissible at the reference setpoint: the rooms pass the ceiling for 18–69 K·h a year, and a cooling setpoint of 23 °C restores admissibility (Section 9.5). An indoor fan of 30 W that runs whenever the compressor is off in the cooling months, as many wall-mounted units do by default, adds 11.8% in Riyadh and 14.7% in Jeddah, comparable to the setpoint lever, although whether the catalogue units do so was not established. None of these changes the ordering of the operational levers or makes pre-cooling pay.

Controller. With escalation at 0.2/0.6 K a 2 K pre-peak pre-cool costs 3.1% in Riyadh and 4.4% in Jeddah, at 0.8/2.0 K 2.3% in Riyadh and 3.2% in Jeddah, and with the inverter units held in their lowest mode 2.0% in Riyadh and 2.8% in Jeddah. Without the indoor-temperature factor of the COP

Table 13: Normal and hard test instances (Case 3, the whole building). Catalogue: the eight instances with the catalogue units (two envelopes, two cities, TMYx and TMYx +3 K weather) in one row, with ranges over them; every instance is in Appendix H. Units: catalogue (sized by coverage) or sized to the building’s own peak hourly load with a 15% margin. Peak load ratio: largest hourly sensible load of any unit over its rated capacity; excursion of the reference policy above 24 °C and below 20 °C; best policy: the cheapest admissible thermostat policy, night/pre-peak depth (none: no pre-cooling; –: no lattice setting at the reference setpoints is admissible; in brackets, the highest admissible cooling setpoint without pre-cooling, where one exists); admissible policies: number of the 49 lattice policies that keep every conditioned room within the safe set on the sampled days (the others are excluded). No unit reaches a load ratio of 0.85.

Envelope	City	Units	Weather	Class	Peak load ratio	Exc. above/below [K·h]	Best policy	Admissible policies
SBC, pre-code	both	catalogue	both	normal	0.19–0.62	0/0	none	30–49 of 49
SBC	Riyadh	by load	TMYx	hard	0.58	69/0	– (23 °C)	0 of 49
SBC	Jeddah	by load	TMYx	hard	0.57	18/0	– (23 °C)	0 of 49
Pre-code	Riyadh	by load	TMYx	hard	0.79	81/0	– (23 °C)	0 of 49
Pre-code	Jeddah	by load	TMYx	hard	0.75	29/0	– (23 °C)	0 of 49

the setpoint lever falls to 9.5% in Riyadh and 8.1% in Jeddah and the 2 K pre-peak penalty to 2.2% in Riyadh and 3.0% in Jeddah; at 3%/K the lever rises to 14.0% in Riyadh and 11.8% in Jeddah and the penalty to 4.1% in Riyadh and 5.1% in Jeddah. The cycle length, set by the time step, moves the absolute bill but not the sign of pre-cooling (Appendix H).

Zone model, envelope and weather. With one node per zone, so that a pull-down stores coolth in the whole mass at once, a 2 K pre-peak pre-cool still costs 3.3% in Riyadh and 6.7% in Jeddah, because the colder room also lowers the COP. The air-node share of the capacitance (2 to 30%) and the air–structure coupling (halved or doubled) leave the best pre-cool at 0.00%; thermal bridges and the solar absorptance move the energy by a few percent; infiltration between 0.2 and 0.8 ACH moves Jeddah’s intensity from 30.4 to 52.4 through the latent load; and a 30% wider daily swing, alone or in a heat wave, leaves the scheduling result unchanged. A room capacitance of 144 to 450 kJ/(m²K) leaves the best pre-cool at 0% (Jeddah), and an imposed day–night COP swing makes pre-cooling pay only far beyond the physical range (from a COP at 22 °C 4.0 times that at 40 °C in Jeddah and not at all up to a ratio of 6.7 in Riyadh, against a ratio of 1.5 for the model’s curve).

Humidity. A diagnostic humidity balance per zone (Appendix H) tests the assumption that the indoor humidity target is met. It holds in Riyadh, where the conditioned rooms exceed 60% relative humidity in 0.8% of the cooling-season hours, but not in Jeddah, where the oversized units run too briefly: at a sensible heat ratio of 0.75 the rooms exceed 60% in 41% of the hours, so holding the target needs dedicated dehumidification, whose electricity the latent term prices. The setpoint lever hardly moves this diagnostic, and pre-peak pre-cooling worsens it.

Cost model. Under three energy-priced tariffs (a flat price of 0.18 SAR/kWh before VAT, the actual two tiers, and the two tiers with the threshold lowered from 6,000 to 500 kWh a month, which the apartment meters exceed in summer) no pre-cooling remains optimal, with 0% saving, as Theorem 3 implies for any tariff of energy alone once its no-gain condition holds. The stricter tiers only raise the 2 K pre-peak penalty, to 4.4% in Riyadh and 5.3% in Jeddah at the

500 kWh threshold, because part of the extra energy is billed in the higher tier.

Contrast: a time-of-use tariff. To check that the null result is a property of the tariff rather than of the model, the same lattice is priced under an illustrative time-of-use tariff that charges the cooling-month energy used from 13:00 to 17:00 at r times the off-peak price, the window of the Saudi time-of-use programme for large industrial and commercial customers, which did not include households [64]. At $r = 1$ the result is that of the volume tariff. At $r = 2, 3$ and 5 the best schedule pre-cools before the peak and saves 2–27% with the base-case zones (13–50% with one node per zone, whose air holds the full capacitance). The same model that finds no value in re-timing under the Saudi tariff therefore finds it as soon as the tariff prices the hour.

Global uncertainty analysis. The one-at-a-time runs leave the joint effect of the assumed inputs open. Seventeen of them (the indoor COP slope, the outdoor COP slope, the low-mode COP ratio, the medium-mode COP ratio, the cycling losses of the inverter and of the fixed-speed units, the escalation thresholds, the air-node share, the latent COP, infiltration, internal gains, thermal bridges, absorptance, door exchange, capacity derating, and the daily swing and level of the weather) were varied together over the ranges given in Appendix I, by a Latin hypercube of 128 samples per city; the per-sample results are in the repository. The reference policy is admissible in every sample; the pre-code building, which serves only as the envelope comparison, leaves the safe set in 66–68 of them, and as the safe set requires, those comparisons are excluded: the envelope lever is taken over the other 60–62 samples. Table 15 gives the median and the 5–95 % range of each result. None of the pre-cooling settings tested in each sample (0.5–2 K, night or pre-peak) saves in any of the 256 samples; a 2 K pre-peak pre-cool costs in every sample, and the ordering envelope, then setpoints, then timing holds in every sample in which all the compared runs are admissible. The setpoint lever depends most on the indoor COP slope γ and the infiltration (ACH), the cost of pre-peak pre-cooling on the indoor COP slope γ and the air-node share of capacitance (partial rank correlations, Riyadh; both cities in Appendix I).

Table 14: Sensitivity analysis (SBC-compliant building, Case 3): HVAC energy intensity [kWh/m²yr], setpoint lever, saving of the best thermostat pre-cool (0.5–2 K in either window), and the change in cost of a 2 K pre-peak pre-cool. C_d : cycling degradation coefficient; sized by load: at 2.5 times the peak hourly load, the first tested margin that keeps every room within the safe set, unless stated; –: inadmissible, the reference policy lets a room pass the ceiling, so the run is excluded and nothing but its excursion (in the text) is reported. Selected variants; all 37 are in Appendix H.

Variant	Riyadh				Jeddah			
	Int.	Setp.	Pre-cool	2 K	Int.	Setp.	Pre-cool	2 K
Reference (base case)	25.1	12.4%	0.00%	+3.4%	37.7	10.5%	0.00%	+4.3%
One node, COP independent of indoor air	23.8	8.2%	0.08%	+1.8%	36.1	8.0%	0.00%	+5.0%
Escalation at 0.2 / 0.6 K	26.0	12.6%	0.00%	+3.1%	38.5	10.8%	0.00%	+4.4%
COP independent of indoor air	23.6	9.5%	0.00%	+2.2%	36.0	8.1%	0.00%	+3.0%
Indoor COP factor 3%/K	25.9	14.0%	0.00%	+4.1%	38.6	11.8%	0.00%	+5.1%
No cycling loss ($C_d = 0$)	21.3	12.5%	0.00%	+4.0%	33.2	10.1%	0.00%	+4.8%
3-ton units as inverter units	21.3	12.4%	0.00%	+4.5%	33.4	10.0%	0.00%	+5.2%
Sized by load, all inverter	20.9	11.7%	0.00%	+2.9%	33.5	9.6%	0.00%	+3.0%
Sized by load, fixed-speed kept	24.5	11.9%	0.00%	+2.6%	37.6	10.1%	0.00%	+2.9%
Sized by load, 15% margin	–	–	–	–	–	–	–	–
Indoor fan on while compressor off	28.0	10.9%	0.00%	+3.3%	43.2	8.8%	0.00%	+4.1%
Infiltration 0.8 ACH	31.5	10.0%	0.00%	+3.4%	52.4	10.2%	0.00%	+3.8%
Heat wave +3 K, swing $\times 1.3$	33.4	12.2%	0.00%	+3.1%	46.7	9.7%	0.00%	+4.1%

Table 15: Global uncertainty analysis (SBC-compliant building, Case 3, 128 Latin-hypercube samples of 17 assumed inputs per city): median and 5–95 % range of each result [%], over the samples in which both compared runs are admissible (envelope: 62 and 60 samples in Riyadh and Jeddah; all others: 128). Levers are savings; pre-cooling rows are the saving of the best admissible pre-cool and the cost of a 2 K pre-cool. Ranges of the inputs and the partial rank correlations: Appendix I.

Result	Riyadh		Jeddah	
	Median	5–95 %	Median	5–95 %
Setpoint lever	10.8	7.9–13.4	9.6	7.6–11.7
Envelope lever	54.3	49.5–60.3	42.4	35.6–51.5
3-ton units as inverter units	14.6	8.7–19.9	10.6	6.5–15.2
Best pre-cool (0.5–2 K)	0.0	0.0–0.0	0.0	0.0–0.0
2 K pre-peak pre-cool, cost	2.5	1.7–4.3	3.1	1.9–5.3
2 K night pre-cool, cost	4.5	2.3–6.9	4.4	2.5–6.7

10 Discussion

The results raise three questions: why they differ from the larger scheduling savings in the literature, what the volume tariff rewards, and where the findings apply. The section answers them in turn and ends with the limits of the study.

10.1 Reconciling with the literature’s double-digit claims

The apparent conflict with studies that report large scheduling savings disappears once the levers are separated. Where such studies start from a low setpoint or a leaky envelope, part of their “scheduling” saving is the setpoint or envelope saving measured separately here. Where they assume time-of-use or real-time prices, the benefit comes from a tariff Saudi households do not face. Where they let rooms float to the comfort limit through the peak or switch empty rooms off, the saving comes from warmer rooms or vacancy, excluded here by the hard ceiling and (A4), not from moving cooling

in time. The same reading explains the larger coordination savings reported for Saudi homes under the same two-tier tariff [8]: about 4.3% for a five-zone villa and 1.0% for a twenty-zone building with a 23–25 °C band, and 13.4% and 7.8% with a wider band. That study coordinated on/off units against uncoordinated thermostats, partly near and above the 6,000 kWh threshold, which no apartment meter here reaches; its wide-band savings come mostly from the level at which rooms are held, and its narrow-band building saving is of the order of our perfect-foresight benchmark under the COP assumption most favourable to pre-cooling (Table 10).

10.2 What the volume tariff rewards

Under a tariff that prices energy alone, the theory predicts, and in the base model the simulations confirm, that the best thermostat policy is the fixed frontier policy of Theorem 3: the setpoint whose cycle just fills the band, no pre-cooling, and the lowest mode that holds the room. It needs no forecast, and a thermostat that pre-cools by default, a feature suited to time-varying prices, raises the Saudi bill (Table 11). The household’s levers are therefore the setpoints (cooling 22 → 23.5 °C and heating 20.5 → 22.5 °C, baseline B1 to B2) and, where the unit offers the setting, keeping the indoor fan from running while the compressor is off. For owners and code bodies the envelope, a one-off decision, is worth the most, and the equipment comes next: units chosen by rated coverage cycle at a fraction of their capacity, and inverter units sized by load would save more than their size alone accounts for (Section 9.7). The equipment figures rest on assumed part-load ratios, cycling coefficients and escalation thresholds rather than on measured data for the catalogue units; varied jointly in the uncertainty analysis (Table 15), the inverter lever spans 6.5–19.9% (5–95 % range over both cities), so its size is uncertain but its sign is not; against the setpoints its rank depends on the measure (percentage of HVAC electricity or SAR). For designers, the heat budget of Section 6.1 explains what passive zones can achieve: a bath or corridor stays close to the band only if most of its heat can

pass to conditioned rooms, through its walls or an open door, and little heat enters it from outdoors.

10.3 Where the findings do and do not apply

The optimal policy of Theorem 3 rests on conditions that can be checked for any building:

- (i) the tariff prices energy alone, as the Saudi residential tariff does in every tier (Theorem 3, Section 9.7);
- (ii) the 24 °C ceiling is hard in rooms that are occupied and conditioned at all hours (A4), so they may not float above the band during the peak;
- (iii) the units' efficiency falls with the mode, and cycling losses fall with the runtime, so the lowest mode that holds the room is the cheapest (Theorem 1, Corollary 1);
- (iv) the neighbouring apartments are occupied and conditioned, so the coupling between them carries little heat (Section 6.1);
- (v) pre-cooling is done by a thermostat setback; with $\gamma = 0$, the perfect-foresight benchmark bounds what any schedule of the idealised model could gain from the day–night swing of the COP, and with the engine's indoor COP slope it finds a smaller achievable saving (Section 9.3, Theorem 2); neither that bound nor Theorem 2 covers the cycling-loss source (c) of Proposition 1, and the benchmark covers one apartment, the typical floor and the top floor under the roof, and the whole building for the bound only;
- (vi) the building is feasible (Eq. (7)) and an admissible policy exists at the reference setpoints (Section 5.8).

Condition (vi) separates two properties. The tightly sized units of Section 9.5 are feasible, yet no policy at the reference setpoints is admissible, because the modelled controller switches on at the ceiling itself and a running unit escalates from a lower mode with a lag within a step; this is why units sized by load need a margin of 2.5 times the peak hourly load (Section 9.7). A 23 °C setpoint restores admissibility for the tightly sized units, as would a switch-on point below the ceiling, while no lattice setting does. At the floor, the guard of Section 5.7 holds $V_{\min}$ at the reference and the ordinary policies, while the deep night pre-cooling policies of the pre-code building that still pass it, and the other pre-cooling policies of that building that pass the ceiling, are inadmissible and excluded. The policy must be re-derived where another condition fails: under time-of-use or coincident-peak tariffs, next to vacant apartments or with empty rooms switched off, and for central plants with thermal storage.

10.4 Limitations and future work

Internal validity (whether the model attributes each saving to the right cause). Each room is a two-node zone after ISO 13790; the walls have no layered conduction and the windows no reveal shading or curtains. The sign of the thermostat result rests on the structure being a separate node or on the COP falling in a colder room, both physically founded: only a one-node zone with a COP that ignores the room temperature lets a shallow pre-cool save, and then

by a trivial amount (Section 9.7). The engine agrees with EnergyPlus on the storey geometry and the BESTEST cases (Section 8.2), but the BESTEST cases run on Riyadh weather, so the acceptance ranges of Standard 140 do not apply, and the engine overstates the extra heat that a setback removes; scaled to EnergyPlus, pre-cooling still costs (Appendix H). The part-load ratios of the modes, the escalation thresholds, the indoor COP slope, the cycling coefficients, standby and derating are assumed rather than measured; the cycling loss is charged through the runtime fraction and the shortest cycle is set by the 3-minute step, so starts per hour are numerical, and the absolute size of the cycling loss is the least certain equipment input. None of the one-at-a-time variants changes the ordering of the levers or makes thermostat pre-cooling pay, and the global analysis varies the assumed inputs jointly, over ranges that are themselves judgements; the capacitance, the ground model and the weather year are varied only one at a time or not at all, and rank correlations, unlike variance-based indices, do not apportion the interactions. The latent load is priced at a fixed latent COP with the humidity target assumed met; in Jeddah the units' sensible runtime alone does not meet it, so a higher setpoint is credited with no loss of dehumidification and the Jeddah results hold for sensible comfort, with humidity priced but not constrained. Heating COP and capacity do not depend on the outdoor temperature and there is no defrost, which affects only Riyadh's small heating energy; the timing result is a cooling-season result.

External validity (whether the result carries over). Every room is occupied and conditioned at all hours (A4); switching empty rooms off and vacant apartments are outside the study, and a fair assessment needs a validated pull-down of single rooms and a moisture model for the hours a unit is off. One representative building, designed for this study rather than surveyed, is modelled; villas, high-rise blocks and mixed stocks are not covered, although the conditions of Section 10.3 can be checked for each. The thermostat comparison covers the uniform, fixed-window lattice of Section 7.2 with ramped and dawn setbacks, and two spatial subsets. The perfect-foresight benchmark covers the design days of Cases 1 and 2 and of the top floor under the roof, the 31-day July horizon of Case 1 and, for the bound only, Case 3, with idealised units and linearised door flows; its $\gamma = 0$ result bounds the idealised model only, and neither it nor the thermostat comparison establishes what a closed-loop predictive controller on discrete, cycling units would achieve. One typical year per city is used, with a wider swing and a heat wave as weather tests.

Construct validity (whether the measured quantities represent the intended ones). Comfort is the air temperature against a fixed band rather than the predicted mean vote, with the operative temperature estimated separately (Section 9.1). "SBC-compliant" refers to the walls, roof and glazing; slabs and partitions keep the uninsulated construction of the stock (Section 4.3). The model is compared with EnergyPlus and with the stock energy use, not with metered apartments, so the bills in SAR are indicative; the ordering of the levers and the relative savings are the robust results.

Future work follows from these limits, in order of priority: (1) occupancy-based operation with measured routines, vacant apartments and validated room pull-down; (2) field data from monitored apartments or a room-resolved EnergyPlus

model; (3) a coil model with mode-dependent dehumidification and a humidity limit; (4) the costs and payback of the envelope and equipment levers; (5) model-predictive control with forecast error on the discrete, cycling units, tested against the small margin the benchmark leaves to re-timing [8]; and (6) multi-year weather.

11 Conclusion

We asked how much the operation of multi-mode heat pumps can save in a Saudi apartment building under the volume tariff, and which lever produces the saving. The theory shows that, without re-timing, the cheapest policy holds every room at the top of the comfort band in the lowest mode that holds the room, and bounds what pre-cooling can gain under any energy-only tariff; the room-resolved simulations of one apartment, one floor and the whole building in Riyadh and Jeddah find (Tables 6 and 8):

- (1) *Setpoint level.* Moving from current practice (cooling at 22, heating at 20.5 °C) to the reference setpoints (23.5 and 22.5 °C) saves 12.2–12.4% of the HVAC energy in Riyadh and 9.8–10.5% in Jeddah across the three cases, 152–234 SAR a year per apartment. With a 1 K thermostat differential and 0.5 K steps this is also the comfort frontier; only finer control would allow more.
- (2) *Envelope.* The SBC envelope saves 50.4–56.4% (Riyadh) and 38.3–45.0% (Jeddah) of the HVAC energy of the same building with the pre-code envelope, 998–2,612 SAR a year per apartment.
- (3) *Pre-cooling.* No thermostat pre-cooling policy pays under the volume tariff in the base model; in the sensitivity analysis the only exception, a one-node zone whose COP does not depend on the room temperature, saves at most 0.08%, and with every choice most favourable to pre-cooling combined the best policy saves 0.77% in Riyadh and 0.03% in Jeddah. 2 K of pre-peak pre-cooling adds 3.4–4.3%, and still 2.9–3.8% if its extra heat is scaled to EnergyPlus. On the solved periodic design days no schedule of the idealised model could save more than 1.9% within the band and 3.6% down to 20 °C (the upper bound with a COP of the outdoor air only); with the engine’s indoor COP factor the achievable saving, that of the best valid schedule found, is at most 0.6% and 0.7%, and a dawn setback fixed in advance on a simulated thermostat costs 0.99–1.80% (Case 3).
- (4) *Equipment.* In the SBC-compliant building, units sized by load at 2.5 times the peak load, the first of the tested margins that keeps every room within the safe set, would use 11.2–16.5% less energy as inverter units, 0.2–2.1% of it from their size alone; replacing only the fixed-speed 3-ton units by inverter units saves 11.4–15.0%, and an indoor fan left running adds 11.8–14.7%.
- (5) *Passive zones.* Holding their neighbours at the setpoint through walls and open doors, the controller removes 96% of the baths’ excursion above the band; a small unit in each bath would remove the rest for 2.8–4.9% more energy (Appendix C).

The operating mode is set by the controller, not the household:

the lowest mode that holds the room is optimal, and holding the highest mode costs more (Table 11). The four levers of the factorial together lower the building’s annual HVAC bill from 26,788 to 8,889 SAR in Riyadh and from 33,616 to 13,924 SAR in Jeddah; a factorial decomposition on that base places the envelope first and timing last (Table 12), and a global uncertainty analysis of 17 assumed inputs leaves that ordering unchanged in every comparison within the safe set, and none of the pre-cooling settings tested in each of its 2×128 samples saves (Table 15). These findings hold for an energy-only tariff, every room occupied and conditioned at all hours, a hard 24 °C ceiling and catalogue units sized by coverage, and the timing result holds in the base model. For Saudi households and code bodies the implications are to improve the envelope, above all under the roof (the top-floor apartments carry the largest envelope penalty), size units by load with enough margin for the controller, raise the setpoints (cooling 22 → 23.5 °C, heating 20.5 → 22.5 °C), switch off pre-cooling and keep the indoor fan on automatic; moving cooling in time pays substantially only under a tariff that prices the time of use or the peak (Section 9.7).

Statements and Declarations

Funding. The author acknowledges the Deanship of Graduate Studies and Scientific Research, Taif University, for funding this work.

Competing interests. The author declares no competing interests.

Author contributions. H. Faraj is the sole author and carried out the conceptualisation, methodology, software, validation, formal analysis, writing and editing.

Ethics approval and consent. Not applicable. The study involves no human participants, personal data or animals.

Data availability. Parameters and their sources are in Table 3, the plan and the units in Section 4.3, and the tariff in Section 5.6. The paper is accompanied by a public repository (<https://github.com/drhamzahfaraj/Comfort-Constrained-Operation-of-HVAC-in-Saudi-Residential-Buildings>). The appendices give the passive zones (Appendix C), the full perfect-foresight benchmark table (Appendix D), the building geometry, every room with its windows, unit and gain factor, and the weather including the ground temperature (Appendix E), the formal definitions and running examples (Appendix F), the validation details (Appendix G), the full sensitivity and robustness tables (Appendix H), the uncertainty-analysis input ranges and partial rank correlation coefficients (Appendix I) and the calculation time (Appendix J); the per-sample uncertainty results are in the repository. The repository contains the code, the configuration files (floor plan, parameters and run matrix), the TMYx weather files, the drawings, the EnergyPlus inputs and outputs, every result as JSON and CSV files, the inputs and results of all uncertainty samples, every solve of the perfect-foresight benchmark, the LaTeX source of the

paper, and the tests, and will be deposited with a citable DOI on publication. Every result is regenerated by the pipeline.

Code availability. The simulation model, the analysis pipeline and the scripts that generate every figure, table and quoted number are in the repository and will be deposited with the data. A test suite checks the plan geometry, the engine, the main theoretical identities and the headline results.

Use of generative AI. Claude (Anthropic) was used to assist with code development, structuring and language editing. All model design, results, validation and interpretation were carried out without it, and the author takes full responsibility for the content.

Table 16: Nomenclature.

Symbol	Meaning	Symbol	Meaning
$\mathcal{Z}, \mathcal{Z}_c, \mathcal{Z}_u$	zones; conditioned; passive	$V_i; W_i$	air; structure temperature of zone i [$^{\circ}\text{C}$]
$C_i; C_i^a, C_i^m$	thermal capacitance; its air and structure parts [kWh/K]	K_i^{env}	zone–outdoor conductance [kW/K] [†]
K_i^w, K_i^o	window and infiltration; opaque conductance [kW/K]	K_i^{am}	air–structure conductance [kW/K]
$S_i^o, S_i^w, S_i^{\text{sky}}$	opaque sol-air, window solar, window sky drives [kW]	$f_r; \beta_i$	radiant share of gains; run fraction of a step
K_{ij}	coupling conductance of zones i, j [kW/K]	K_i^{grd}	zone–ground conductance [kW/K]
G_i, S_i	internal, solar gains [kW]	L	heat gain of a zone [kW]
q_i^{env}	heat entering via envelope and ground [kW]	q_{ji}	heat carried through a door [kW]
M, m	mode set $\{0, 1, 2, 3\}$; a mode	f_m	capacity fraction of mode m
$Q_i; Q_i^h$	cooling; heating capacity of unit i [kW]	COP_m	coefficient of performance
$\psi; g, \gamma$	capacity derating with T_a ; indoor COP factor, its slope [K^{-1}]	$C_d; \text{PLF}; \text{RTF}$	cycling degradation; part-load factor; runtime fraction
(m, t)	timed action: mode m for time t	$\Delta; \Delta_{\text{th}}$	amplitude of a leap cycle; thermostat differential [K]
σ	schedule (finite or infinite)	$\pi_i(m)$	cost per unit time, unit i , mode m
θ^*	selected policy (frontier setpoint, best depths)	λ	energy price [SAR/kWh]
$\bar{V}; \bar{V}^*$	level (time-mean temperature) of a leap cycle; highest admissible level (comfort frontier)	$U; d_m$	utilisation; duty in mode m
$[V_{\text{low}}, V_{\text{high}}]$	comfort band [22, 24] $^{\circ}\text{C}$	$[V_{\text{min}}, V_{\text{max}}]$	safe set [20, 24] $^{\circ}\text{C}$
θ	policy ($V^{\text{cool}}, V^{\text{heat}}, \delta_{\text{night}}, \delta_{\text{peak}}$)	$E_{r,k}$	energy of meter r in month k [kWh]
Π	annual bill [SAR]	T_a, T_g	outdoor, ground temperature [$^{\circ}\text{C}$]
$u_i(t); s_i(t)$	mode of unit i ; +1 cooling, −1 heating	$c_m, h_m; \varphi$	cooling, heating COP coefficients; derating
ω_a, ω^*	outdoor, indoor humidity ratio [kg/kg]	n_{ach}	infiltration [air changes per hour]
$\delta =$	pre-cooling depth pair [K]	U-value	thermal transmittance [$\text{W}/\text{m}^2\text{K}$] (not U_i)
$(\delta_{\text{night}}, \delta_{\text{peak}})$		COP_{lat}	latent (dehumidification) COP
$V^{\text{cool}}, V^{\text{heat}}$	cooling, heating setpoint [$^{\circ}\text{C}$]	$x_t; q_{it}; v_{\text{min}}$	nodal temperatures; heat removal; pre-cooling floor (benchmark)
J_{∞}	long-run mean electrical power [kW]	Π^{vol}	annual bill under the volume tariff [SAR]
V_0	initial state of a run (not a setpoint)		

[†] Conductances are quoted in W/K in the running example. Symbols used only locally are defined where they appear.

A Nomenclature

Table 16 lists the symbols used in more than one section.

B Proofs

Proof of Theorem 1. Over one period T of the cycle the stored heat returns to its initial value, so the heat removed equals the heat gained: $\int_0^T f_m \psi Q_i \mathbb{1}_{\text{on}} dt = \int_0^T L(V(t)) dt$. With the outdoor conditions and the neighbours’ levels constant (A3, A4), $L(V) = a - bV$ is affine with $b = K_i^{\text{env}} + K_i^{\text{grd}} > 0$, so $\int_0^T L(V(t)) dt = T L(\bar{V})$. The electrical energy of the cycle is the heat removed divided by COP_m , and dividing by T gives Eq. (8). (i) For a cycle between $V_{\text{high}} - \Delta$ and V_{high} both legs are exponential and, to first order in Δ , linear in time, so $\bar{V} = V_{\text{high}} - \Delta/2$. The numerator of Eq. (8) decreases with the level: when every conditioned zone is raised by $d\bar{V}$ (A4), the exchange with conditioned neighbours is unchanged, each passive zone, whose monthly mean temperature is by its heat budget (Appendix F) a weighted mean of its neighbours’ and the outdoor and ground temperatures, rises by at most $d\bar{V}$, and the envelope and ground inflows fall by $b d\bar{V}$; hence $dL/d\bar{V} \leq -b < 0$. The denominator decreases with the mode, since $c_1 > c_2 > c_3$. Hence $\bar{P}$ is minimised by the highest admissible level and, at that level, by the lowest mode that holds the room; a mode with $f_m \psi Q_i \leq L$ cannot complete the cycle and violates the ceiling. A thermostat with differential Δ_{th} centred on its setpoint cycles between the setpoint $\pm \Delta_{\text{th}}/2$, so its highest admissible setpoint is $V_{\text{high}} - \Delta_{\text{th}}/2$, which is also its level. (ii) With constant ambient conditions, integrating the heat balance of an arbitrary safe infinite schedule over $[0, T]$ gives the heat removed as $\int_0^T L(V(t)) dt$ plus a change in stored heat that stays bounded because V stays in the safe set. Dividing by T and letting $T \rightarrow \infty$, the long-run mean heat removed equals the long-run mean of $L(V(t))$, at least $L(V_{\text{high}})$ because L decreases with V and $V \leq V_{\text{high}}$. Since $\text{COP}_1 \geq \text{COP}_m$, the electrical power is at least the heat removed divided by COP_1 . By (i), mode-1 cycles at the ceiling approach this bound as $\Delta \rightarrow 0$; with a given differential no schedule holds a higher mean than the optimal leap, and any schedule that holds the zone below $\bar{V}^*$ for a positive fraction of time raises the mean of $L(V(t))$ and therefore J_{∞} . $\square$

Proof of Corollary 1. By Eq. (8) the mean power of each zone is fixed by its level and mode; summing over zones and time gives the cost, in which neither the number of cycles nor the assignment of heat to units appears. The PLF rises with the runtime fraction $L/f_m\psi Q_i$, which is largest in the lowest mode. $\square$

Proof of Theorem 2. Over a periodic cycle the heat removed equals the heat gained (the coupling between conditioned zones held at a common level cancels under (A4), Section 6.1). Pre-cooling lowers V_i for part of the cycle, so the zone gains $\Delta H \geq 0$ more heat, and because the ceiling is hard it cannot compensate by rising above V_{high} later. In the window the unit removes $C_i\delta$ plus the part ΔH_w of the extra heat admitted there, at COP_w ; later it removes $C_i\delta$ less, minus the part $\Delta H_r = \Delta H - \Delta H_w$ admitted during the recovery, at a COP of at least COP_p . Hence $\Delta E \geq (C_i\delta + \Delta H_w)\eta_w - (C_i\delta - \Delta H_r)\eta_p$, which rearranges to Eq. (9). $\square$

Proof of Theorem 3. By Eq. (5) the bill depends on the policy only through the meter energies $E_{r,k}$, each the heat removed by the meter’s units in month k divided by their mean effective COP, so the timing of the leaps within a month matters only through these two quantities. By Theorem 1, applied hour by hour to the level at which a zone is held (which requires (A3), so that for long cycles this step is an approximation), each unit’s mean power, and hence each meter’s energy, decreases as its level rises. A bill that is non-decreasing in every $E_{r,k}$ is therefore minimised at the highest level allowed by (C2), $\bar{V}^*$; this is (i). By Theorem 2, any $\delta_{\text{night}} > 0$ or $\delta_{\text{peak}} > 0$ that satisfies its no-gain condition gives $\Delta E \geq 0$ for every affected meter and so does not lower the bill, and raises it if the tariff is strictly increasing and $\Delta E > 0$. The argument is applied zone by zone: under (A4) the conditioned zones are held at a common level, so the coupling between them carries no net heat (Section 6.1) and a meter’s energy is, to that approximation, the sum of its zones’ terms; coupling to zones of other meters cancels only in the sum over the building. Where the no-gain condition fails, Theorem 2 gives $\Delta E \geq -C_i\delta(\eta_p - \eta_w)$ for each zone, the stated bound. Nothing in the argument uses the tariff beyond its monotonicity in energy, which is (ii). $\square$

Proof of Proposition 1. By Theorem 1, the mean electrical power of zone i over a cycle is L_i/COP_{u_i} , and summing over cycles and zones gives E . The heat gain L_i decreases as V_i rises and as K_i^{env} falls, and COP_m decreases with m (Eq. 1). Pre-cooling lowers V_i below the setpoint for part of the day and so raises L_i there (Theorem 2). No other term of E depends on the policy. $\square$

C Passive zones with and without the controller

The model imposes the comfort band on the conditioned rooms, and the passive zones exceed it on warm days. Table 17 shows how much of this excursion the controller removes without acting on them (32 baths of the whole building). With every unit off all year the baths average 39.3–41.3 °C in July and peak at 41.7–44.3 °C. With the controller holding their neighbours at the reference setpoint they average 24.7–24.9 °C in July, and their excursion above the band falls by 96%. They shed their heat to the conditioned neighbours through the walls and, above all, through the open doors (as the heat budget of Appendix F predicts): with the interior doors closed the excursion is 4.3 times larger. A 1-ton unit in every bath would hold them in the band for 2.8–4.9% more energy, and colder neighbours (current practice) would cost 11.7–14.2% more.

Table 17: The baths of the SBC-compliant building (Case 3, the whole building; 32 baths) with and without the controller: July mean and annual peak temperature [°C], share of the year above the 24 °C ceiling [%], mean excursion above the ceiling per bath [K·h/yr], and the building’s HVAC energy relative to the controller of this study [%].

Case	Riyadh					Jeddah				
	July	Peak	> 24 °C	K·h	Energy	July	Peak	> 24 °C	K·h	Energy
No controller (all units off)	41.3	44.3	83	79,141	–	39.3	41.7	99	96,640	–
Controller, interior doors closed	27.7	31.9	68	15,164	+0.1	27.1	31.4	97	18,350	–0.3
Controller, reference setpoint (this study)	24.9	26.3	62	3,509	0	24.7	26.3	91	4,248	0
Controller at current practice (22 °C)	23.5	25.0	6	118	+14.2	23.3	24.9	4	52	+11.7
Controller and a 1-ton unit in every bath	23.6	24.0	0	0	+2.8	23.7	24.0	0	0	+4.9

D Perfect-foresight benchmark on every design day

Table 18 gives the perfect-foresight benchmark of Section 9.3 on every design day solved; Table 10 shows a selection of these rows, and the ranges it quotes are taken over all of them. The $\gamma = 0$ columns are rigorous upper bounds on what any schedule of the idealised model could save; the $\gamma = 0.02$ columns are achievable savings, those of the best valid schedule found by sequential linear programming from two starts (the program re-solved with the indoor factor of its first solution, and the program without pre-cooling), each schedule priced with its own indoor factor. Holding the ceiling is itself a valid schedule, so the achievable saving is at least 0, and a schedule that keeps the rooms within the band is valid down to 20 °C as well, so at 20 °C it is at least the saving at 22 °C of the same day. The bracket between the two columns holds for every periodic horizon solved, the design days and the 31-day July horizon (within the band). The search improves on holding the

Table 18: Perfect-foresight benchmark (SBC-compliant building): saving [%] of the sensible cooling electricity that an ideal schedule achieves over holding the 24 °C ceiling with the same idealised units, with the rooms pre-cooled at most to the band floor (22 °C) or to the floor of the safe set (20 °C), with a COP that depends on the outdoor air only ($\gamma = 0$) or the COP of the engine ($\gamma = 0.02$, falling by 2%/K of indoor air below 27 °C). The $\gamma = 0$ columns are rigorous upper bounds on the saving of any schedule of the idealised model; the $\gamma = 0.02$ columns are achievable savings, those of the best valid schedule found (sequential linear programming, every schedule priced with its own indoor factor): at least the reference, 0, and at 20 °C at least the 22 °C schedule of the same day. Hold: electricity of the reference at $\gamma = 0.02$ [kWh/day]. Season: May–September mean days weighted by the reference energy of their month (Case 1); July, 31 days: the whole month as one horizon (Case 1, band floor only). Case 3: the bound only; the search at $\gamma = 0.02$ is not run. All design days.

		Riyadh					Jeddah				
			$\gamma = 0.02$ (achievable)		$\gamma = 0$ (bound)			$\gamma = 0.02$ (achievable)		$\gamma = 0$ (bound)	
Case	Day	Hold	22 °C	20 °C	22 °C	20 °C	Hold	22 °C	20 °C	22 °C	20 °C
1: apartment	May, mean day	16.8	0.13	0.13	0.79	1.47	13.7	0.06	0.06	0.59	1.04
	Jun, mean day	20.8	0.21	0.21	1.05	1.99	15.3	0.14	0.14	0.87	1.59
	Jul, mean day	22.3	0.28	0.28	1.26	2.41	16.8	0.10	0.10	0.78	1.43
	Aug, mean day	21.4	0.35	0.35	1.41	2.68	16.8	0.01	0.01	0.24	0.42
	Sep, mean day	17.1	0.13	0.13	0.82	1.52	15.0	0.01	0.01	0.34	0.56
	Jul, hottest day	25.4	0.46	0.47	1.50	2.86	19.3	0.54	0.54	1.79	3.34
	Season	–	0.23	0.23	1.07	2.07	–	0.06	0.06	0.58	1.03
	July, 31 days	22.3	0.33	–	1.31	–	16.9	0.23	–	0.96	–
2: floor	Jul, mean day	46.6	0.35	0.35	1.39	2.65	35.9	0.13	0.13	0.86	1.58
	Jul, hottest day	53.8	0.54	0.56	1.63	3.09	41.6	0.63	0.67	1.92	3.57
	Aug, mean day	44.9	0.43	0.43	1.56	2.95	36.2	0.00	0.00	0.27	0.47
Top floor	Jul, mean day	55.8	0.12	0.12	0.75	1.42	43.5	0.02	0.02	0.35	0.63
	Jul, hottest day	64.5	0.19	0.19	0.96	1.82	50.1	0.25	0.25	1.08	2.02
	Aug, mean day	53.7	0.16	0.16	0.82	1.56	43.8	0.00	0.00	0.07	0.12
3: building	Jul, mean day	204.8	–	–	0.94	1.78	157.3	–	–	0.50	0.91
	Jul, hottest day	235.6	–	–	1.16	2.21	181.1	–	–	1.34	2.50
	Aug, mean day	197.0	–	–	1.04	1.97	159.0	–	–	0.13	0.22

ceiling on 44 of the 48 design-day programs at $\gamma = 0.02$; on the others no valid schedule cheaper than the reference was found. Two checks support the linear model: linearising the door exchange about 0.2 or 1.0 K instead of 0.5 K moves the bound by at most 0.13 points, and the full nonlinear engine, run with ideal equipment holding the ceiling in its lowest mode, differs from the linear model’s reference by -3.1 to -0.9% ; the schedule and its reference share the linear model, so this error bears on their level more than on the saving.

E Building geometry and weather

This appendix gives the room dimensions and the room schedule of the building and the monthly weather and ground temperature that Section 4.3 and Fig. 2 summarise.

Room dimensions. Each apartment has a 5.00×5.00 m master bedroom reached through a 2.35×1.50 m lobby that also serves its 2.50×1.50 m bath; two 4.00×4.00 m bedrooms, Bed 2 on the north side beside the party wall and Bed 3 on the west side; a 2.00×2.00 m bath and a 2.00×2.00 m maid room along the party wall; a 5.00×5.00 m living room, open over its full width to a 2.20×5.00 m dining area on the party-wall side and joined by a sliding door to a 1.50×5.00 m west balcony enclosed by the exterior wall; a 4.00×4.00 m kitchen; a 6.90×5.00 m guest room; two further 2.00×2.00 m baths, one between the kitchen and the guest room and one beside the hall; and a corridor, hall and entrance that connect them (all clear dimensions). The common stair is 4.25×9.05 m clear. Exterior walls are 0.30 m thick, the party and stair walls 0.25 m and partitions 0.15 m. Four floors of 3.40 m (3.00 m clear) form the building. Windows are 1.50 m high (sill 0.90 m, head 2.40 m), 0.80–2.00 m wide in the rooms and 4.00 m on the balcony, which gives a window-to-wall ratio of 17.3% for the building. Table 19 lists every room with its zone area as modelled, its exterior faces and windows, its unit and the factor that scales its internal gain.

Weather. Table 20 gives the TMYx typical-year weather of Riyadh and Jeddah month by month. Riyadh’s monthly mean rises from 14.7 °C in January to 36.4 °C in July, with mean daily maxima above 43 °C in July and August and relative humidity near 12% in summer; Jeddah’s monthly mean never falls below 23.5 °C and its relative humidity stays between 54% and 70% all year.

Table 19: Rooms of apartment A and the stair core (apartment B mirrors A, with west and east exchanged). Clear size and clear area from the drawing; floor area of the zone as modelled, on wall centrelines (used for capacitance, internal gains and the energy intensity); exterior faces with the widths of their windows [m] (all windows 1.50 m high); split unit, by rated coverage of the clear area; gain factor: multiple of the per-area internal gain given in Table 3. Every room of every storey is the same; the ground-floor rooms also lose heat to the ground and the top-floor rooms gain it through the roof.

Room	Clear size [m]	Clear area [m ²]	Zone area [m ²]	Exterior faces (windows)	Unit	Gain factor
Master bedroom	5.00 × 5.00	25.0	27.3	N (2.00), W	2.5 t, inverter	1.0
Bed 2	4.00 × 4.00	16.0	17.7	N (2.00)	1.5 t, inverter	1.0
Master bath	2.50 × 1.50	3.8	4.5	W (0.90)	–	0.5
Lobby	2.35 × 1.50	3.5	4.1	–	–	0.3
Bath 2	2.00 × 2.00	4.0	4.8	–	–	0.5
Maid room	2.00 × 2.00	4.0	4.8	–	–	1.0
Corridor	irregular	–	23.0	–	–	0.3
Bed 3	4.00 × 4.00	16.0	17.5	W (1.80)	1.5 t, inverter	1.0
Balcony (enclosed)	1.50 × 5.00	7.5	9.3	W (4.00)	–	0.0
Living room	5.00 × 5.00	25.0	26.9	–	2.5 t, inverter	1.0
Dining area	2.20 × 5.00	11.0	12.4	–	1.5 t, inverter	1.0
Kitchen	4.00 × 4.00	16.0	17.5	W (1.80)	1.5 t, inverter	1.5
Hall and entrance	irregular	–	22.9	–	–	0.3
Bath 3	2.00 × 2.00	4.0	5.0	–	–	0.5
Guest room	6.90 × 5.00	34.5	37.5	S (2.00), W (2.00)	3.0 t, fixed-speed	1.0
Bath 4	2.00 × 2.00	4.0	4.8	W (0.80)	–	0.5
Stair and lobby (core)	4.25 × 9.05	38.5	42.0	S (2.00)	3.0 t, fixed-speed	0.3

Table 20: Measured climate driving the model (TMYx typical years): monthly mean, mean daily maximum and minimum dry-bulb temperature [°C], mean relative humidity (RH) [%], global horizontal irradiation (GHI) [kWh/m² per day] and undisturbed ground temperature at 2 m depth (Ground) [°C], the temperature under the ground slab.

	Riyadh						Jeddah					
	Mean	Max	Min	RH	GHI	Ground	Mean	Max	Min	RH	GHI	Ground
Jan	14.7	20.9	8.7	47	4.4	19.3	23.5	28.8	18.8	59	4.4	26.2
Feb	16.9	23.6	10.7	38	5.5	19.7	24.0	29.1	19.8	54	5.3	25.5
Mar	21.4	28.2	14.5	30	6.3	21.8	25.6	31.7	20.1	69	6.5	25.6
Apr	26.8	33.2	20.1	25	7.2	24.1	28.1	34.0	22.8	55	7.2	26.2
May	32.8	38.7	26.2	15	7.6	29.0	30.5	37.0	25.0	58	7.4	28.1
Jun	35.6	41.9	28.5	13	7.7	32.2	31.8	38.1	25.8	59	7.4	29.8
Jul	36.4	43.2	29.4	12	7.6	33.8	33.0	39.0	27.1	55	7.1	31.2
Aug	35.8	43.1	27.9	14	7.4	33.4	33.2	37.8	28.9	57	6.8	31.9
Sep	33.2	38.9	26.7	16	6.8	31.2	31.8	37.1	27.2	69	6.4	31.8
Oct	27.7	34.7	20.4	21	5.9	27.7	30.0	36.1	25.2	70	5.8	30.8
Nov	21.6	27.1	16.1	36	4.7	23.9	27.6	32.6	23.4	58	4.9	29.2
Dec	15.6	22.1	8.8	47	4.2	20.8	25.2	29.6	21.0	54	4.4	27.6

F Formal definitions and running examples

This appendix gives the formal definitions on which the model and the theory of Sections 5 and 6 rest, following the multi-mode formalism of Alur et al. [14, 16], Wojtczak [15] and Mousa et al. [11, 12] and the coupled-zone model of Nghiem et al. [17], together with the continuations of the running example (Bed 2 of apartment 2A) and the heat budget of a passive zone.

F.1 Zones, units and the multi-mode system

Definition F.1 (Coupled zone network). The zones $\mathcal{Z}$, their conditioned and passive subsets $\mathcal{Z}_c$ and $\mathcal{Z}_u$, the capacitances C_i , the couplings K_{ij} and the envelope conductances K_i^{env} are those of Section 5. Two zones are *adjacent* if $K_{ij} > 0$, and a zone with an exterior wall, window or roof is an *edge zone*. Heat flows from zone j into zone i at the rate $K_{ij}(V_j - V_i)$ through shared walls and slabs and by buoyant exchange through an open door between them, and leaves the building through the edge zones.

Definition F.2 (Multi-directional multi-mode unit). The unit of a conditioned zone (Section 5) is multi-directional: in mode $m \in M$ it moves heat out of the zone when cooling and into it when heating, with the capacity fractions $0 = f_0 < f_1 < f_2 < f_3 = 1$, and its electricity is the heat moved divided by the cooling or heating COP of Eq. (1). The thermostat decides the direction. For passive zones $f_m Q_i \equiv 0$.

Remark F.1. The orderings $c_1 > c_2 > c_3$ and $h_1 > h_2 > h_3$ of the COP coefficients mean that a unit is most efficient at low output.

Definition F.3 (Multi-mode system with costs). Following Mousa et al. [12], the building is a multi-mode system $\mathcal{A} = (\mathbf{M}, N, A, \pi, V_{\min}, V_{\max}, V_0)$. Here $\mathbf{M} = M^{|\mathcal{Z}|}$ is the set of mode vectors, one mode per unit; $N = |\mathcal{Z}|$ is the number of continuous variables, the zone temperatures $V = (V_1, \dots, V_N)$; A gives the rate of change of V under each mode vector, which is the heat balance of Eq. (2); $\pi_i(m)$ is the cost per unit time of unit i in mode m , given for the Saudi tariff in Section 5.6; the bounds $V_{\min}$ and $V_{\max}$ define the safe set $\mathcal{S} = [V_{\min}, V_{\max}]$ of the conditioned zones; and V_0 is the initial state.

Remark F.2. Apart from the door exchange, which is nonlinear in the temperature difference, the rates are affine in the temperatures, so the building is close to a *linear-rate* multi-mode system in the sense of Wojtczak [15]; when the heat gain is held constant over a short interval (assumption A3) the rates are constant and the theory of Alur et al. [14] applies.

F.2 Timed actions, schedules, runs and costs

Definition F.4 (Timed action and leap). A *timed action* is a pair $(m, t) \in M \times \mathbb{R}_{>0}$ of a mode m and a duration t : the unit stays in mode m for time t . A timed action is a *leap* when it moves the zone temperature from one bound of a band to the other, and a *drift* when $m = 0$ and the zone temperature floats.

Definition F.5 (Schedule and infinite schedule). A *schedule* of horizon $t_{\max}$ is a finite sequence of timed actions $\sigma = \langle (m_1, t_1), \dots, (m_k, t_k) \rangle$ with $\sum_j t_j = t_{\max}$. An *infinite schedule* is either an infinite sequence $\langle (m_1, t_1), (m_2, t_2), \dots \rangle$ with $\sum_j t_j = \infty$, or a finite sequence whose last duration is $t_k = \infty$. Each unit follows its own schedule.

Definition F.6 (Run, safe leap and safe schedule). The *run* of a schedule from the initial state $V^{(0)} = V_0$ is the sequence of states $V^{(0)}, V^{(1)}, V^{(2)}, \dots$ with $V^{(j)} = \Phi_{m_j}(V^{(j-1)}, t_j)$, the state reached by following the dynamics of mode m_j for time t_j from $V^{(j-1)}$; with constant rates, $V^{(j)} = V^{(j-1)} + t_j A(m_j)$. (The superscript indexes the run; the subscript i of V_i indexes zones. The labels $V_0, \dots, V_5$ of Fig. 4 are the states $V^{(0)}, \dots, V^{(5)}$ of one zone's run.) A timed action is a *safe leap* from a state if the trajectory stays in $\mathcal{S}$ for its whole duration. A schedule is *safe* if each of its timed actions is safe from the state its run has reached, and a safe schedule is *comfortable* if every conditioned zone also stays within the comfort band $[V_{\text{low}}, V_{\text{high}}] \subseteq \mathcal{S}$.

Definition F.7 (Cost of a schedule). The cost of a finite schedule of unit i is $\pi(\sigma) = \sum_{j=1}^k \pi_i(m_j) t_j$. The cost of an infinite schedule is its limit-average cost

$$\pi_{\text{avg}}(\sigma) = \limsup_{k \rightarrow \infty} \frac{\sum_{j=1}^k \pi_i(m_j) t_j}{\sum_{j=1}^k t_j},$$

and, for a finite sequence ending in (m_k, ∞) , $\pi_{\text{avg}}(\sigma) = \pi_i(m_k)$. Since $\pi_i(m)$ is the energy price λ times the electrical power, $\pi_{\text{avg}} = \lambda J_{\infty}$, with J_{∞} the long-run mean electrical power of the unit.

Remark F.3. The Saudi tariff has no charge per switch; Mousa et al. [12] also attach a cost to each switch between modes, which is therefore zero here, and the energy a unit loses by cycling is counted in its electricity through the part-load factor.

Definition F.8 (Optimal leap). With the leap cycle, its level $\bar{V}$ and the condition $f_m \psi Q_i > L(\bar{V})$ under which mode m holds the zone as defined in Section 5.5, an *optimal leap* is a pair $(\bar{V}, m)$ whose mode holds the zone and whose cycle stays in the comfort band at the least cost π_{avg} (Fig. 6 shows the cycles of the running example). In the heating season the roles of drift and leap are reversed.

Definition F.9 (Schedulability and utilisation). Following Alur et al. [14, 16], a zone is *safely schedulable* if it admits a safe infinite schedule. For states inside the safe set this holds if and only if there are dwell times whose rate vectors sum to zero over a period. For a single zone with drift rate $L/C_i > 0$ in mode 0 and rate $(L - f_m \psi Q_i)/C_i$ in mode m , this is the condition $f_m \psi Q_i > L$ of Section 5.5. The fraction of time the unit must spend in mode m , $d_m = L/(f_m \psi Q_i)$, is its *duty* in that mode, and the zone is schedulable in mode m if and only if $d_m < 1$. Over a leap cycle the *utilisation* $U_i = L/Q_i$ is the mean fraction of the unit's full capacity in use.

Remark F.4. Nghiem et al. [18] give sufficient schedulability conditions for coupled zones that share a peak-power budget. Here each unit serves one zone and no budget is shared, so Definition F.9 applies zone by zone.

Remark F.5 (why the cycle returns to the switching point). The run of Fig. 4 returns to the thermostat's lower switching point rather than descending to V_{low} or $V_{\min}$ in every cycle, because a deeper cycle holds the room colder on average and so admits more heat: for the running example a cycle down to V_{low} costs 2.6% more and one down to $V_{\min}$ 7.7% more, although the unit switches far less often.

F.3 Heat budget of a passive zone

Proposition F.1 (Heat budget of a passive zone). Let $u \in \mathcal{Z}_u$ be a passive zone and let overbars denote means over a period long compared with its time constant (a month), over which its stored heat changes negligibly. Then the heat that enters it balances the heat that leaves it:

$$\bar{q}_u^{\text{env}} + \bar{G}_u + \bar{S}_u = \sum_j K_{uj}(\bar{V}_u - \bar{V}_j) + \bar{D}_u, \quad (11)$$

where the left-hand side is the mean heat that enters from the outdoors, the ground and the zone's own gains, the sum is the heat it loses through walls and slabs, and $\bar{D}_u$ is the mean heat it loses through its open doorways. Consequently: (i) in the cooling season a passive zone with any exposure or gain is warmer than the conditioned rooms that take its heat; (ii) its temperature does not depend on the capacity of any unit, only on the temperatures the units hold; (iii) the more of its heat it sheds directly to conditioned rooms, through walls or open doors, the closer it stays to their setpoint; and (iv) passive zones that touch one another raise one another's temperature.

Proof. Averaging the heat balance of u (where no unit acts) over the period gives the change of its stored heat divided by the period on the left, which vanishes when the stored heat changes negligibly, and the mean of the right-hand side on the right. The conductive terms are linear in the temperatures with constant coefficients, so their means are the same expressions evaluated at the mean temperatures; the door term is kept as its mean $\bar{D}_u$. Setting the sum to zero gives Eq. (11). In the cooling season the left-hand side is positive, so the right-hand side must be positive too; since both wall and door exchanges carry heat from warmer to cooler air, $\bar{V}_u$ must exceed the temperature of the rooms that receive its heat, which is (i). No unit capacity appears in Eq. (11), which is (ii). For a given inflow, a larger share of exchange with rooms held at the setpoint requires a smaller excess $\bar{V}_u - \bar{V}_j$, which is (iii). A passive neighbour is itself warmer than the setpoint by (i), so heat shed to it requires a higher $\bar{V}_u$, which is (iv). It also follows that $\bar{V}_u$ is a weighted mean of its neighbours' and the outdoor and ground temperatures, which the proof of Theorem 1 (Appendix B) uses. $\square$

Running example (passive zones). In July in Riyadh ($\bar{T}_a = 36.4^\circ\text{C}$) the bath beside the kitchen of apartment 2A, with an exterior wall and a window, receives 127 W (80 W from the outdoors and 47 W of its own and solar gains). It sheds 22 W through its walls to conditioned rooms, 14 W to passive zones and 91 W through its open door, and averages 25.0°C . The least exposed bath, the shared bath, receives only 36 W and averages 24.4°C . By (i), each sits above the conditioned rooms that take its heat, and by (ii), a larger unit in a neighbouring room does not change that as long as the room is held at the same setpoint; Appendix C reports the passive zones of the whole building with and without the controller.

F.4 Running example: further continuations

Coupled neighbours. Bed 2 is coupled to its neighbours with 138 W/K, about 7 times its envelope conductance, yet on the typical floor the zones on either side of the apartment's party and core walls differ by only 0.09 K on average over the year (Riyadh). Removing the coupling across those walls altogether changes the apartment's annual energy by 0.9%, and tripling it by -1.0% : a strong coupling carries little heat when no temperature difference drives it, as Section 6.1 states.

Free-floating room and the indoor COP factor. With its unit off, Bed 2 would float towards 43°C in mean July conditions: its insulated wall loses little, so its own and solar gains alone would hold it far above the ambient. The mean powers of the running example of Section 6 are evaluated without the indoor COP factor g ($\gamma = 0$); with it, every mean power would be about 8% higher at 23.5°C and 11% at 22°C , which widens each difference.

Sources of saving. In July in Riyadh, Bed 2 gains 0.391 kW at 22°C and 0.363 kW at 23.5°C : each kelvin of warmth admits about 19 W less heat, and its mean electrical power falls from 83 to 77 W (lever a of Proposition 1). Holding the same level in mode 3 would cost 112 W (lever b). Pre-cooling the room admits the same 19 W per kelvin more, for as long as it lasts.

G Validation details

This appendix gives the details of the comparative tests of Section 8.2: the BESTEST-style test on the single-zone cases of Standard 140 and the settings of the storey-box comparison with EnergyPlus.

BESTEST-style comparative test. The engine of the model was run on the single-zone cases 600 (lightweight) and 900 (heavyweight) of ANSI/ASHRAE Standard 140, with their geometry, constructions, 12 m^2 of south glazing, 200 W of internal gains, 0.5 ACH and the $20/27^\circ\text{C}$ setpoints, and with the units switched off (600FF and 900FF), on the Riyadh weather instead of the standard's Denver file, and the same cases were run in EnergyPlus 26.1 (Table 21). This is a comparative test between two programs on the same inputs rather than the standard's acceptance test, whose reference ranges apply only to Denver.




Figure 6: Leap cycles of the running example (Bed 2 of apartment 2A, July, Riyadh).

Cases 640 and 940 add the standard's night heating setback (10 °C from 23:00 to 07:00), which exercises the response of light and heavy construction to a setback. Annual cooling, which dominates in Riyadh, differs by -0.2% (case 600), $+4.3\%$ (case 900), -0.1% (case 640) and $+4.3\%$ (case 940), and the peak hourly cooling by -11.3% and -10.4% . Free-floating, the mean temperature differs by -1.2 and -1.3 K and the annual maximum by -5.5 and -4.5 K. The engine therefore reproduces EnergyPlus's annual loads closely and its peaks and extremes to within the spread usually found between programs: its exterior surfaces have a fixed film coefficient and no surface temperature of their own, and its structure is one node, so it damps the sharpest afternoon peaks. Heating is small in Riyadh, and its differences are a few hundred kWh.

Table 21: BESTEST-style comparative test (Standard 140 cases on the Riyadh weather; differences computed from unrounded values): annual heating and cooling [MWh], peak hourly heating and cooling [kW], and the free-floating minimum, mean and maximum temperature [°C]. Cases 640/940: 600/900 with the night heating setback. E+: EnergyPlus 26.1; this: the engine of the model.

	Case 600		Case 900		Case 640		Case 940	
	E+	this	E+	this	E+	this	E+	this
Heating [MWh]	0.40	0.62	0.00	0.01	0.16	0.28	0.00	0.00
Cooling [MWh]	11.12	11.10	9.62	10.04	11.05	11.04	9.62	10.03
Peak heating [kW]	1.38	1.63	0.26	0.57	3.30	3.77	0.25	1.05
Peak cooling [kW]	6.57	5.83	4.02	3.60	6.57	5.83	4.02	3.60
	Case 600FF		Case 900FF					
Minimum [°C]	12.0	9.6	20.2	19.0				
Mean [°C]	39.1	37.9	39.2	37.9				
Maximum [°C]	71.1	65.6	51.6	47.1				

Settings of the storey-box comparison. EnergyPlus runs with 10-minute time steps, its default conduction-transfer-function heat balance and surface convection algorithms, full exterior solar distribution and the same TMYx files as the model (Riyadh Air Base, WMO 404380, record 1958–2022; Jeddah King Abdulaziz International Airport, WMO 410240, record 1981–2025). On the storey box the internal gains of the two programs are identical and their infiltration gains differ by 2.1–12.5%; the engine on the storey-box geometry finds an envelope effect of 53.6% in Riyadh and 53.0% in Jeddah, between those of EnergyPlus and of the room-resolved model.

H Full sensitivity analysis and pre-cooling robustness

This appendix gives the full one-at-a-time sensitivity analysis of Section 9.7 (Table 22; Table 14 shows the decisive rows), the diagnostics behind it (sizing margin, controller resolution and humidity), the seasonal operation of the building, every test instance, and the tests of the pre-cooling result where it is most likely to fail. All runs are of the whole building (Case 3); the sensitivity variants and the robustness tests are of the SBC-compliant building.

Table 22: Sensitivity analysis (SBC-compliant building, Case 3): HVAC energy intensity [kWh/m²yr], setpoint lever, saving of the best thermostat pre-cool (0.5–2 K in either window), and the change in cost of a 2 K pre-peak pre-cool. C_d : cycling degradation coefficient; sized by load: at 2.5 times the peak hourly load, the first tested margin that keeps every room within the safe set, unless stated; –: inadmissible, the reference policy lets a room pass the ceiling, so the run is excluded and nothing but its excursion (in the text) is reported. Door schedule: bath doors closed, bedroom and guest-room doors closed 23:00–07:00.

Variant	Riyadh				Jeddah			
	Int.	Setp.	Pre-cool	2 K	Int.	Setp.	Pre-cool	2 K
Reference (base case)	25.1	12.4%	0.00%	+3.4%	37.7	10.5%	0.00%	+4.3%
Interior doors closed	25.1	12.2%	0.00%	+3.1%	37.6	10.5%	0.00%	+3.9%
Internal gains –30%	23.0	11.4%	0.00%	+3.5%	35.0	11.0%	0.00%	+4.3%
Internal gains +30%	27.4	12.7%	0.00%	+3.2%	40.4	10.1%	0.00%	+4.3%
Flat part-load COP	31.5	12.6%	0.00%	+2.1%	45.0	11.0%	0.00%	+3.2%
Ground at constant mean temperature	26.0	17.0%	0.00%	+4.0%	42.2	12.5%	0.00%	+4.6%
One node per zone	25.5	11.2%	0.00%	+3.3%	38.0	10.4%	0.00%	+6.7%
One node, COP independent of indoor air	23.8	8.2%	0.08%	+1.8%	36.1	8.0%	0.00%	+5.0%
Air node 2% of C	24.7	12.5%	0.00%	+4.6%	37.2	10.7%	0.00%	+5.4%
Air node 15% of C	25.6	12.2%	0.00%	+2.7%	38.6	10.4%	0.00%	+3.7%
Air node 30% of C	25.5	12.3%	0.00%	+2.8%	38.5	10.5%	0.00%	+4.2%
Air–structure coupling $\times 0.5$	24.5	12.0%	0.00%	+3.3%	36.8	10.4%	0.00%	+3.8%
Air–structure coupling $\times 2$	25.5	12.6%	0.00%	+3.0%	38.3	10.5%	0.00%	+4.6%
Latent COP –30% off / low mode	25.1	12.4%	0.00%	+3.4%	41.6	9.5%	0.00%	+3.8%
Thermostat differential 0.1 K	26.4	11.4%	0.00%	+4.3%	38.8	10.5%	0.00%	+5.1%
Escalation at 0.2 / 0.6 K	26.0	12.6%	0.00%	+3.1%	38.5	10.8%	0.00%	+4.4%
Escalation at 0.8 / 2.0 K	25.0	12.3%	0.00%	+2.3%	37.7	10.4%	0.00%	+3.2%
Inverter units in low mode only	25.0	12.3%	0.00%	+2.0%	37.7	10.4%	0.00%	+2.8%
No full-capacity response	25.1	12.4%	0.00%	+3.4%	37.7	10.5%	0.00%	+4.3%
COP independent of indoor air	23.6	9.5%	0.00%	+2.2%	36.0	8.1%	0.00%	+3.0%
Indoor COP factor 3%/K	25.9	14.0%	0.00%	+4.1%	38.6	11.8%	0.00%	+5.1%
No cycling loss ($C_d = 0$)	21.3	12.5%	0.00%	+4.0%	33.2	10.1%	0.00%	+4.8%
$C_d = 0.25$ for every unit	26.4	12.4%	0.00%	+3.2%	39.3	10.5%	0.00%	+4.1%
3-ton units as inverter units	21.3	12.4%	0.00%	+4.5%	33.4	10.0%	0.00%	+5.2%
No standby power	24.3	12.8%	0.00%	+3.5%	36.9	10.7%	0.00%	+4.4%
No capacity derating	25.1	12.4%	0.00%	+3.3%	37.8	10.6%	0.00%	+4.1%
Indoor fan on while compressor off	28.0	10.9%	0.00%	+3.3%	43.2	8.8%	0.00%	+4.1%
Sized by load, all inverter	20.9	11.7%	0.00%	+2.9%	33.5	9.6%	0.00%	+3.0%
Sized by load, fixed-speed kept	24.5	11.9%	0.00%	+2.6%	37.6	10.1%	0.00%	+2.9%
Sized by load, 15% margin	–	–	–	–	–	–	–	–
Wall U-value +20% (thermal bridges)	25.6	12.3%	0.00%	+3.4%	38.2	10.6%	0.00%	+4.3%
Solar absorptance 0.5	24.3	12.3%	0.00%	+3.6%	36.8	10.6%	0.00%	+4.4%
Solar absorptance 0.9	25.9	12.5%	0.00%	+3.3%	38.6	10.4%	0.00%	+4.3%
Infiltration 0.2 ACH	22.5	12.9%	0.00%	+3.2%	30.4	10.7%	0.00%	+4.5%
Infiltration 0.8 ACH	31.5	10.0%	0.00%	+3.4%	52.4	10.2%	0.00%	+3.8%
Door schedule	24.8	12.3%	0.00%	+3.6%	37.4	10.4%	0.00%	+4.5%
Daily swing $\times 1.3$	26.0	11.8%	0.00%	+3.2%	38.2	10.4%	0.00%	+4.6%
Heat wave +3 K, swing $\times 1.3$	33.4	12.2%	0.00%	+3.1%	46.7	9.7%	0.00%	+4.1%

Sizing margin. Units sized by load are sized at a multiple of each room’s peak hourly load on the sampled days; of the margins tried in turn (1.15, 1.5, 2, 2.5), the first at which every room stays within the safe set is 2.5 in both cities. A finer sweep of the margin (1.15, 1.25, 1.5, 1.75, 2, 2.5, 3) shows what it buys. At the margins that keep every room within the safe set (2.5, 3) the units save 15.5–16.5% in Riyadh and 10.6–11.2% in Jeddah against the catalogue units; the smaller margins are inadmissible, and only their excursion is reported: it falls from 69 K·h in Riyadh and 18 K·h in Jeddah at 1.15 to zero from 2.5 on, so the smallest margin that keeps every room within the safe set lies between 2 and 2.5. Every unit is at the 0.75-ton minimum size at 1.15, so the building needs 45 tons at 1.15 and 63–66 at 3: in capacity the margins differ far less than their names suggest. The excursions are small, the warmest room peaking at 24.15 °C, and mostly in the guest rooms (98–100% of the excursion at the tightest margin). As in the hard instances of Section 9.5, they arise while a running unit escalates from a lower mode, not at start-up; Section 9.7 discusses what this implies for the margin. The change of compressor, which the 3-ton variant measures on its own, accounts for most of the difference between the units sized by load as inverter

units (16.5% in Riyadh and 11.2% in Jeddah against the catalogue units) and with the fixed-speed zones keeping fixed-speed units (2.1% in Riyadh and 0.2% in Jeddah), the two effects not being additive.

Controller resolution. The units start on average 2.0 (Riyadh) and 2.6 (Jeddah) times per hour of the year, a rate set by the 3-minute time step rather than by a measured cycle; without the 3-minute restart delay the bill changes by less than 0.01%. The twelve fixed-speed 3-ton units run 3–6% of the time and as inverter units would use 39% less; the four stair units, a feature of the building studied rather than of every Saudi apartment block, take 8.9–9.1% of the units’ electricity and are billed to the common meter. The robustness tests below show how far a 1-minute step, minimum on- and off-times and a cycling loss charged per start move the results.

Humidity. The main model prices the latent load at a fixed latent COP and assumes the indoor target is met. A diagnostic humidity balance per zone, with infiltration and the internal moisture of five occupants per dwelling entering and the coil removing moisture at a sensible heat ratio while the unit runs, tests that assumption. In Riyadh the target holds: the conditioned rooms exceed 60% relative humidity in 0.8% of the cooling-season hours. In Jeddah the sensible runtime of the oversized units is too short: at a sensible heat ratio of 0.75 the rooms exceed 60% in 41% of the hours (21% at 0.65), and the coil removes 82% of the latent load, so holding the target needs dedicated dehumidification, whose electricity the latent term prices. Internal latent gains would add 0.2% (Riyadh) and 3.2% (Jeddah) to the HVAC energy at every schedule, leaving every absolute saving unchanged. A 30% lower latent COP whenever the units are off or in the lowest mode raises Jeddah’s latent share to 33% and leaves the scheduling result unchanged. Run for the levers themselves (current practice, the reference setpoint and 2 K of pre-peak or night pre-cooling), the diagnostic hardly moves: at a sensible heat ratio of 0.75 the rooms exceed 60% in 0.7–0.9% of the cooling-season hours in Riyadh and 41.1–44.6% in Jeddah. At that ratio the higher setpoint lowers the Jeddah share slightly, since warmer air holds the same moisture at a lower relative humidity, while at 0.65 it raises it by 1.3 points; pre-peak pre-cooling raises it at both ratios, the coil then removing 76% of the latent load instead of 82%, so the setpoint lever costs little humidity comfort and pre-cooling gains none.

Seasonal operation. The model runs through the whole year with units that cool and heat (Table 23). In Riyadh summer accounts for 61% of apartment 2A’s HVAC energy and winter for 4%; Jeddah spreads its load more evenly (47% and 13%). Winter is a heating season only in Riyadh, and a substantial one only for the pre-code building, which uses 11,116 kWh of heating a year; the SBC-compliant building needs 1,367 kWh, because its internal gains and its neighbours keep most rooms above the heating setpoint. At the reference policy no conditioned room of the SBC-compliant building leaves the safe set in either season (cold excursion 0 and 0 K·h). Inverter units use the medium and high modes on 4.5–5.2% of the hours; the time shares of Table 23 include the fixed-speed units, which run only at full capacity. The latent load, computed from the measured humidity, is 0.4% of the HVAC energy in Riyadh and 26% in Jeddah.

Table 23: Summer and winter operation of the whole building at the reference policy: annual cooling, heating and latent electricity [kWh], and the share of time [%] the conditioned rooms spend off and in the low, medium and high modes (cooling and heating together; fixed-speed units count as high) in summer (Jun–Sep) and winter (Dec–Feb). The remainder of the HVAC energy is the units’ standby electricity, 1,577 kWh a year in the SBC-compliant building. Last column: summer / winter shares of apartment 2A’s HVAC energy.

City	Envelope	Cooling	Heating	Latent	Summer modes	Winter modes	Apt. 2A summer / winter
					off/low/med/high	off/low/med/high	
Riyadh	SBC	47,383	1,367	185	59/33/1/7	97/2/0/1	61.0% / 3.9%
		pre-code 103,038	11,116	185	40/32/15/13	81/14/1/5	–
Jeddah	SBC	54,784	0	19,551	63/31/0/6	82/14/0/4	46.8% / 12.6%
		pre-code 116,870	0	19,551	44/32/13/12	75/18/2/6	–

Test instances. Table 24 lists every test instance; Table 13 reports the eight instances with the catalogue units in one row.

Robustness of the pre-cooling result. Table 25 collects the tests of the thermostat pre-cooling result where it is most likely to fail (SBC-compliant building, Case 3). None of them saves, except the favourable combinations, which need every favourable choice at once and save at most 0.77%. The loss per start is the unit’s full power for 1.5 min at each start of a fixed-speed unit and 0.82 min of an inverter unit, calibrated to the part-load factor at the cyclic rating point; the controller variants move the absolute bill by 2–32%, the loss per start most, but not the sign of pre-cooling. With minimum on- and off-times the variant is inadmissible in Riyadh: its reference breaks the ceiling in the heating months (December to February), when the oversized fixed-speed units, held on for 3 minutes while heating, overshoot it (636 K·h a year). Scaled to EnergyPlus’s extra heat, a 2 K night pre-cool still costs 3.2% in Riyadh and 3.3% in Jeddah. With the favourable choices combined, the best ramped setback changes the bill by –0.55% (Riyadh) and +0.29% (Jeddah); with the 0.08% of the

Table 24: Every normal and hard test instance (Case 3, the whole building). Units: catalogue (sized by coverage) or sized to the building’s own peak hourly load with a 15% margin. Peak load ratio: largest hourly sensible load of any unit over its rated capacity; excursion of the reference policy above 24 °C and below 20 °C; best policy: the cheapest admissible thermostat policy, night/pre-peak depth (none: no pre-cooling; –: no lattice setting at the reference setpoints is admissible; in brackets, the highest admissible cooling setpoint without pre-cooling, where one exists); admissible policies: number of the 49 lattice policies that keep every conditioned room within the safe set on the sampled days (the others are excluded). No unit reaches a load ratio of 0.85.

Envelope	City	Units	Weather	Class	Peak load ratio	Exc. above/below [K·h]	Best policy	Admissible policies
SBC	Riyadh	catalogue	TMYx	normal	0.19	0/0	none	49 of 49
SBC	Jeddah	catalogue	TMYx	normal	0.19	0/0	none	49 of 49
SBC	Riyadh	catalogue	TMYx +3 K	normal	0.26	0/0	none	49 of 49
SBC	Jeddah	catalogue	TMYx +3 K	normal	0.26	0/0	none	49 of 49
Pre-code	Riyadh	catalogue	TMYx	normal	0.55	0/0	none	42 of 49
Pre-code	Jeddah	catalogue	TMYx	normal	0.53	0/0	none	36 of 49
Pre-code	Riyadh	catalogue	TMYx +3 K	normal	0.59	0/0	none	30 of 49
Pre-code	Jeddah	catalogue	TMYx +3 K	normal	0.62	0/0	none	33 of 49
SBC	Riyadh	by load	TMYx	hard	0.58	69/0	– (23 °C)	0 of 49
SBC	Jeddah	by load	TMYx	hard	0.57	18/0	– (23 °C)	0 of 49
Pre-code	Riyadh	by load	TMYx	hard	0.79	81/0	– (23 °C)	0 of 49
Pre-code	Jeddah	by load	TMYx	hard	0.75	29/0	– (23 °C)	0 of 49

one-node variant whose COP ignores the room temperature (Table 22), these rows hold the only savings found for thermostat pre-cooling. No policy cools a room of the SBC-compliant building below the 20 °C floor; in the pre-code building, on the sampled days, 7 (Riyadh) and 13 (Jeddah) of the 49 policies are inadmissible and are excluded: 7 in Jeddah let rooms drift below the floor on cool nights, by at most 0.2 K·h a year and to 19.9 °C, and the remaining 7 in Riyadh and 6 in Jeddah pass the ceiling. The cheapest admissible policy remains no pre-cooling.

Table 25: Robustness of the thermostat pre-cooling result (SBC-compliant building, Case 3, volume tariff). Best saving: saving of the cheapest admissible policy against no pre-cooling [%] (positive: saves; 0: no pre-cooling is best; negative: every depth run costs, for the rows that do not include no pre-cooling among their options; –: not run, or inadmissible because the reference policy leaves the safe set). 2 K pre-peak: change in the annual bill of a 2 K pre-peak pre-cool [%] (positive: costs). Favourable choices: one node per zone, COP independent of the indoor air, inverter units in their lowest mode, no cycling loss. Dawn setback: all 365 days; the other rows: sampled year.

Test	Riyadh		Jeddah	
	Best saving	2 K pre-peak	Best saving	2 K pre-peak
Base model, lattice of 49 policies	+0.00	+3.40	+0.00	+4.30
Inverter units in their lowest mode	+0.00	+1.95	+0.00	+2.84
Ramped pre-peak setback (0.5 K/h)	–0.25	+2.26	–0.34	+3.04
Extra heat scaled to EnergyPlus	–	+2.94	–	+3.82
Dawn setback, 2 K, all 365 days	–0.99	–	–1.80	–
Top floor only (15 units)	+0.00	+0.82	+0.00	+1.14
Rooms with west windows only (12 units)	+0.00	+1.02	+0.00	+1.29
Cycling loss charged per start	+0.00	+2.45	+0.00	+2.82
1-minute step	+0.00	+2.11	+0.00	+2.85
1-minute step, 3-min minimum on/off, loss per start	–	–	+0.00	+2.45
Favourable choices combined	+0.77	–0.21	+0.03	+3.07
Favourable choices, top floor only	+0.21	–0.20	+0.00	+0.50

I Uncertainty analysis

Seventeen assumed inputs of the SBC-compliant building (Case 3, sampled year) were varied jointly over the uniform ranges of Table 26 by a Latin hypercube of 128 samples per city (fixed seed). This appendix gives the input ranges and the partial rank correlations; the per-sample inputs and results are not reproduced here but are in the repository (results/parts/uncertainty_Riyadh.json and uncertainty_Jeddah.json). For each sample the reference, current-practice and 0.5–2 K pre-cooling policies (night or pre-peak), the pre-code building and the 3-ton units as inverter units were simulated. The weather inputs scale the daily swing of the air temperature about each day’s mean and shift it uniformly (the heating months follow the shifted weather). Table 27 gives the partial rank correlation coefficient (PRCC) of every input with every result.

Table 26: Inputs of the uncertainty analysis: base value and uniform range.

Input	Base	Low	High
indoor COP slope γ	0.02	0	0.03
outdoor COP slope	0.02	0.01	0.03
COP ratio c_1/c_3	1.45	1.3	1.6
COP ratio c_2/c_3	1.24	1.1	1.3
inverter C_d	0.15	0.05	0.25
fixed-speed C_d	0.25	0.15	0.35
escalation thresholds (scale)	1	0.5	2
air-node share of capacitance	0.05	0.02	0.15
latent COP	3.4	2.5	4
infiltration (ACH)	0.4	0.2	0.8
internal gains (scale)	1	0.7	1.3
wall U (thermal bridges)	1	1	1.2
opaque solar absorptance	0.7	0.5	0.9
door exchange (scale)	1	0.5	1.5
capacity derating slope	0.01	0.005	0.02
daily temperature swing (scale)	1	0.8	1.3
air temperature shift [K]	0	-1	2

Table 27: Partial rank correlation coefficients of the inputs with the results (Riyadh / Jeddah). Columns: setpoint lever, envelope lever, inverter lever, best admissible pre-cool (omitted when no sample saves), cost of a 2 K pre-peak and of a 2 K night pre-cool.

Input	Setp.	Env.	Inv.	Pre-peak	Night
indoor COP slope γ	+0.93/+0.98	+0.04/+0.10	-0.17/-0.09	+0.69/+0.65	+0.76/+0.81
outdoor COP slope	-0.19/-0.10	+0.23/+0.39	+0.01/+0.09	-0.14/+0.34	-0.78/-0.80
COP ratio c_1/c_3	-0.32/-0.28	+0.43/+0.33	+0.90/+0.89	+0.35/+0.34	+0.12/+0.16
COP ratio c_2/c_3	-0.12/-0.09	+0.05/-0.10	+0.13/+0.17	+0.10/+0.03	+0.07/+0.07
inverter C_d	-0.19/+0.16	-0.36/-0.04	-0.89/-0.89	-0.37/-0.38	-0.15/-0.16
fixed-speed C_d	+0.04/+0.22	+0.04/+0.03	+0.94/+0.95	-0.08/-0.14	-0.13/-0.16
escalation thresholds (scale)	-0.22/-0.27	-0.55/-0.27	+0.32/+0.33	-0.36/-0.34	-0.24/-0.19
air-node share of capacitance	-0.36/-0.41	-0.80/-0.80	+0.31/+0.05	-0.44/-0.46	+0.08/-0.04
latent COP	-0.10/+0.84	+0.12/+0.77	+0.14/+0.64	-0.06/+0.16	+0.04/+0.33
infiltration (ACH)	-0.85/-0.57	-0.88/-0.96	-0.21/-0.82	+0.34/-0.27	+0.55/+0.15
internal gains (scale)	+0.48/-0.80	-0.90/-0.77	-0.15/+0.01	-0.26/-0.24	-0.29/-0.37
wall U (thermal bridges)	+0.00/+0.06	+0.35/+0.00	-0.07/+0.07	-0.04/-0.03	+0.02/-0.03
opaque solar absorptance	-0.07/-0.43	+0.85/+0.87	+0.11/+0.18	+0.05/+0.09	-0.00/+0.03
door exchange (scale)	-0.03/-0.11	-0.14/+0.11	-0.15/-0.29	+0.02/+0.03	+0.05/+0.01
capacity derating slope	+0.06/+0.04	-0.31/+0.15	-0.05/-0.03	+0.09/+0.12	+0.15/+0.22
daily temperature swing (scale)	-0.43/-0.20	+0.05/-0.03	+0.07/+0.13	-0.15/+0.12	-0.50/-0.55
air temperature shift [K]	+0.73/-0.78	-0.52/+0.78	+0.12/+0.36	+0.02/-0.28	+0.21/-0.42

J Calculation time

Table 28 reports the measured calculation times. One annual evaluation of the whole building (132 zones with two nodes each, 120 open doors, 28,800 integration steps) takes 13.4 s for one policy and 52.5 s for the 49 policies of the lattice together, i.e. 1.07 s per policy. The simulation time grows much more slowly than the number of zones, because at these sizes the fixed cost of each step dominates. The optimal-control program for one day has 5,088 variables and 3,072 equality constraints in Case 1 and 10,656 and 6,336 in Case 2, and takes 1.3 and 18.4 s for the bound ($\gamma = 0$, one solve), and the search for the indoor COP factor 21.2 and 284.3 s (19 and 19 solves; the top floor under the roof, the size of Case 2, 295.1 s; the bound of the whole building, with Clarabel, 233.8 s), against 18.9 and 24.2 s for a year of all 49 thermostat policies; the program’s time grows faster with its size, about 13-fold for twice the zones. In the building each unit needs only its own temperature and the clock: selecting the modes of all 60 units at one control step takes 8.4 μ s; the call overhead of one vectorised step dominates at all three sizes, so the time does not grow with the number of units (the smaller cases are within timing noise), and a single unit’s thermostat logic is trivial for ordinary hardware.

Table 28: Calculation time (two-core virtual machine): one annual evaluation of a thermostat policy (sampled year, 3-minute steps), alone and for all 49 policies together; the optimal-control linear program for one mean July day (15-minute steps); the bound, $\gamma = 0$, and the search, sequential linear programming for the indoor COP factor; Case 3: bound only, with Clarabel); and the controller at one control step.

Case	Zones	Units	Doors	1 policy [s]	49 policies [s]	Bound/search [s]	Ctrl. [μ s]
1	16	7	15	11.2	18.9	1.3/21.2	7.2
2	33	15	30	10.0	24.2	18.4/284.3	7.1
3	132	60	120	13.4	52.5	233.8/-	8.4

References

- [1] M. Krarti, M. Aldubyan, and E. Williams. Residential building stock model for evaluating energy retrofit programs in Saudi Arabia. *Energy*, 195:116980, 2020. <https://doi.org/10.1016/j.energy.2020.116980>.
- [2] Lucelia Rodrigues, Benjamin A. Cherian, and Serik Tokbolat. Reducing cooling energy demand in Saudi Arabian residential buildings using passive design approaches. *Buildings*, 15(11):1895, 2025. <https://doi.org/10.3390/buildings15111895>.
- [3] Ahmed Felimban, Ulrich Knaack, and Thaleia Konstantinou. Evaluating savings potentials using energy retrofitting measures for a residential building in Jeddah, KSA. *Buildings*, 13(7):1645, 2023. <https://doi.org/10.3390/buildings13071645>.
- [4] James E. Braun. Reducing energy costs and peak electrical demand through optimal control of building thermal storage. *ASHRAE Transactions*, 96(2):876–888, 1990.
- [5] Shayan Naderi, Gloria Pignatta, Simon Heslop, Iain MacGill, and Dong Chen. Demand response via pre-cooling and solar pre-cooling: a review. *Energy and Buildings*, 272:112340, 2022. <https://doi.org/10.1016/j.enbuild.2022.112340>.
- [6] Stepp Mayes, Tong Zhang, and Kelly T. Sanders. Residential precooling on a high-solar grid: impacts on CO₂ emissions, peak period demand, and electricity costs across California. *Environmental Research: Energy*, 1(1):015001, 2024. <https://doi.org/10.1088/2753-3751/acfa91>.
- [7] SERA. Saudi Electricity Regulatory Authority. Consumption Tariff. <https://www.sera.gov.sa/en/consumer/electric-tariff/electric-tariff-categories/consumption-tariff>, 2026. Residential: 0.18 SAR/kWh up to 6000 kWh per month, 0.30 SAR/kWh above; bills subject to 15% VAT; accessed 25 September 2026.
- [8] Hamzah Faraj. Cost-effective tariff-aware HVAC coordination in Saudi residential buildings using physics-informed deep reinforcement learning. *Journal of King Saud University – Engineering Sciences*, 38(7):58, 2026. <https://doi.org/10.1007/s44444-026-00131-0>.
- [9] Jérôme Le Dréau and Per Heiselberg. Energy flexibility of residential buildings using short term heat storage in the thermal mass. *Energy*, 111:991–1002, 2016. <https://doi.org/10.1016/j.energy.2016.05.076>.
- [10] Glenn Reynders, Rui Amaral Lopes, Anna Marszal-Pomianowska, Daniel Aelenei, João Martins, and Dirk Saelens. Energy flexible buildings: an evaluation of definitions and quantification methodologies applied to thermal storage. *Energy and Buildings*, 166: 372–390, 2018. <https://doi.org/10.1016/j.enbuild.2018.02.040>.
- [11] Mahmoud A. A. Mousa, Sven Schewe, and Dominik Wojtczak. Optimal control for simple linear hybrid systems. In *2016 23rd International Symposium on Temporal Representation and Reasoning (TIME)*, pages 12–20. IEEE, 2016. <https://doi.org/10.1109/TIME.2016.9>.
- [12] Mahmoud A. A. Mousa, Sven Schewe, and Dominik Wojtczak. Optimal control for multi-mode systems with discrete costs. In *Formal Modeling and Analysis of Timed Systems (FORMATS 2017)*, volume 10419 of *Lecture Notes in Computer Science*, pages 77–96. Springer, 2017. https://doi.org/10.1007/978-3-319-65765-3_5.
- [13] Thomas A. Henzinger. The theory of hybrid automata. In *Verification of Digital and Hybrid Systems*, pages 265–292. Springer, 2000. https://doi.org/10.1007/978-3-642-59615-5_13.
- [14] Rajeev Alur, Ashutosh Trivedi, and Dominik Wojtczak. Optimal scheduling for constant-rate multi-mode systems. In *Proceedings of the 15th ACM international conference on Hybrid Systems: Computation and Control*, pages 75–84. ACM, 2012. <https://doi.org/10.1145/2185632.2185647>.
- [15] Dominik Wojtczak. Optimal control for linear-rate multi-mode systems. In *Formal Modeling and Analysis of Timed Systems (FORMATS 2013)*, volume 8053 of *Lecture Notes in Computer Science*, pages 258–273. Springer, 2013. https://doi.org/10.1007/978-3-642-40229-6_18.
- [16] Rajeev Alur, Vojtěch Forejt, Salar Moarref, and Ashutosh Trivedi. Safe schedulability of bounded-rate multi-mode systems. In *Proceedings of the 16th International Conference on Hybrid Systems: Computation and Control (HSCC)*, pages 243–252. ACM, 2013. <https://doi.org/10.1145/2461328.2461366>.
- [17] Truong X. Nghiem, Madhur Behl, Rahul Mangharam, and George J. Pappas. Green scheduling of control systems for peak demand reduction. In *Proceedings of the 50th IEEE Conference on Decision and Control and European Control Conference (CDC-ECC)*, pages 5131–5136. IEEE, 2011. <https://doi.org/10.1109/CDC.2011.6161164>.
- [18] Truong X. Nghiem, Madhur Behl, Rahul Mangharam, and George J. Pappas. Scalable scheduling of building control systems for peak demand reduction. In *Proceedings of the American Control Conference (ACC)*, pages 3050–3055. IEEE, 2012. <https://doi.org/10.1109/ACC.2012.6315252>.
- [19] Truong X. Nghiem, George J. Pappas, and Rahul Mangharam. Event-based green scheduling of radiant systems in buildings. In *Proceedings of the American Control Conference (ACC)*, pages 455–460. IEEE, 2013. <https://doi.org/10.1109/ACC.2013.6579879>.
- [20] Ján Drgoňa, Javier Arroyo, Iago Cupeiro Figueroa, David Blum, Krzysztof Arendt, Donghun Kim, Enric Perarnau Ollé, Juraj Oravec, Michael Wetter, Dragana L. Vrabie, and Lieve Helsen. All you need to know about model predictive control for buildings. *Annual Reviews in Control*, 50:190–232, 2020. <https://doi.org/10.1016/j.arcontrol.2020.09.001>.
- [21] Frauke Oldewurtel, Andreas Ulbig, Alessandra Parisio, Göran Andersson, and Manfred Morari. Reducing peak electricity demand in building climate control using real-time pricing and model predictive control. In *49th IEEE Conference on Decision and Control (CDC)*, pages 1927–1932. IEEE, 2010. <https://doi.org/10.1109/CDC.2010.5717458>.
- [22] Yudong Ma, Francesco Borrelli, Brandon Hancey, Brian Coffey, Sorin Bengea, and Philip Haves. Model predictive control for the operation of building cooling systems. *IEEE Transactions on Control Systems Technology*, 20(3):796–803, 2012. <https://doi.org/10.1109/TCST.2011.2124461>.
- [23] Petru-Daniel Moroşan, Romain Bourdais, Didier Dumur, and Jean Buisson. Building temperature regulation using a distributed model predictive control. *Energy and Buildings*, 42(9):1445–1452, 2010. <https://doi.org/10.1016/j.enbuild.2010.03.014>.

- [24] Vikas Chandan and Andrew G. Alleyne. Decentralized predictive thermal control for buildings. *Journal of Process Control*, 24(6): 820–835, 2014. <https://doi.org/10.1016/j.jprocont.2014.02.015>.
- [25] Wanfu Zheng, Dan Wang, and Zhe Wang. Economic model predictive control for building HVAC system: a comparative analysis of model-based and data-driven approaches using the BOPTEST framework. *Applied Energy*, 374:123969, 2024. <https://doi.org/10.1016/j.apenergy.2024.123969>.
- [26] H. Wang, D. Mai, Q. Li, and Z. Ding. Evaluating machine learning models for HVAC demand response: the impact of prediction accuracy on model predictive control performance. *Buildings*, 14(7):2212, 2024. <https://doi.org/10.3390/buildings14072212>.
- [27] Alexandre David, Peter Gjør Jensen, Kim Guldstrand Larsen, Marius Mikučionis, and Jakob Haahr Taankvist. UPPAAL Stratego. In *Tools and Algorithms for the Construction and Analysis of Systems (TACAS 2015)*, volume 9035 of *Lecture Notes in Computer Science*, pages 206–211. Springer, 2015. https://doi.org/10.1007/978-3-662-46681-0_16.
- [28] Kevin R. Keeney and James E. Braun. A simplified method for determining optimal cooling control strategies for thermal storage in building mass. *HVAC&R Research*, 2(1):59–78, 1996. <https://doi.org/10.1080/10789669.1996.10391333>.
- [29] Gregor P. Henze, Clemens Felsmann, and Gottfried Knabe. Evaluation of optimal control for active and passive building thermal storage. *International Journal of Thermal Sciences*, 43(2):173–183, 2004. <https://doi.org/10.1016/j.ijthermalsci.2003.06.001>.
- [30] W. J. N. Turner, I. S. Walker, and J. Roux. Peak load reductions: Electric load shifting with mechanical pre-cooling of residential buildings with low thermal mass. *Energy*, 82:1057–1067, 2015. <https://doi.org/10.1016/j.energy.2015.02.011>.
- [31] James E. Braun. Load control using building thermal mass. *Journal of Solar Energy Engineering*, 125(3):292–301, 2003. <https://doi.org/10.1115/1.1592184>.
- [32] Stephen Morgan and Moncef Krarti. Impact of electricity rate structures on energy cost savings of pre-cooling controls for office buildings. *Building and Environment*, 42(8):2810–2818, 2007. <https://doi.org/10.1016/j.buildenv.2005.11.010>.
- [33] Reza Arababadi, Mohamed Elzomor, and Kristen Parrish. Selection of energy efficiency measures to enhance the effectiveness of pre-cooling in residential buildings in hot arid climate. *Science and Technology for the Built Environment*, 23(5):858–867, 2017. <https://doi.org/10.1080/23744731.2016.1262660>.
- [34] Wesley J. Cole, Joshua D. Rhodes, William Gorman, Krystian X. Perez, Michael E. Webber, and Thomas F. Edgar. Community-scale residential air conditioning control for effective grid management. *Applied Energy*, 130:428–436, 2014. <https://doi.org/10.1016/j.apenergy.2014.05.067>.
- [35] Essam Alayed, Richard O’Hegarty, and Oliver Kinnane. Thermal envelope analysis for new code compliance of Saudi Arabian dwellings. *Energy and Buildings*, 243:110997, 2021. <https://doi.org/10.1016/j.enbuild.2021.110997>.
- [36] Saleh H. Alyami, Ali Alqahtany, Noman Ashraf, Abdelbagi Osman, Naief Ali Aldossary, Ayman Almutlaqa, Faris Al-Maziad, Maher S. Alshammari, and Wadee Ahmed Ghanem Al-Gehlani. Impact of location and insulation material on energy performance of residential buildings as per Saudi Building Code (SBC) 601/602 in Saudi Arabia. *Materials*, 15(24):9079, 2022. <https://doi.org/10.3390/ma15249079>.
- [37] Mana Alyami and Siddig Omer. Building energy performance simulation: a case study of modelling an existing residential building in Saudi Arabia. *Environmental Research: Infrastructure and Sustainability*, 1(3):035001, 2021. <https://doi.org/10.1088/2634-4505/ac241e>.
- [38] Ahmed Felimban, Alejandro Prieto, Ulrich Knaack, Tillmann Klein, and Yasser Qaffas. Assessment of current energy consumption in residential buildings in Jeddah, Saudi Arabia. *Buildings*, 9(7):163, 2019. <https://doi.org/10.3390/buildings9070163>.
- [39] Mohammad Aldubyan and Moncef Krarti. Impact of stay home living on energy demand of residential buildings: Saudi Arabian case study. *Energy*, 238:121637, 2022. <https://doi.org/10.1016/j.energy.2021.121637>.
- [40] Moncef Krarti and Mohammad Aldubyan. Peak demand-based optimization approach for building retrofits: case study of Saudi residential buildings. *Energy Efficiency*, 15(8):69, 2022. <https://doi.org/10.1007/s12053-022-10077-2>.
- [41] Alaa Alaidroos and Moncef Krarti. Optimal design of residential building envelope systems in the Kingdom of Saudi Arabia. *Energy and Buildings*, 86:104–117, 2015. <https://doi.org/10.1016/j.enbuild.2014.09.083>.
- [42] Moncef Krarti and Nicholas Howarth. Transitioning to high efficiency air conditioning in Saudi Arabia: a benefit cost analysis for residential buildings. *Journal of Building Engineering*, 31:101457, 2020. <https://doi.org/10.1016/j.jobbe.2020.101457>.
- [43] Tyler Hoyt, Edward Arens, and Hui Zhang. Extending air temperature setpoints: simulated energy savings and design considerations for new and retrofit buildings. *Building and Environment*, 88:89–96, 2015. <https://doi.org/10.1016/j.buildenv.2014.09.010>.
- [44] ASHRAE. ANSI/ASHRAE Standard 55-2023: Thermal Environmental Conditions for Human Occupancy. American Society of Heating, Refrigerating and Air-Conditioning Engineers, Atlanta, GA, 2023.
- [45] International Organization for Standardization. ISO 7730:2025 – Ergonomics of the Thermal Environment: Analytical Determination and Interpretation of Thermal Comfort Using Calculation of the PMV and PPD Indices and Local Thermal Comfort Criteria. ISO, Geneva, 2025.
- [46] Kahramaa. Qatar General Electricity and Water Corporation (Kahramaa), National Program for Conservation and Energy Efficiency (Tarsheed). Tips to Using an Air Conditioner Efficiently. <https://www.km.qa/Tarsheed/Pages/TarsheedDetails.aspx?ItemID=2>, 2026. Accessed 25 September 2026.
- [47] Saudi Building Code National Committee. *Saudi Building Code: General Building Code (SBC 201), Section 1010: Doors, Gates and Turnstiles*. Saudi Building Code National Committee, Riyadh, Saudi Arabia, 2018.
- [48] SASO. Saudi Standards, Metrology and Quality Organization. SASO 2663:2014 – Energy Labelling and Minimum Energy Performance Requirements for Air-Conditioners. Policy record: <https://www.iea.org/policies/2429-saso-26632014-meps-and-labelling-for-air-conditioners>, 2014. Minimum EER of 11.5 (Btu/h)/W at test condition T1 for split units from 2015.

- [49] SASO. Saudi Standards, Metrology and Quality Organization. SASO 2663:2021 – Air Conditioners: Minimum Energy Performance, Labelling and Testing Requirements for Low Capacity Window and Single-Split Types. Policy record: <https://www.iea.org/policies/20488-saso-26632021-standard-for-air-conditioners>, 2021. Replaces SASO 2663:2018; introduces the Seasonal Energy Efficiency Ratio (SEER).
- [50] Saudi Building Code National Committee. *Saudi Building Code: The Low-Rise (Residential) Buildings Energy Conservation Code (SBC 602-CC)*. Saudi Building Code National Committee, Riyadh, Saudi Arabia, 2018.
- [51] International Organization for Standardization. ISO 13790:2008 – Energy Performance of Buildings: Calculation of Energy Use for Space Heating and Cooling. ISO, Geneva, 2008. Withdrawn; superseded by ISO 52016-1:2017.
- [52] ASHRAE. ASHRAE handbook – fundamentals (SI edition). ASHRAE, Peachtree Corners, GA, 2021.
- [53] W. G. Brown and K. R. Solvason. Natural convection through rectangular openings in partitions—1: Vertical partitions. *International Journal of Heat and Mass Transfer*, 5(9):859–868, 1962. [https://doi.org/10.1016/0017-9310\(62\)90184-9](https://doi.org/10.1016/0017-9310(62)90184-9).
- [54] International Organization for Standardization. ISO 13370:2017 – Thermal Performance of Buildings: Heat Transfer via the Ground: Calculation Methods. ISO, Geneva, 2017.
- [55] Air-Conditioning, Heating, and Refrigeration Institute. AHRI standard 210/240-2017: Performance rating of unitary air-conditioning & air-source heat pump equipment. AHRI, Arlington, VA, 2017.
- [56] Q. Huangfu and J. A. J. Hall. Parallelizing the dual revised simplex method. *Mathematical Programming Computation*, 10(1):119–142, 2018. <https://doi.org/10.1007/s12532-017-0130-5>.
- [57] Paul J. Goulart and Yuwen Chen. Clarabel: An interior-point solver for conic programs with quadratic objectives. *Mathematical Programming Computation*, 2026. <https://doi.org/10.1007/s12532-026-00320-7>.
- [58] J. C. Helton and F. J. Davis. Latin hypercube sampling and the propagation of uncertainty in analyses of complex systems. *Reliability Engineering & System Safety*, 81(1):23–69, 2003. [https://doi.org/10.1016/S0951-8320\(03\)00058-9](https://doi.org/10.1016/S0951-8320(03)00058-9).
- [59] Simeone Marino, Ian B. Hogue, Christian J. Ray, and Denise E. Kirschner. A methodology for performing global uncertainty and sensitivity analysis in systems biology. *Journal of Theoretical Biology*, 254(1):178–196, 2008. <https://doi.org/10.1016/j.jtbi.2008.04.011>.
- [60] Wei Tian. A review of sensitivity analysis methods in building energy analysis. *Renewable and Sustainable Energy Reviews*, 20: 411–419, 2013. <https://doi.org/10.1016/j.rser.2012.12.014>.
- [61] Andrea Saltelli and Paola Annoni. How to avoid a perfunctory sensitivity analysis. *Environmental Modelling & Software*, 25(12): 1508–1517, 2010. <https://doi.org/10.1016/j.envsoft.2010.04.012>.
- [62] Ron Judkoff and Joel Neymark. Model validation and testing: The methodological foundation of ASHRAE Standard 140. *ASHRAE Transactions*, 112(2):367–376, 2006.
- [63] ASHRAE. ANSI/ASHRAE Standard 140-2023: Method of Test for Evaluating Building Performance Simulation Software. American Society of Heating, Refrigerating and Air-Conditioning Engineers, Atlanta, GA, 2023.
- [64] Sh. Mahmoud, Y. Alyousef, Y. Alusaimi, I. Yassin, and A. Alelwani. Time-of-use tariff program in Saudi Arabia: Design, implementation, and evaluation. *Journal of King Saud University - Engineering Sciences*, 22(2):165–172, 2010. [https://doi.org/10.1016/S1018-3639\(18\)30503-8](https://doi.org/10.1016/S1018-3639(18)30503-8).