Seattle Department of Construction & Inspections
Viktor Peykov
viktor.peykov@seattle.gov
(206)-615-0749
700 5th Avenue, Suite 2000, PO Box 34019, Seattle, WA 98124-4019

7088950-CN Drainage Cycle1 2-27-2026_Markup Summary

Drainage (4)

Subject: General
Page Index: 27
Author: Viktor Peykov
X: 11.4158 in
Y: 6.2533 in
Layer: Review Comment
Review Type: Drainage

OSM Calculator Summary Sheet is incomplete:
Add the following:
- SDCI permit number
- Total new plust replaced landscaping - to match the SA area shown on the CSC plan
-Total existing hard surface area

Action: William - email Rachel verify current storm water impervious maximum.

Subject: SPU Public Sewer Mainline Buildover
Page Index: 27
Author: Viktor Peykov
X: 28.1843 in
Y: 14.8931 in
Layer: Review Comment
Review Type: Drainage

Action: William - email the DSO office to get in contact to who this is assigned to, prepare the build over form, and show the cross section (show we aren't putting earth pressure over the pipe)

A build-over agreement may be required with SPU for this project. The SPU Mainline is located onsite. See Tip 507, Build-Over and/or Re-Route Review and Approval Process, for instructions on applying for a build-over review. http://www.seattle.gov/DPD/Publications/CAM/cam507.pdf

Please submit the Request for Build-over Review application form and required documentation the SPU Developer Services Office (DSO). If SPU determines that a build-over agreement is not necessary, then submit the correspondence from SPU indicating so with the next SDCI submittal. Otherwise, the build-over agreement must be finalized before this SDCI permit may be approved for Drainage Review.

Note: when required, new easements or relinquishing existing easements requires City Council action prior to building permit approval, and may take up to 18 months. Revisions to existing easements are sometimes required for Construction Permits.

Subject: Engineered Plans - Stamped and Signed
Page Index: 27
Author: Viktor Peykov
X: 23.3992 in
Y: 16.4648 in
Layer: Review Comment
Review Type: Drainage

All Civil Drainage Plan sheets & Drainage Report must be stamped & signed by a licensed Civil PE.

Action: William - email Rachel make sure we have a stamp.

Subject: Side Sewer
Page Index: 27
Author: Viktor Peykov
X: 17.2130 in
Y: 18.7572 in
Layer: Review Comment
Review Type: Drainage

Drainage Review approval is for private property stormwater only. SPU will conduct sanitary side sewer review under a separate permit. Please add a large boxed note to indicate that.

Action: Derek - ask Reid to scope the side sewer, and give us elevation of the main

Responding to Review Comments

You can upload corrected plans AFTER all reviews are completed and the project's status is Corrections Required.

To respond to comments:

1. Provide a response to each comment on the Correction Response Plan set and identify changes since initial review on the updated drawings.
2. Make sure drawings are the appropriate size, legible, oriented correctly, and combined in a single PDF file.

See How to Respond to Review Comments for detailed steps.

An equal employment opportunity, affirmative action employer. Accommodations for people with disabilities provided upon request.