7088950-CN Comment Review Cycle#1 3-6-2026 Energy Summary

Energy (7)

Karen - Note

Subject: General
Page Index: 9
Status:
Author: CaryNovotney
X: 19.5859 in
Y: 15.4385 in
Layer: Review Comment
Review Type: Energy

Identify the cooking range type and indicate 160 CFM for and electric range and 250 CFM if the range is gas per Table M1505.4.4.3.



Karen - verify HRV calculation and location per code

Subject: General
Page Index: 10
Status:
Author: CaryNovotney
X: 13.1718 in
Y: 15.8386 in
Layer: Review Comment
Review Type: Energy

M1505.4.3.1 Ventilation quality adjustment. The minimum whole house ventilation rate from Section 1505.4.3 shall be adjusted by the system coefficient in Table M1505.4.3(2) based on the system type not meeting the definition of a balanced whole house ventilation system and/or not meeting the definition of a distributed whole house ventilation system. Show the calculation on the drawings. (Typical) Revise and resubmit.



Subject: General
Page Index: 10
Status:
Author: CaryNovotney
X: 13.1718 in
Y: 15.8386 in
Layer: Review Comment
Review Type: Energy

SRC M1505.4: It appears that the whole house ventilation is provided by the local exhaust fan(s). Identify the fan on the drawing. Also, specify Fan CFM and mode of operation as continuous or intermittent. For intermittent operation specify run time. For intermittent operation specify run time. Balanced or Not balanced.



Subject: General
Page Index: 10
Status:
Author: CaryNovotney
X: 13.1664 in
Y: 16.9479 in
Layer: Review Comment
Review Type: Energy

SRC M1505.4.3: Indicate on the drawings whether the whole house ventilation system will operate continuously or intermittently. If the system is to operate continuously, indicate the minimum ventilation CFM flow rate to be provided, per SRC Table M1505.4.3 (1). If the system is to operate intermittently, provide run-time percentage in each 4-hour segment and corresponding ventilation CFM per SRC Table M1505.4.3.2 on the drawings.



Karen - Update window schedules to reflect C3 U-values

Subject: General
Page Index: 10
Status:
Author: CaryNovotney
X: 10.5801 in
Y: 19.0430 in
Layer: Review Comment
Review Type: Energy

Add the U-value for the fenestration in-line with the compliance path chosen (Typical)

Karen - Consider heated slab and adjust insulating perimeter and/or under-slab as needed

Subject: General
Page Index: 12
Status:
Author: CaryNovotney
X: 16.62 in
Y: 19.90 in
Layer: Review Comment
Review Type: Energy

Revise the slab on grade insulation to extend a minimu8m of 4'-0": with a R-5 thermal break at the wall. (Typical)

Karen - As per HRV above

ubject: General
age Index: 14
tatus:
Author: CaryNovotney
X: 4.3930 in
Y: 10.3373 in
Layer: Review Comment
Review Type: Energy

Whole House Ventilation using Heat Recovery system requires a full detail shown on the drawing for the review and inspection verification purpose. An example of such details is available online at http://www.seattle.gov/sdci/codes/codes-we-enforce-(a-z)/mechanical-code