Seattle Department of Construction & Inspections
David Aguilera
david.aguilera@seattle.gov 206-684-7715
700 5th Avenue, Suite 2000, PO Box 34019, Seattle, W

Other reviewers we are waiting on : addressing, land use, Geo, Arborist,
derek - check portal where I paid. for the full list of reviewers.

7088950-CN_Ordinance_Cycle#1_ 2-20-2026_Markup Summary

Ordinance (7)

Subject: 00 Code Edition
Page Index: 4
Author: David Aguilera
Layer: Review Comment
Review Type: Ordinance
X: 30.9597 in
Y: 10.9076 in

This project has been reviewed for conformance with one or more of the following codes: 2021 Seattle Residential Code (SRC)

No Action Required

Subject:
Page Index: 8
Author: David Aguilera
Layer: Review Comment
Review Type: Ordinance
X: 17.3099 in
Y: 11.3790 in

Sheet A4

SRC R302.7 - Enclosed spaces under stairs accessed by a door shall have walls, under-stair surface and any soffits protected on the enclosed side with 1/2" gypsum board.

Action: Karen - add note to stairs by the golf room

Subject:
Page Index: 8
Author: David Aguilera
Layer: Review Comment
Review Type: Ordinance
X: 31.8386 in
Y: 9.8720 in

Sheet A4, Garage note 1

SRC R302.5 and R302.6 - Clarify that at habitable rooms above the garage, a minimum 5/8-inch Type X gypsum board ceiling is required to provide fire separation from the garage and dwelling unit.

Action: Karen - probably already there, just double check.

Subject:
Page Index: 9
Author: David Aguilera
Layer: Review Comment
Review Type: Ordinance
X: 5.0422 in
Y: 12.7669 in

Sheet A5

SRC R408.4 – Show crawl space access on the plans via openings in the floor or through the foundation walls. Openings shall be 18"x24" minimum through floors, and 16"x24" minimum through walls. If below grade a 16"x 24" minimum area-way is required.

Action: Karen - probably already there, just double check, off golf room to under the garage.

Subject:
Page Index: 9
Author: David Aguilera
Layer: Review Comment
Review Type: Ordinance
X: 16.4881 in
Y: 9.3534 in

Sheet A5 Action: Karen - update for both stairs.

SRC R311.7 - Provide notes or details that clearly show the following basic stair dimensions for each stair run in the plans:

a) Width (Min. 36")
b) Riser height (Max. 7-3/4")
c) Tread length (Min. 10")
d) Clear headroom (Min. 6'-8")
e) Landing length (Min. 3'-0")
f) Total vertical rise (Max 12'-7")

Subject:
Page Index: 10
Author: David Aguilera
Layer: Review Comment
Review Type: Ordinance
X: 5.2967 in
Y: 12.8727 in

Sheet A6 Action: Karen - update for plans to show this is called out, update window schedule, may change U value, adn credits.

SRC R308.4 - Clearly indicate on the plans each location where safety glazing is required. See the following locations of concern:

a) SRC R308.4.2 - The window in the plane of the door within 24 inches of the door jamb.

Subject:
Page Index: 11
Author: David Aguilera
Layer: Review Comment
Review Type: Ordinance
X: 26.8679 in
Y: 14.4787 in

Sheet A7
Specify if the roof assembly is vented or unvented, and provide one of the following:

1) SRC R806.2 - If the roof is a vented assembly, provide venting details and calculations that demonstrate the ventilation area is adequate, OR

2) SRC R806.5 - If the roof is an unvented assembly using spray foam insulation, provide the following on the drawings:
a) A detail of the proposed assembly that clearly shows compliance with one of the 4 assembly options from R806.5, Item 5. Include the R-value of the foam insulation.
b) The following note: "The applied spray foam must be installed in accordance with the manufacturer's instructions by a certified installer."

Action: Karen talk to Reid about venting for flat roof

Responding to Review Comments

You can upload corrected plans AFTER all reviews are completed and the project's status is Corrections Required.

To respond to comments:

1. Provide a response to each comment on the Correction Response Plan set and identify changes since initial review on the updated drawings.
2. Make sure drawings are the appropriate size, legible, oriented correctly, and combined in a single PDF file.

See How to Respond to Review Comments for detailed steps.

An equal employment opportunity, affirmative action employer. Accommodations for people with disabilities provided upon request.