Seattle Department of Construction & Inspections

Leah Carlson

leah.carlson@seattle.gov

206.684.5191

700 5th Avenue, Suite 2000, PO Box 34019, Seattle, WA 98124-4019

PERMIT#7088950-CN_REVEGETATION REVIEW_CYCLE#1 [02_26_2026]_Markup Summary

Leah Carlson (6)

Subject: ECA Revegetation - General
Review Type: Revegetation
Author: Leah Carlson
Status:
Layer: Review Comment
Page Index: 1

Please map the Potential Slide ECA area on plans. Please note that mitigation sequencing is not needed in potential slide ECA.

Additionally, please note that revegetation standards do not apply in shoreline areas, which part of this site is located in.

Action: William - work with Sage & Stone on mitigation plan.
Action: Karen & Terrain - add the 25ft buffer. Karen to reach out to Terrain to take off the wetland symbols

---

Subject: ECA Revegetation - General
Review Type: Revegetation
Author: Leah Carlson
Status:
Layer: Review Comment
Page Index: 3

This project was reviewed for consistency with SMC 25.09.070: Standards for Vegetation and Impervious Surface Management. The proposed project activities appear to be located within mapped environmentally critical areas (ECAs) or their buffers.

If either temporary construction disturbance or permanent new development within ECAs or their buffers that impacts trees/vegetation within the ECA is approved, mitigation and revegetation requirements apply even if an exemption or other ECA relief is granted.

Action: William - Work with Sage & Stone, to complete

Subject: ECA Revegetation - Existing Conditions Plan
Review Type: Revegetation
Author: Leah Carlson
Status:
Layer: Review Comment
Page Index: 3

Action: William - Karen - use the survey after removing wetland markers.

Provide an existing conditions plan, including:

(a) Delineate and label the ECA.

(b) A brief description/identification of the existing ground coverage within the area of temporary and permanent disturbance in the ECA. Examples of ground coverage include: lawn, ornamental landscaping (vegetation species), blackberry or other invasive species, tree species, patio, pathway, driveway, stairway, etc.

(c) Locations of all existing trees located within and adjacent to the disturbance area consistently across all plan sheets. Include the tree genus, species, and dripline diameter. Do not provide tier categories (they do not apply in ECA code). Please number trees consistently within table, if provided, and across all plan sheets.

(d) A summary in a brief narrative or bulleted list of the existing ecological functions performed by the trees and vegetation within the ECA. The ecological functions include but may not be limited to: habitat for amphibian, avian, and terrestrial wildlife species; soil stabilization; and stormwater filtering, detention, and infiltration (SMC 25.09.065.C.2.a).

Subject: ECA Revegetation - Mitigation Sequencing (Steep Slope ECA)
Review Type: Revegetation
Author: Leah Carlson
Status:
Layer: Review Comment
Page Index: 3

Action: William - sage & stone, mitigation plan

Provide documentation of mitigation sequencing. The ECA code requires that you avoid or minimize tree/vegetation removal within ECAs (see SMC 25.09.065). Mitigation sequencing must be undertaken in the order of priority listed in SMC 25.09.065.B. Provide a brief narrative or bulleted list documenting how mitigation sequencing was considered in project design and construction. This may require the relocation/reconfiguration of structures and/or utilities to avoid tree/vegetation removal.

Subject: ECA Revegetation - Area of Impact
Review Type: Revegetation
Author: Leah Carlson
Status:
Layer: Review Comment
Page Index: 3

Action: William - use the updated CSC plan from Rachel to close out on this issue

Delineate and label the total area and square feet of both permanent development (structures and hard surface area) and temporary construction disturbance within the ECA. Show all trees proposed to be removed and the following calculation [(a+b) –c = d):

a -- Total new development (structures and hard surface area)

b -- Total temporary construction disturbance area including all construction-related activities including, but not limited to construction access, staging area, temporary excavation, and areas of tree/vegetation removal

c -- Areas of existing development within the area of development (structures and hard surface area)

d -- Total area of impact that requires mitigation in the form of replanting

Responding to Review Comments

You can upload corrected plans AFTER all reviews are completed and the project's status is Corrections Required.

To respond to comments:

1. Provide a response to each comment on the Correction Response Plan set and identify changes since initial review on the updated drawings.
2. Make sure drawings are the appropriate size, legible, oriented correctly, and combined in a single PDF file.

See How to Respond to Review Comments for detailed steps.

An equal employment opportunity, affirmative action employer. Accommodations for people with disabilities provided upon request.

Seattle Department of Construction & Inspections
Leah Carlson
leah.carlson@seattle.gov
206.684.5191
700 5th Avenue, Suite 2000, PO Box 34019, Seattle, WA 98124-4019

Subject: ECA Revegetation - Mitigation Plan (Steep Slope ECA)
Review Type: Revegetation
Author: Leah Carlson
Status:
Layer: Review Comment
Page Index: 3

Provide a mitigation (revegetation/restoration) plan, including:

(a) Location and square feet of the mitigation area

(b) Location, size, species, quantities, and spacing of trees/shrubs to be newly planted.

Shrub quantities can be determined by using multiplier 0.042 times the total area of impact

Tree replacement quantities can be 1:1 or alternatively use a tree multiplier of 0.01 x area of impact.

You may use Seattle SDCI - ECA standard mitigation plan as a guide. References to help you choose native plants: King County Native Plant Guide: Plant list - Native Plant Guide or WSU Native Plant Guide

(c) A brief narrative describing how the proposed mitigation plan will compensate for the loss of ecological functions provided by trees and vegetation to be removed.

(d) The following notes:

-Planting selections shall be Pacific Northwest native species suited to specific site conditions/orientation, no cultivars or hybrids are allowed.

-New trees must be at least 4-6 feet in height and shrubs one-gallon size at time of installation.

-Areas that have been cleared, graded, or compacted are to be amended with organic matter prior to planting. Use finely shredded mulch, minimum 4” depth between new plantings.

-The following monitoring and maintenance is required for a period of 5 years from date of plant installation. Self-monitoring is sufficient. No documentation is required to be submitted to SDCI unless requested.

80 percent survival of new trees and vegetation planted at the end of five years

Annual inspections of the plants

Replacement of failed plants

Removal of invasive species that have become established

Photographic documentation of planting success retained for the five-year period

No permanent irrigation is allowed on steep slope erosion hazard areas or their buffers.

Responding to Review Comments

You can upload corrected plans AFTER all reviews are completed and the project's status is Corrections Required.

To respond to comments:

1. Provide a response to each comment on the Correction Response Plan set and identify changes since initial review on the updated drawings.
2. Make sure drawings are the appropriate size, legible, oriented correctly, and combined in a single PDF file.

See How to Respond to Review Comments for detailed steps.

An equal employment opportunity, affirmative action employer. Accommodations for people with disabilities provided upon request.