David Landry, AICP
david.landry@seattle.gov
(206)-684-5318

7088950-CN Land Use Comment Summary_Markup Summary 2-23-2026

General Shoreline Review Comment (5)

Subject: General Shoreline Review Comment
Page Index: 1
Author: David Landry
X: 1.4834 in
Y: 3.5166 in
Layer: Review Comment
Review Type: Shoreline

Construction drawings for Shoreline projects must accurately depict the Shoreline Environment, including boundaries and relevant shoreline features, to comply with Seattle's Shoreline Master Program (SMP). The Shoreline District for this property is Urban Residential and Conservancy Recreation.

Action: Karen - add a zoning overlay? indicate shoreline environment UR

Subject: General Shoreline Review Comment
Page Index: 1
Author: David Landry
X: 1.5144 in
Y: 6.8598 in
Layer: Review Comment
Review Type: Shoreline

Please depict on the relevant site plans any and all Shoreline) best management practices (BMPs) related to construction zones and construction staging areas to prevent deleterious and waste material from entering shoreline habitat during the proposed work, per applicable standards in SMC 23.60A.15.

Action: Derive a mitigation plan (Gabe / Karen / William) mitigate debris going into lake etc. (wait for landscape plan) ?

Subject: General Shoreline Review Comment
Page Index: 1
Author: David Landry
X: 1.5513 in
Y: 8.6679 in
Layer: Review Comment
Review Type: Shoreline

Please depict on appropriate site plans the location of any construction staging area and how it will be fitted with BMPs.

Action: Karen Call out for the staging on the site plan (probably basketball court area). Create a new site plan for BMP's and staging.

Subject: General Shoreline Review Comment
Page Index: 1
Author: David Landry
X: 1.6530 in
Y: 10.7978 in
Layer: Review Comment
Review Type: Shoreline

Please specify on plans, equipment using oil, gasoline, or diesel on site shall be checked daily for evidence of leakage, if evidence of leakage is found, further use of such equipment shall be suspended until the deficiency has been satisfactorily corrected.

Action: William — send 6-page BMP document, Karen - work with Rachel to make this part of this is on the CSC (Construction Stormwater Control). add BMPs that shoreline wants to see. Karen add bullet point checklists on the site plan. same BMPs

---

Subject: General Shoreline Review Comment
Page Index: 1
Author: David Landry
X: 1.5892 in
Y: 12.6469 in
Layer: Review Comment
Review Type: Shoreline

Please add a note on the plans that states, the owner(s), builder(s), or responsible party(s) shall follow a Best Management Practices and an Emergency Containment plan developed to prevent debris and other deleterious material from entering the water during construction.

Action: Karen add notes onto the site plan, and give the 6-page BMP and Emergency Containment Plan (ECP)

Impervious Surface Calculation Needed (1)

Subject: Impervious Surface Calculation Needed
Page Index: 1
Author: David Landry
X: 1.4033 in
Y: 5.0306 in
Layer: Review Comment
Review Type: Shoreline

Please provide calculation for existing and proposed impervious (including but not limited to the two paths and steps leading into the water in the shoreline setback) surface and show any changes to vegetation proposed, including changes that have occurred without prior authorization such as tree removal. Please note that an increase in impervious surface will trigger need for mitigation plan per SMC 23.60A.190, which typically is addressed by planting equal area of native vegetation as new impervious surface. Plants should be a mixture of shrubs, groundcover suitable for this location and planted as close to the water as possible.

Note* Any new ground coverage—such as a structure, addition, or impermeable surface that intrudes into a shoreline environment is considered an impact. Mitigation must compensate for the removal or disturbance of natural vegetation. Shoreline policies require that every development achieves No Net Loss (NNL) of ecological functions. Therefore applicants must mitigate, compensate, remediate the removal, disturbance of all natural vegetation including temporary impact areas.

Action: Need finished landscape plan.