

 Add icon  Add cover

# 3. Environmental Monitoring Log

## Environmental Monitoring Log

NovaThera Pharmaceuticals Pvt. Ltd.

Quality Assurance Department

Document No: LOG-ENV-P101

Page: 53 of 365

### Section 1: Area & Date Details

	Field	Details
1	Area / Room ID:	Packaging Suite P-101
2	Date:	22-Feb-2025
3	Associated Batch (if any):	ASP-25-001

### Section 2: Acceptance Criteria

	Parameter	Specification / Required Limit
1	Differential Pressure (Pa):	10.0 Pa – 15.0 Pa
2	Temperature (°C):	20.0 °C – 25.0 °C
3	Relative Humidity (%):	Not More Than 60%

### Section 3: Log Entries

	Time	Differential Pressure (Pa)	Temperature (°C)	Relative Humidity (%)	Performed By (Signature)	Reviewed By (Signature)
1	07:45	12.8	22.1	45	Priya Singh	Amit Sharma
2	09:00	12.9	22.3	46	Priya Singh	Amit Sharma
3	10:00	13.1	22.5	48	Priya Singh	Amit Sharma
4	11:00	13.0	22.6	49	Priya Singh	Amit Sharma

5	12:00	12.8	22.8	51	Priya Singh	Amit Sharma
6	13:00	12.9	22.9	52	Priya Singh	Amit Sharma
7	14:00	13.2	22.7	51	Priya Singh	Amit Sharma
8	15:00	13.1	22.6	50	Priya Singh	Amit Sharma
9	16:30	12.8	22.4	48	Priya Singh	Amit Sharma
10	---	---	---	---	---	---
11	21:00	12.5	22.0	46	Sandeep Chowdhury	Rina Desai
12	23:00	12.4	21.8	45	Sandeep Chowdhury	Rina Desai

Section 4: Deviations & Corrective Actions

Instruction: If any reading is outside the limits defined in Section 2, record the details and corrective actions below.

	≡ Time	≡ Parameter	≡ Reading	≡ Corrective Action Taken	≡ Notified Supervisor
1	N/A	N/A	N/A	N/A	N/A

(No Deviations Recorded on this Date)

Section 5: Daily Review

Comments:

All environmental parameters for the Packaging Suite P-101 remained within the specified limits throughout the primary packaging of Batch ASP-25-001.

Reviewed By:

- Department: Production
- Name: Amit Sharma
- Title: Packaging Supervisor
- Signature: Amit Sharma
- Date: 23-Feb-2025