

Daily Verification Log Register: Dispensing Booth DB03

Logbook Document No.: DVL-DB03

Area ID: Dispensing Booth DB03

Department: Production / Quality Assurance

Date of Verification	Time of Verification	Cleaning Log Verification	Differential Pressure Reading	Differential Pressure Spec.	Temperature Reading	Temperature Spec.	Relative Humidity Reading	Relative Humidity Spec.	Balance Daily Check	Final Status	Verified By (Signature)
15-Apr-25	07:45	Ref: CL-DB03	12.7 Pa	12 - 20 Pa	22.2 °C	20 - 25 °C	50%	NMT 55 % RH	Pass (Ref: LOG/WB-03/029)	SUITABLE FOR USE	Sunita Rao
15-Apr-25	21:30	Ref: CL-DB03	12.8 Pa	12 - 20 Pa	22.6 °C	20 - 25 °C	47%	NMT 55 % RH	N/A	End-of-day cleaning complete	Meena Iyer
16-Apr-25	07:45	Ref: CL-DB03	14.2 Pa	12 - 20 Pa	22.5 °C	20 - 25 °C	50%	NMT 55 % RH	Pass (Ref: LOG/WB-03/027)	SUITABLE FOR USE	Sunita Rao
16-Apr-25	21:30	Ref: CL-DB03	13.4 Pa	12 - 20 Pa	22.7 °C	20 - 25 °C	52%	NMT 55 % RH	N/A	End-of-day cleaning complete	Meena Iyer

Logbook Custodian

Name: Deepak Shah