

# Daily Verification Log Register: Dispensing Booth DB02

Logbook Document No.: DVL-DB02

Area ID: Dispensing Booth DB02

Department: Production / Quality Assurance

Date of Verification	Time of Verification	Cleaning Log Verification	Differential Pressure Reading	Differential Pressure Spec.	Temperature Reading	Temperature Spec.	Relative Humidity Reading	Relative Humidity Spec.	Balance Daily Check	Final Status	Verified By (Signature)
15-May-25	07:45	Ref: CL-DB02	12.9 Pa	10 - 15 Pa	22.3 °C	20 - 25 °C	49%	NMT 60 % RH	Pass (Ref: LOG/WB-02/009)	SUITABLE FOR USE	Priya Shah
15-May-25	21:30	Ref: CL-DB02	13.1 Pa	10 - 15 Pa	22.6 °C	20 - 25 °C	50%	NMT 60 % RH	N/A	End-of-day cleaning complete	Pooja Gupta
16-May-25	07:45	Ref: CL-DB02	13.0 Pa	10 - 15 Pa	22.5 °C	20 - 25 °C	49%	NMT 60 % RH	Pass (Ref: LOG/WB-02/007)	SUITABLE FOR USE	Priya Shah
16-May-25	21:30	Ref: CL-DB02	12.9 Pa	10 - 15 Pa	22.7 °C	20 - 25 °C	49%	NMT 60 % RH	N/A	End-of-day cleaning complete	Pooja Gupta

Logbook Custodian

Name: Karan Joshi