

# PARTICLE COUNTER

Date: February 08, 2025 | Time: 9:10 | Booth ID: SB-01

## Environmental Data



## MEASUREMENT DETAILS

Parameter	Value	Unit	Acceptance Criteria	Status
Particle Count	2900	$\geq 0.5\mu\text{m}/\text{m}^3$	NMT 3520 $\geq 0.5\mu\text{m}/\text{m}^3$	✓ PASS

## INSTRUMENT INFORMATION

HEPA Integrity	Pass
Type of Monitoring	Weekly
Instrument Calibration Status	Y
CFU Count	N/A
Remarks	Weekly check

### SYSTEM GENERATED DOCUMENT

Calibration Due: August 29, 2026

This document is automatically generated and does not require manual signature.