

😊 Add icon    🖼️ Add cover

# Daily Verification Log Register: Dispensing Booth DB-03

## Daily Verification Log Register: Dispensing Booth DB-03

Logbook Document No.: DVL-DB-03

Area ID: Dispensing Booth DB-03

Department: Production / Quality Assurance

	<div>Date of Verification</div>	<div>Time of Verification</div>	<div>Cleaning Log Verification</div>	<div>Differential Pressure Reading</div>	<div>Differential Pressure Spec.</div>	<div>Temperature Reading</div>	<div>Temperature Spec.</div>	<div>Relative Humidity Reading</div>	<div>Relative Humidity Spec.</div>	<div>Balance Daily Check (WB-03)</div>	<div>Final Status</div>	<div>Verified By (Signature)</div>
1	15-Feb-25	07:45	Ref: CL-DB-03	14.5 Pa	12 - 20 Pa	22.5 °C	20 - 25 °C	45%	NMT 55 % RH	Pass (Ref: LOG/WB-03/021)	SUITABLE FOR USE	Sunita Rao
2	15-Feb-25	21:30	Ref: CL-DB-03	14.2 Pa	12 - 20 Pa	23.0 °C	20 - 25 °C	47%	NMT 55 % RH	N/A	End-of-day cleaning complete	Meenalyer
3	16-Feb-25	07:45	Ref: CL-DB-03	14.3 Pa	12 - 20 Pa	22.6 °C	20 - 25 °C	46%	NMT 55 % RH	Pass (Ref: LOG/WB-03/022)	SUITABLE FOR USE	Sunita Rao
4	16-Feb-25	21:30	Ref: CL-DB-03	14.1 Pa	12 - 20 Pa	23.1 °C	20 - 25 °C	48%	NMT 55 % RH	N/A	End-of-day cleaning complete	Meenalyer

**Logbook Custodian**

**Name:** Deepak Shah

**Designation:** Production Supervisor

**Company:** NovaThera Pharmaceuticals Pvt. Ltd.