

Environmental Monitoring Log - Sampling Booth

NovaThera Pharmaceuticals Pvt. Ltd.

Quality Control Department

Document No: LOG-EM-SB-02

Page: 1 of 12

Section 1: Area & Date Details

Field	Details
Area / Room ID:	Sampling Booth SB-02
Month / Year:	Jan-25

Section 2: Acceptance Criteria

Parameter	Specification / Required
Differential Pressure (Pa):	10.0 Pa – 15.0 Pa
Temperature (°C):	20.0 °C – 25.0 °C
Relative Humidity (%):	Not More Than 55%
Particle Count (≥0.5µm/m³):	Not More Than 3,520
HEPA Integrity:	Pass

Section 3: Log Entries

Date	Sampling Booth ID	Time	Differential Pressure (Pa)	Temperature (°C)	Relative Humidity (%)	Particle Count (≥0.5µm/m³)	HEPA Integrity (Pass/Fail)	Verified By	Comments / Action Taken
4-Jan-25	SB-02	9:10	12.1	22.3	48	2950	Pass	Ravi Kumar	Weekly check. All parameters OK.
4-Jan-25	SB-02	—	—	—	—	—	—	Ravi Kumar	NA
4-Jan-25	SB-02	—	—	—	—	—	—	Ravi Kumar	NA
11-Jan-25	SB-02	9:15	12.3	22.1	47	3100	Pass	Ravi Kumar	Weekly check. All parameters OK.
11-Jan-25	SB-02	—	—	—	—	—	—	Ravi Kumar	NA
11-Jan-25	SB-02	—	—	—	—	—	—	Ravi Kumar	NA
18-Jan-25	SB-02	9:20	12	22.5	49	2800	Pass	Ravi Kumar	Weekly check. All parameters OK.
18-Jan-25	SB-02	—	—	—	—	—	—	Ravi Kumar	NA
18-Jan-25	SB-02	—	—	—	—	—	—	Ravi Kumar	NA
25-Jan-25	SB-02	9:00	12.2	22.4	48	3050	Pass	Ravi Kumar	Pre-sampling check for Packaging Materials.
25-Jan-25	SB-02	—	—	—	—	—	—	Ravi Kumar	NA
25-Jan-25	SB-02	—	—	—	—	—	—	Ravi Kumar	NA
31-Jan-25	SB-02	9:10	12.4	22.2	49	2900	Pass	Ravi Kumar	Monthly summary OK.
31-Jan-25	SB-02	—	—	—	—	—	—	Ravi Kumar	NA
31-Jan-25	SB-02	—	—	—	—	—	—	Ravi Kumar	NA

Section 4: Monthly Review

Reviewed By:

Name: Anjali Mehta

Title: Head of Quality Control

Signature: Anjali Mehta

Date: 01-Feb-2025