

😊 Add icon 🖼️ Add cover

Daily Verification Log Register: Dispensing Booth DB-02

Logbook Document No.: DVL-DB-02

Area ID: Dispensing Booth DB-02

Department: Production / Quality Assurance

	<div>Date of Verification</div>	<div>Time of Verification</div>	<div>Cleaning Log Verification</div>	<div>Differential Pressure Reading</div>	<div>Differential Pressure Spec.</div>	<div>Temperature Reading</div>	<div>Temperature Spec.</div>	<div>Relative Humidity Reading</div>	<div>Relative Humidity Spec.</div>	<div>Balance Daily Check (WB-02)</div>	<div>Final Status</div>	<div>Verified By (Signature)</div>
1	15-Feb-25	07:45	Ref: CL-DB-02	13.1 Pa	10 - 15 Pa	21.9 °C	20 - 25 °C	49%	NMT 60 % RH	Pass (Ref: LOG/WB-02/009)	SUITABLE FOR USE	Priya Shah
2	15-Feb-25	21:30	Ref: CL-DB-02	13.0 Pa	10 - 15 Pa	22.5 °C	20 - 25 °C	52%	NMT 60 % RH	N/A	End-of-day cleaning complete	Pooja Gupta
3	16-Feb-25	07:45	Ref: CL-DB-02	13.2 Pa	10 - 15 Pa	22.0 °C	20 - 25 °C	51%	NMT 60 % RH	Pass (Ref: LOG/WB-02/010)	SUITABLE FOR USE	Priya Shah
4	16-Feb-25	21:30	Ref: CL-DB-05	13.1 Pa	10 - 15 Pa	22.6 °C	20 - 25 °C	53%	NMT 60 % RH	N/A	End-of-day cleaning complete	Pooja Gupta

Logbook Custodian

Name: Karan Joshi

Designation: Production Supervisor

Company: NovaThera Pharmaceuticals Pvt. Ltd.