

DIGITAL THERMO-HYGROMETER / DATA LOGGER

Date: February 01, 2025 | Time: 9:15 | Booth ID: SB-01

Environmental Data



MEASUREMENT DETAILS

Parameter	Value	Unit	Acceptance Criteria	Status
Temperature	22.0	°C	20.0 - 25.0 °C	✓ PASS
Relative Humidity	48	%	NMT 55.0%	✓ PASS
Overall Status				✓ PASS

INSTRUMENT INFORMATION

HEPA Integrity	Pass
Type of Monitoring	Initial
Instrument Calibration Status	Y
CFU Count	N/A
Remarks	Initial EM baseline

SYSTEM GENERATED DOCUMENT

Calibration Due: August 29, 2026

This document is automatically generated and does not require manual signature.