

# Daily Verification Log Register: Dispensing Booth DB01

**Logbook Document No.:** DVL-DB01

**Area ID:** Dispensing Booth DB01

**Department:** Production / Quality Assurance

Date of Verification	Time of Verification	Cleaning Log Verification	Differential Pressure Reading	Differential Pressure Spec.	Temperature Reading	Temperature Spec.	Relative Humidity Reading	Relative Humidity Spec.	Balance Daily Check	Final Status	Verified By (Signature)
15-May-25	07:45	Ref: CL-DB01	13.1 Pa	10 - 15 Pa	22.2 °C	20 - 25 °C	48%	NMT 55 % RH	Pass (Ref: LOG/WB-01/008)	SUITABLE FOR USE	Arvind Kumar
15-May-25	21:30	Ref: CL-DB01	12.6 Pa	10 - 15 Pa	22.8 °C	20 - 25 °C	47%	NMT 55 % RH	N/A	End-of-day cleaning complete	Manpreet Kaur
16-May-25	07:45	Ref: CL-DB01	13.0 Pa	10 - 15 Pa	22.7 °C	20 - 25 °C	49%	NMT 55 % RH	Pass (Ref: LOG/WB-01/006)	SUITABLE FOR USE	Arvind Kumar
16-May-25	21:30	Ref: CL-DB01	13.0 Pa	10 - 15 Pa	22.9 °C	20 - 25 °C	47%	NMT 55 % RH	N/A	End-of-day cleaning complete	Manpreet Kaur

**Logbook Custodian**

**Name:** Balwinder Singh