

😊 Add icon   🖼️ Add cover

# Daily Verification Log Register: Dispensing Booth DB-01

Logbook Document No.: DVL-DB-01

Area ID: Dispensing Booth DB-01

Department: Production / Quality Assurance

	<div>Date of Verification</div>	<div>Time of Verification</div>	<div>Cleaning Log Verification</div>	<div>Differential Pressure Reading</div>	<div>Differential Pressure Spec.</div>	<div>Temperature Reading</div>	<div>Temperature Spec.</div>	<div>Relative Humidity Reading</div>	<div>Relative Humidity Spec.</div>	<div>Balance Daily Check (WB-01)</div>	<div>Final Status</div>	<div>Verified By (Signature)</div>
1	15-Feb-25	07:45	Ref: CL-DB-01	12.8 Pa	10 - 15 Pa	22.1 °C	20 - 25 °C	46%	NMT 55 % RH	Pass (Ref: LOG/WB-01/015)	SUITABLE FOR USE	Arvind Kumar
2	15-Feb-25	21:30	Ref: CL-DB-01	12.6 Pa	10 - 15 Pa	22.8 °C	20 - 25 °C	49%	NMT 55 % RH	N/A	End-of-day cleaning complete	Manpreet Kaur
3	16-Feb-25	07:45	Ref: CL-DB-04	12.9 Pa	10 - 15 Pa	22.3 °C	20 - 25 °C	48%	NMT 55 % RH	Pass (Ref: LOG/WB-01/016)	SUITABLE FOR USE	Arvind Kumar
4	16-Feb-25	21:30	Ref: CL-DB-04	12.7 Pa	10 - 15 Pa	22.9 °C	20 - 25 °C	50%	NMT 55 % RH	N/A	End-of-day cleaning complete	Manpreet Kaur

Logbook Custodian

Name: Balwinder Singh

**Designation:** Production Supervisor

**Company:** NovaThera Pharmaceuticals Pvt. Ltd.