DIGITAL THERMO-HYGROMETER / DATA LOGGER

Date: January 25, 2025 | **Time:** 9:00 | **Booth ID:** SB-02 | **Model:** TH-DL2000

Environmental Data

DAILY SUMMARY STATISTICS

Parameter	Value	Range	Status
Temperature	22.4°C	20.0-25.0°C	✓ PASS
Relative Humidity	48.0%	NMT 55.0%	✓ PASS
Overall Status			✓ PASS

INSTRUMENT INFORMATION

HEPA Integrity	Pass
Comments	Pre-sampling check for Packaging Materials.

System generated | Serial: TH-DL2000-3745 | Cal Due: 2025-12-31