

Floor tile quantities — "sample set – new house" (eastcoast)

Job QA-EC · measured against drawings BA issue set, 17/05/12 · 5 wet areas · PARTIAL — floors first.

ORDER THIS

Nothing yet – and that's the honest answer.

+ ~25.7 m² wet-area floors – pending Q1
+ laundry nook floor – pending Q1
+ tile skirting – pending Q2

Nothing on these drawings is safe to order from.
Here's why, and exactly what fixes it – Q1.

NOT INCLUDED

ALL WALL TILE – see below.
Every number above – provisional, see Q1
Main-area floors (kitchen/living etc) – extent
of floor tiling isn't called up on this set
Waterproofing membrane and upturns
Screed, falls and floor wastes
Substrate prep, sheeting and levelling
Labour, rates and pricing of any kind

We measure. What you charge is your business.

Walls

Walls: not measured — this set has no internal wet-area elevations. Send the internal elevations and we'll add every wall.

Wall tile heights only exist on the internal wall drawings of each room, and this set doesn't carry them. We won't price a wall off a guess. Send the internal elevation / joinery sheets and every wall goes into this same job.

⚠ Check these 3 things before you quote

[] **1. This set doesn't print the room dimensions — so no floor here is order-grade.** It's marked "QUOTE SET ONLY – NOT FOR CONSTRUCTION" and it dimensions the *building* (every structural chain we tested adds up perfectly) but not the *rooms*: the wet rooms carry door widths (720/820) and nothing else. We never scale off a drawing — a 1:100 print that's been "fit to page" is wrong by more than the tile margin. The floors below are worked from the wall-position chains with stated assumptions, and they are provisional. **What fixes it:** the dimensioned working drawings ("Construction Set" — the title block says one exists once approved), or room sizes confirmed by the builder. **Worth: every number on this page.**

[] **2. Is there any tile skirting?** No skirting of any kind is called up on this set. If the tiled areas get a tile skirting, say so and we'll add the lineal metres when the room sizes land.

[] **3. Which floors are actually tiled?** The set shows floor finishes nowhere. We've assumed the five wet areas are tiled and the rest is not our scope — confirm both halves of that.

Room by room — all provisional, all waiting on Q1

Every figure below is a zone read off the wall-position chains, not a printed room dimension. △ on every line is deliberate.

FIRST FLOOR — ENSUITE △

- **Floor — about 10.8 m² △** · zone 3,090 wide (1,790 + 90 + 1,210 off the south wall chain) × the 3,505 band, assumed full depth. Twin basins, shower, tub, own WC zone.

FIRST FLOOR — WC (ensuite side) △

- **Floor — about 1.8 m² △** · zone 910 wide × assumed 2,000 deep.

FIRST FLOOR — BATH △

- **Floor — about 6.6 m² △** · zone 1,870 wide (1,000 + 90 + 780) × the 3,505 band. Tub, shower, vanity.

FIRST FLOOR — WC (bath side) △

- **Floor — about 1.9 m² △** · zone 940 wide × assumed 2,000 deep.

GROUND FLOOR — BATH △

- **Floor — about 4.6 m² △** · zone 2,320 wide (south chain) × assumed 2,000 deep. WC, basin, shower; "mechanical vent to bathroom" noted on the plan.

GROUND FLOOR — LAUNDRY NOOK △

- **Floor — not measurable △** · a washer + trough nook in the hallway cupboard run, no dimensions at all. Included in Q1's ask.

SITE NOTES

"QUOTE SET ONLY - NOT FOR CONSTRUCTION" is stamped across every sheet. The title block says only plans marked "Construction Set" may be built from. Do not price for contract off this set without Q1's answer.

The set's own Floor Area Schedule totals 343.17 m² (ground 180.74 + garage 38.86 + gatehouse 2.25 + first 121.33). Useful sanity anchor - not a room-level measurement.

Hand-lettered QLD style, 1:100. Structural chains check out exactly (17,990 south run, 10,630 west run) - the drawing is internally consistent; it just doesn't dimension rooms.

Crimsafe screens and obscure glazing called on several openings - matters to the glazier, not to tile.

Assumptions — the answer form

What we assumed	We used	Worth	Your answer
First-floor wet band depth (not printed)	3,505	~17 m ²	___
WC depths, all three small rooms	2,000	~5 m ²	___
South-chain zone → room mapping (which zone is which room)	as listed above	all of it	___
Ground bath depth	2,000	~4.6 m ²	___
Wet areas are tiled, living areas aren't our scope	yes / yes	scope	___

=====

THE PROOF — for checking, not reading.

=====

1. What we measured, and what we couldn't

Measured and verified: the building. The first-floor south wall chain closes exactly — $4,820 + 90 + 1,790 + 90 + 1,210 + 90 + 910 + 90 + 940 + 90 + 1,000 + 90 + 780 + 90 + 5,820 + 90 = 17,990$, which is the printed overall. The west chain closes the same way: $1,210 + 90 + 3,350 + 90 + 515 + 90 + 3,505 + 90 + 1,510$ (+ end walls) = **10,630** printed. Ninety-plus chains verify across the set (the gate counted 100). The text layer is real and the drawing is internally consistent.

Not measurable to order grade: any single room. No wet room carries one printed extent. The zones above come from mapping the south-chain wall positions onto the drawn rooms — the mapping is our judgement, the numbers inherit it, and that is why every line is $\triangle$ pending Q1 and the order box is empty.

	Provisional floor	Basis
Ensuite (first)	<i>10.831</i>	3.090×3.505 — zone $\times$ band
WC, ensuite side	<i>1.820</i>	0.910×2.000 assumed
Bath (first)	<i>6.554</i>	1.870×3.505 — zone $\times$ band
WC, bath side	<i>1.880</i>	0.940×2.000 assumed
Bath (ground)	<i>4.640</i>	2.320×2.000 assumed
Laundry nook	—	no dimensions at all
Provisional total	<i>25.7 m²</i>	<i>+10% $\approx$ 28.3 m² — for budgeting only</i>

Italics = provisional. Nothing here is an order quantity.

2. What we double-checked

- ✓ **Chains sum to totals** — south 17,990 exact, west 10,630 exact, master window chain $970 + 2,880 + 970 = 4,820$ exact.
- ✓ **Opposite sides agree** — the ground and first-floor overall runs reconcile where they share structure (17,990 over 17,480 + steps, consistent with the drawn overhangs).
- $\triangle$ **Wall runs vs floor perimeter** — **not runnable**. Needs room-level dims. Q1.
- $\triangle$ **Heights** — **not runnable for tile**. Sections give storey heights but no internal elevations exist; no tiling heights anywhere.
- ✓ **Fixtures sane** — tubs draw $\sim 1,700$ – $1,800$ long in both bathrooms at the stated 1:100; door leaves 720/820 as labelled.
- $\triangle$ **Sanity ranges** — provisional wet floors 1.8–10.8 m² all inside the 2–25 m² band (the 1.8/1.9 WCs sit at the bottom edge, as WCs do). No range can be run to measurement grade until Q1.

3. The drawings we read

31 sheets, East Coast Building Design "sample set – new house", BA issue set (issue G, 17/05/12), 1:100: ground + first floor plans (sheets 04–05, with floor area schedules), external elevations (06–09), sections A/B/E (15–17), drainage/setout, awning and slab details. **No internal wet-area elevations; no room dimensions on the floor plans.**

4. Before you quote

```
[ ] Q1 answered - room dimensions from the Construction Set or the builder  
[ ] Q2 answered - skirting, yes or no  
[ ] Q3 answered - which floors are tiled  
[ ] Internal elevations sent -> walls get added to this same job  
[ ] Nothing on this page has been quoted to a client as a firm quantity
```