

Evacuation Plan - Tower A, Level 12

3. Emergency lighting

Emergency luminaires are installed along all corridors and stairwells.

The design illuminance at floor level is 6 lux. Battery autonomy is 90 minutes.

4. Exit widths

All exit doors provide a clear width of 1.5 m. Occupant load is 240 persons.

5. Travel distances

The longest travel distance to a protected stair is 38 m. The building is fully sprinklered.