

CHAPTER 6 Means of Egress

6.4 Emergency lighting

6.4.1 Scope

This section applies to all assembly, commercial and high-rise residential occupancies.

6.4.2 Emergency illumination

Emergency illumination shall cover every point along the means of egress and shall provide an average illuminance of not less than 10 lux measured at the floor.

Emergency lighting shall operate for a minimum of 90 minutes upon loss of primary power.

6.5 Exit width

6.5.1 Minimum clear width

The clear width of every exit shall be not less than 1.2 m where the occupant load exceeds 50 persons.

6.6 Travel distance

6.6.1 Maximum travel distance

Travel distance to an exit shall not exceed 45 m in sprinklered buildings.

Notwithstanding 6.6.1, travel distance in open-plan office areas may extend to 60 m where an approved smoke control system is provided.

6.7 Smoke control

6.7.1 Documentation

A smoke control design report shall be submitted and approved before occupancy.