0
Latches the E-stop faults when the raw condition becomes true
Raw E-stop condition
Cond_EStop
Latched E-stop fault
Flt_EStop

1
Latches the motor overload fault when the raw condition becomes true
Raw motor overload condition
Cond_MotorOL
Latched E-stop fault
Flt_EStop

2
Latches the high temp fault when the raw condition becomes true
Raw high temperature fault
Cond_HighTemp
Latched high temp fault
Flt_HighTemp
L

3
Latches the low temp timeout talk
Raw low temp fault
Cond_LowTemp
Latched low temp fault
Flt_LowTemp
L

4
Latches the high level fault
Raw high level fault
Cond_Highlevel
Latched high level fault
Flt_HighLevel
L

5
Latches the low fault
Raw low level fault
Cond_Lowlevel
Latched low level fault
Flt_LowLevel
L

6
Latches the valve 1 failure fault
Raw low level fault
Cond_Valve1Fail
Latched valve 1 failure
Flt_Valve1Fail
L

7
Latches the valve 2 failure fault
Raw valve 1 failure
Cond_Valve2Fail
latched valve 2 failure
Flt_Valve2Fail
L

8
Latches the valve 3 failure fault
Raw valve 2 failure
Cond_Valve3Fail
Latched valve 3 failure
Flt_Valve3Fail
L

9
Latches the sensor fault when the input is outside the valid range
Raw valve 3 failure
Cond_SensorFault
Latched sensor fault
Flt_SensorFault
L

(End)