0
set ready-to-run when safety permit is active
S_SafeRunPermit — Std_ReadyToRun

1
Latch machine run command when start is pressed and safety is ok
Std_StartPB Std_ReadyToRun — Std_machineRunCmd (L)

2
Unlatch machine run command on stop
Std_StopPB — Std_machineRunCmd (U)

3
Drop run command when safety permit is lost
S_SafeRunPermit — Std_machineRunCmd (U)

4
Machine running when run command and safety permit are true
Std_machineRunCmd S_SafeRunPermit — Std_MachineRunning

5
indicate simulated machine cycle active
Std_MachineRunning — Std_CycleActive

6
Energize simulated motor while machine running
Std_MachineRunning — Std_MotorRun

7
Extend simulated cylinder during active cycle
Std_CycleActive — Std_CylinderExtend

8
Green light when machine ready to run
Std_ReadyToRun — Std_GreenLight

9
red light when safety fault present
S_SafetyFault — Std_RedLight

10
Amber light when safety trip requires reset
S_SafetyTrip S_ResetComplete — Std_AmberLight

11
Sound horn during safety trip
S_SafetyTrip — Std_Horn

12
Indicate machine fault from safety task
S_SafetyFault — Std_Faulted

13

Mirror safety reset complete status

S_ResetComplete

Std_ResetComplete

(End)