

# Lecture 29: The Evolution of Graphite and High-Temperature Gas Reactors (HTGR)

CBE 30235: Introduction to Nuclear Engineering — D. T. Leighton

March 27, 2026

## 1 Introduction: Escaping the Limits of Water

So far, we have focused on Light Water Reactors (PWR/BWR) and Heavy Water Reactors (CANDU). While highly successful, these designs are fundamentally limited by the thermodynamic and neutronic properties of water:

1. **Temperature Limits:** Water boils and severely pressurizes, limiting practical coolant temperatures to  $\approx 320^\circ\text{C}$  and thermal efficiency to  $\approx 33\%$ .
2. **Neutron Absorption:** Light water inherently absorbs some neutrons, requiring enriched fuel and limiting the reactor's neutronic economy.

To achieve higher efficiencies and temperatures (useful for industrial process heat, co-generation, or hydrogen production), we must change the moderator and the coolant entirely. This leads us to the evolution of the **Graphite Moderated Reactor**.


## 2 The Graphite Arc: A History of Coolant and Fuel Engineering

The history of graphite reactors is a story of engineers trying to find the right coolant and the right fuel geometry to pair with a solid carbon moderator.

### 2.1 Phase 1: Graphite + Water (The RBMK)

The Soviet Union scaled up the graphite core concept originally developed for CP-1 to produce commercial power and weapons-grade plutonium, creating the **RBMK** (the design used at Chernobyl). They used massive graphite blocks for moderation and pumped *light water* through channels in the graphite to cool the fuel.

- **Positive Void Coefficient:** If the water boils into steam (a void), it stops absorbing neutrons, but the solid graphite keeps right on moderating them. This causes the reactor power to spike. This inherent instability was the direct neutronic cause of the 1986 Chernobyl disaster.
- **Water + Hot Graphite:** If liquid water or steam comes into direct contact with incandescently hot graphite, it undergoes the endothermic *water-gas reaction*:



This generates highly explosive hydrogen and carbon monoxide, which likely contributed to the fires and combustible gas environment that followed the initial steam explosions and enhanced the dispersal of radioactive core material during the Chernobyl disaster.

## 2.2 Phase 2: The U.S. Prototype and the Move to Helium (Peach Bottom 1)

To eliminate the dangers of the water-graphite interaction, Western engineers developed the **High-Temperature Gas-Cooled Reactor (HTGR)**. They kept the graphite moderator but replaced water with **Helium** gas. Helium is a noble gas (won't chemically react with graphite) and absorbs effectively zero neutrons.

The first successful demonstration was **Peach Bottom Unit 1 (PB1)** in Pennsylvania, a 40 MWe prototype that operated from 1967 to 1974.

- **The Fuel Approach:** PB1 utilized long, cylindrical graphite tubes filled with ring-shaped fuel compacts. Crucially, it pioneered the use of **Coated Particle Fuel** (specifically BISO—Buffer Isotropic—coatings), proving that radioactive fission products could be contained at the microscopic particle level rather than relying on metal cladding.
- **The Power Cycle:** PB1 used an **Indirect Cycle**. The hot helium flowed out of the core and into a Steam Generator, boiling water in a secondary loop to drive a conventional steam turbine.
- **The Verdict:** It was a resounding technical success, operating with high availability and proving the physics of the helium/graphite/steam-generator concept.

## 2.3 Phase 3: The U.S. Scale-Up and Failure (Fort St. Vrain)

Encouraged by PB1, the U.S. built a commercial 330 MWe HTGR in Colorado called **Fort St. Vrain (FSV)** in the 1970s.

- **The Fuel Evolution (TRISO & Prismatic Blocks):** FSV upgraded the fuel to **TRISO** (Tristructural-Isotropic), adding a crucial Silicon Carbide (SiC) pressure-vessel layer to the microscopic particles. These TRISO particles were pressed into small cylindrical compacts and stacked inside massive, hexagonal **Prismatic Graphite Blocks**.
- **The Fatal Flaw:** Like PB1, FSV used an indirect steam cycle. However, to pump the massive volume of high-pressure helium required for a 330 MWe core, the circulators utilized *water-lubricated bearings*.
- **The Result:** The seals routinely failed, injecting liquid water directly into the high-temperature primary helium loop. While it didn't cause a Chernobyl-style explosion, it caused severe corrosion of the graphite blocks and forced endless shutdowns. The plant was an economic disaster, leading the U.S. to largely abandon HTGR development for decades.

## 2.4 Phase 4: The Direct Cycle Dream (and Reality)

Following Fort St. Vrain, a common assumption was that to prevent water ingress, the Steam Generator had to be eliminated entirely, although the failure there was not due to the steam generator.

- **The Direct Brayton Cycle Concept:** Engineers theorized passing the 800°C helium directly from the core into a gas turbine (a Direct Brayton Cycle) to achieve 50% thermal efficiency and remove water from the plant entirely. Designs like the South African PBMR and the General Atomics GT-MHR pursued this.
- **The Reality:** The metallurgical challenges of operating gas turbines at those temperatures, combined with the risk of highly abrasive, radioactive graphite dust from the core plating out on delicate turbine blades, proved too difficult. *No commercial direct-cycle HTGR has ever been successfully operated.*

## 2.5 Phase 5: The Modern Pebble Bed Revival

Today, the HTGR is experiencing a renaissance. Engineers accepted that the **Indirect Steam Cycle** is the most practical way to generate power, but they solved the Fort St. Vrain water-ingress problem by utilizing modern *Active Magnetic Bearings* in the helium circulators—ensuring a 100% water-free primary loop.

The standard geometry has also largely shifted from Prismatic Blocks to the **Pebble Bed**.

1. **China's HTR-PM (Operating Status):** The culmination of this arc is the Chinese HTR-PM, which entered commercial operation in December 2023. It utilizes twin 250 MWt pebble bed cores loaded with TRISO fuel. It uses an indirect steam cycle, producing 566°C steam to drive a single 210 MWe turbine at roughly 40% efficiency.
2. **Next-Generation U.S. SMRs (X-energy Xe-100):** The U.S. is re-entering the HTGR space through Small Modular Reactors (SMRs). X-energy is developing the Xe-100, an 80 MWe modular pebble bed reactor. Like its predecessors, it relies on TRISO fuel and an indirect steam cycle. By producing superheated steam at 565°C, the Xe-100 is designed not just for the electrical grid, but to plug directly into heavy industrial facilities (like Dow Chemical) to replace fossil-fueled process heat.

## 3 The Physics of Graphite Moderation

A common misconception is that graphite cores are physically massive because graphite has a low atom density. In reality, the atom density of Carbon in graphite ( $\approx 0.14N_A$ ) is slightly *higher* than Hydrogen in water ( $\approx 0.11N_A$ ).

The difference lies entirely in the scattering mechanics:

| Parameter                                             | Light Water ( $H_2O$ )  | Graphite (C)           |
|-------------------------------------------------------|-------------------------|------------------------|
| Scattering Cross-Section ( $\sigma_s$ )               | $\approx 50$ b (H)      | $\approx 4.8$ b (C)    |
| Logarithmic Energy Decrement ( $\xi$ )                | 0.92                    | 0.158                  |
| Collisions to Thermalize                              | $\approx 19$            | $\approx 115$          |
| <b>Slowing Down Length (<math>\sqrt{\tau}</math>)</b> | $\approx$ <b>5.7</b> cm | $\approx$ <b>19</b> cm |

Table 1: Comparison of Moderating Properties.

- **Energy Loss:** Because Carbon ( $A = 12$ ) is 12 times heavier than a neutron, a neutron bounces off it like a ping-pong ball hitting a bowling ball. It loses very little energy per elastic collision ( $\xi$  is small).

- **Distance Traveled:** Because  $\sigma_s$  is smaller and  $\xi$  is low, the neutron must travel a much larger physical distance ( $\sqrt{\tau}$ ) to slow down to thermal energies.
- **Result:** To prevent neutrons from leaking out before they thermalize, a graphite reactor core must be physically much larger than a PWR. (For example, the 250 MWt HTR-PM vessel is 25 meters high and 5.7 meters in diameter).

## 4 Inherent Safety: The Negative Temperature Coefficient

Having established how massive the graphite moderator must be to thermalize neutrons, we must now examine how this geometry and material choice dictates the reactor's behavior during an accident. The defining safety characteristic of a modern High-Temperature Gas Reactor (HTGR) is its heavily negative temperature coefficient of reactivity, driven primarily by a quantum mechanical phenomenon known as **Doppler broadening**.

### Doppler Broadening and Reactivity

In any nuclear fuel matrix, there is a significant amount of Uranium-238 ( $^{238}\text{U}$ ). Unlike  $^{235}\text{U}$ , which fissions when struck by thermal neutrons,  $^{238}\text{U}$  tends to absorb neutrons without fissioning, particularly at specific “resonance” energy levels.

As the temperature of the reactor core increases, the kinetic energy of the  $^{238}\text{U}$  atoms increases, causing them to vibrate more violently within their crystal lattice. From the perspective of an incoming neutron, this vibration effectively broadens the energy target for resonance absorption. Consequently, as the core gets hotter, the  $^{238}\text{U}$  acts as a massive neutron sponge, drastically increasing parasitic absorption. This removes neutrons from the chain reaction, driving the effective multiplication factor down ( $k_{\text{eff}} < 1$ ) and shutting down the fission process entirely.

### The Light Water Reactor (PWR) Limitation

It is important to note that traditional Light Water Reactors (PWRs) also possess a negative temperature coefficient and utilize Doppler broadening for normal operational stability. However, a PWR cannot rely on this mechanism to survive a total loss of forced cooling without control rod insertion.

In a PWR, the fuel is clad in a metallic zirconium alloy (Zircaloy), which reacts violently with steam and begins to fail at temperatures around 1200°C. If a PWR were to rely purely on thermal feedback to shut down and attempt to passively radiate away its decay heat, the internal temperatures required to reach that thermal equilibrium would completely melt and destroy the metallic core structure. In fact, even the residual decay heat is enough to melt the core without coolant, such as was the fate of TMI-2.

### The HTGR “Walkaway Safe” Mechanism

An HTGR, completely stripped of its coolant, behaves differently. If the helium flow stops, the reactor temperature spikes. The Doppler effect immediately kicks in and halts the fission chain reaction.

However, even with fission stopped, radioactive **decay heat** continues to generate massive amounts of thermal energy. Because the HTGR core is constructed of graphite, it possesses immense thermal capacity and excellent thermal conductivity at high temperatures. The core temperature rises dramatically—often peaking around 1600°C, well above the temperatures conventional

zirconium clad fuel cells could survive—but the heat conducts outward through the graphite blocks and passively radiates into the surrounding environment. The reactor naturally establishes a thermal equilibrium where the decay heat generated equals the heat passively rejected, all while  $k_{\text{eff}}$  remains safely below 1 due to the elevated temperature.

*Transition:* The fundamental question then becomes: If the reactor relies on reaching and sustaining temperatures of  $1600^{\circ}\text{C}$  to safely ride out an accident, what kind of nuclear fuel could possibly survive such extreme, sustained heat without melting or releasing radioactive fission products?

## 5 Fuel Technology: TRISO and the Pebble Bed

Because HTGRs operate at incredibly high temperatures, standard Zircaloy metal cladding is useless. Instead, we use **TRISO** (Tristructural-Isotropic) particles.

### 5.1 TRISO Particles

TRISO fuel effectively gives every individual grain of uranium its own microscopic containment building.

- **The Structure:** Tiny kernels of uranium ( $\approx 0.5$  mm) are coated in layers of porous carbon, pyrolytic carbon, and crucially, **Silicon Carbide (SiC)**.
- **Safety:** The SiC layer acts as a miniature pressure vessel that chemically and physically retains fission products up to  **$1600^{\circ}\text{C}$** —well above the maximum temperature the reactor can reach even in a total loss-of-coolant accident. The fuel is thus highly resistant to melt-down.

### 5.2 The Pebble Bed Core (HTR-PM Specifications)

Rather than loading fuel rods, TRISO particles are embedded into graphite spheres. The Chinese HTR-PM provides the standard benchmark for modern commercial operation:

- **The Fuel Element:** Each pebble is 60 mm in diameter (about the size of a tennis ball) and contains 7 g of fuel.
- **Enrichment and Burnup:** To achieve a high average burnup (approx. 90 MWd/tU), the uranium is enriched to **8.5%**  $^{235}\text{U}$ .
- **The Core Load:** A single 250 MWt HTR-PM reactor is essentially a giant silo loaded with exactly **245,318** of these fuel elements, alongside some pure graphite moderator pebbles of the same size.
- **Online Refueling:** Fresh pebbles are dropped into the top of the core one by one while the reactor is operating. Used pebbles flow out the bottom, where broken ones are separated, burn-up is measured, and spent elements are screened out and sent to storage. This eliminates the need for refueling outages.

### 5.3 Pebble Extraction and Granular Physics

A major mechanical challenge of the pebble bed design is extracting a single graphite sphere from the bottom of the vessel without the weight of the  $\approx 245,000$  pebbles above it crushing it into highly radioactive dust. The solution relies heavily on the physics of granular silos rather than traditional fluid dynamics.

- **The Janssen Effect:** In a wide cylindrical core, the rough graphite pebbles wedge against each other, forming internal structural arches or "bridges." This transfers the vast majority of the downward weight horizontally into the massive graphite walls of the reactor vessel. Consequently, the pebble at the very bottom exit hole only supports the weight of a small, localized column of pebbles immediately above it, preventing it from being pulverized.
- **The Funnel Geometry:** The solid graphite blocks that form the bottom reflector are machined into a steep inverted cone (typically a 20 to 30-degree angle). This funnel shape ensures "mass flow," meaning the entire core bed slowly moves downward together uniformly toward a single central discharge tube.
- **The Singulator Mechanism:** At the bottom of the discharge tube (outside the active core but inside the high-pressure helium boundary) sits a mechanical extraction device called a singulator. Operating much like the dispensing wheel in a commercial gumball machine, a slowly rotating scalloped disc catches one pebble at a time, separates it from the bed's weight, and drops it into the exit pipe.
- **Pneumatic Transport:** To avoid grinding the pebbles on mechanical conveyor belts, bursts of the reactor's own high-pressure helium coolant are used to blow the extracted pebble through pneumatic tubes. The gas blows the pebble past a radiation detector to measure burnup, and then either routes it back to the top of the core for another pass, or blows it into spent fuel storage bins.

*Historical Note (The THTR-300 Failure):* Germany's THTR-300 reactor critically disrupted this delicate granular balance. Instead of placing control rods in the outer walls, they mechanically rammed them directly down into the flowing pebble bed. This forced the pebbles downward, broke the friction bridges, and transferred immense mechanical pressure to the bottom of the funnel. The extraction singulator jammed, and the system literally ground thousands of fuel elements into highly radioactive dust. Modern designs like the HTR-PM strictly insert control rods into the outer graphite reflector to protect this flow.

## 6 Control and Power Generation

### 6.1 Reactivity Control

Inserting standard metal rods into a  $750^{\circ}\text{C}$  core is highly problematic.

- **Control Rods:** In Pebble Bed designs like the HTR-PM, the primary reactivity control consists of 24 control rods that insert into the **Graphite Side Reflector** (the outer structural ring of pure graphite), rather than directly into the flowing hot fuel bed itself.
- **Secondary Shutdown System:** As a backup, small absorber spheres can be dropped by gravity through six dedicated channels alongside the control rods in the graphite reflector to safely kill the chain reaction.

## 6.2 Thermal-Hydraulics: The Top-Down Flow Approach

A fundamental departure from Light Water Reactors (LWRs) is the direction of coolant flow. While PWRs and BWRs flow water from the bottom up to work *with* natural thermal buoyancy and convection, HTGRs force high-pressure helium from the top down. While pumping against natural convection requires significant energy, it is an absolute mechanical necessity for three primary reasons:

1. **Preventing a “Fluidized Bed” (The Levitation Problem):** Graphite is relatively light. To remove enough heat from a high-power core, helium must be pumped through the vessel at massive velocities. If pumped from the bottom up, the aerodynamic drag would overcome gravity and lift the 60 mm pebbles, creating a highly turbulent fluidized bed. The pebbles would violently grind together, generating catastrophic amounts of radioactive graphite dust and causing dangerous, rapid fluctuations in neutronic reactivity as the core density shifted. Top-down flow aerodynamically pins the pebble bed securely in place.
2. **Protecting Control Rod Mechanisms:** Because gravity is the ultimate fail-safe, control rods are almost always designed to drop into the core from above. This places the complex, metallic Control Rod Drive Mechanisms (CRDMs) and sensitive instrumentation at the top of the reactor vessel. By flowing the helium top-down, the “cold” return gas from the steam generator ( $\approx 250^\circ\text{C}$ ) enters at the top, bathing and cooling these sensitive components. The gas heats up as it moves downward, exiting the bottom at a blistering  $750^\circ\text{C}$  to  $950^\circ\text{C}$ . Bottom-up flow would continuously blast the safety mechanisms with peak-temperature gas, severely degrading the metals and potentially jamming the guide tubes.
3. **Mechanical Stability:** Even in non-pebble, prismatic block designs (like Fort St. Vrain), top-down flow is required. The core consists of thousands of stacked, machined graphite blocks. The aerodynamic pressure of the top-down helium flow acts like a giant, invisible hand, pressing the columns firmly down against the bottom support structure, preventing them from rattling, lifting, or misaligning and blocking the coolant channels.

**The Natural Convection Trade-off:** The engineering cost for this mechanical stability is paid during a Loss of Forced Cooling (LOFC) accident. If the main helium circulators fail, the top-down flow stops, and natural thermal convection takes over—which intrinsically wants to flow bottom-up. The reactor vessel and internal reflectors must be carefully engineered to safely accommodate this passive flow reversal so decay heat can naturally convect to the outer walls without damaging the upper internals.

## 6.3 Thermodynamics: The Indirect Steam Cycle

While early HTGR concepts envisioned a *Direct Cycle* (Brayton cycle) where the hot helium flows directly into a gas turbine, modern commercial implementations have largely opted for a more conventional *Indirect Cycle* to avoid the complexities of radioactive graphite dust plating out on delicate gas turbine blades.

- **The Steam Generator Approach:** In the HTR-PM, primary Helium exits the core at  $750^\circ\text{C}$  and 7 MPa. This gas flows through a Steam Generator, producing secondary steam at  $566^\circ\text{C}$ .

- **Turbine and Efficiency:** The twin 250 MWt reactors feed a single 210 MWe conventional steam turbine. Because the steam is produced at such high temperatures, the thermal efficiency reaches **40%** (and scales up to 43.7% in the larger 655 MWe HTR-PM 600 models).
- **Coal Replacement:** This high-quality, 566°C steam means these reactors can readily be plugged in to replace the steam systems in existing fossil-fuel power plants, utilizing their pre-existing turbines and grid connections.

## 7 HTGR Safety and Historical Operational Failures

When discussing nuclear disasters, it is important to clarify that there has never been a radiological disaster with a helium-cooled HTGR on the scale of Chernobyl or Fukushima. This is due to the inherent physics of the design: Helium is already a gas (it cannot boil away or cause a steam explosion), it is chemically inert, and the massive graphite core has an enormous heat capacity. If all coolant flow is lost, the reactor takes days to heat up, and modern TRISO fuel particles can withstand these peak accident temperatures without melting.

However, if we define "disaster" as massive engineering failures, severe radioactive contamination of the plant, or public relations nightmares, early gas-cooled graphite reactors have a very rocky history.

### 7.1 The German Pebble-Bed Experience: AVR and THTR-300

While Germany pioneered the pebble-bed concept, their operational execution revealed severe practical flaws with the "gumball machine" approach that modern designs (like China's HTR-PM) must carefully engineer around.

- **The AVR Overheating and Dust (1967–1988):** The AVR in Jülich was a 15 MWe pebble-bed prototype. While it successfully generated power, it suffered from undetected "hot spots" in the core where the helium flow bypassed the pebbles. Temperatures locally exceeded the limits of the early fuel coatings.
  - *The Fuel Failure (BISO vs. TRISO):* The AVR primarily utilized **BISO** (Bistructural-Isotropic) fuel particles, which only utilized porous and pyrolytic carbon layers. Crucially, BISO lacked the Silicon Carbide (SiC) containment layer that defines modern TRISO fuel. While pyrolytic carbon effectively holds back noble gases, it becomes essentially transparent to metallic fission products at extreme temperatures.
  - *The Consequence:* Because of the core hot spots, temperatures spiked high enough that metallic fission products like Strontium-90 and Cesium-137 literally diffused straight through the intact BISO carbon coatings. Furthermore, because pebbles physically grind against each other as they flow through the core, they constantly create microscopic graphite dust. The escaped Sr and Cs bonded to this dust, which then circulated and heavily plated out on every surface inside the primary loop. This specific containment failure is exactly why modern HTGRs strictly mandate the impermeable SiC layer found in TRISO fuel.
- **The AVR Decommissioning Reality:** Did they ever fully clean the AVR up? No. It is now widely considered one of the most difficult and expensive nuclear decommissioning projects in history.



- *The Concrete Sarcophagus (2008)*: Because the internal surfaces were coated in highly mobile radioactive dust, conventional dismantling was impossible. Engineers pumped the entire reactor vessel full of lightweight concrete to freeze the dust in place. This also permanently entombed roughly 200 radioactive fuel pebbles that had become wedged in a crack in the damaged bottom reflector.
- *The Great Move (2015)*: This created a massive, highly radioactive, 2,000-ton solid plug. In 2015, heavy cranes hoisted the entire 26-meter-tall reactor vessel out of its containment building, laid it onto a custom crawler, and drove it 600 meters to a specially built temporary storage building.
- *The Waiting Game and the Bill*: The vessel currently sits in this storage hall, where it will remain locked away for 40 to 60 years to allow the Strontium-90 and Cesium-137 (both with half-lives of roughly 30 years) to naturally decay. Despite being a tiny 15 MWe experimental reactor, the decommissioning bill has already surpassed €700 million and is projected to ultimately cost German taxpayers between €1.5 and €2.5 billion.
- **The THTR-300 Mechanical Failure and Scandal (1983–1989)**: Germany scaled up to a 300 MWe commercial prototype called the Thorium High-Temperature Reactor (THTR-300). It was an unmitigated operational disaster.
  - *Pebble Crushing*: Unlike modern designs that insert control rods into the outer graphite reflector, control rod insertion into channels interacting with the moving pebble bed caused mechanical stresses. This caused immense friction, crushing thousands of pebbles, generating massive amounts of radioactive dust, and jamming the fuel extraction tubes.
  - *The 1986 Cover-Up*: On May 4, 1986—just days after the Chernobyl disaster—a pebble became jammed in a pipe. While trying to clear it, operators vented radioactive helium and dust directly into the environment. When radioactivity was detected around the plant, operators initially lied and blamed it on Chernobyl fallout. The cover-up was exposed, causing a public scandal that effectively killed the German pebble-bed program.

## 7.2 Channel Blockages: The Saint-Laurent Meltdowns

While not Helium-cooled HTGRs, the French Saint-Laurent reactors (which were Carbon Dioxide-cooled and graphite-moderated UNGG reactors) highlight a key vulnerability in solid-moderator designs: keeping the coolant channels clear.

- **The 1969 Accident**: An error during fuel loading restricted the flow of  $CO_2$  coolant in a single channel. The localized loss of cooling caused the magnesium-zirconium cladding to spike in temperature, resulting in the melting of 50 kg of uranium.
- **The 1980 Accident**: A metal sheet physically detached from within the primary cooling circuit and partially blocked coolant flow to the core. This triggered a partial core meltdown, resulting in 20 kg of highly irradiated uranium melting inside the reactor.
- **The Takeaway**: While the scale was relatively small and the radiation was primarily contained within the vessel (though the 1980 event required venting some pressure), these represent the two most severe nuclear accidents in French history (INES Level 4). They serve as a stark reminder that solid-core geometries are highly susceptible to localized flow blockages from debris.

## 8 Thermal-Hydraulic Vulnerabilities: Solid vs. Liquid Moderators

A critical engineering thread connecting the historical failures of gas-cooled reactors is their vulnerability to localized flow blockages and flow maldistribution. This represents a fundamental divergence in reactor physics between solid-moderated gas reactors and liquid-moderated water reactors.

### 8.1 The Neutronic Disconnect: Local vs. Global Feedback

The severity of a flow blockage is driven by the relationship between the coolant and the moderator:

- **LWRs (Coupled Feedback):** In a PWR or BWR, water serves as both the coolant and the moderator. If a flow channel is partially blocked by debris, the water locally overheats and its density drops (or it boils into steam). Because the moderator is physically disappearing from that specific spot, thermalization drops, and the local fission rate immediately decreases. The physics inherently self-corrects the localized heat spike.
- **HTGRs (Decoupled Feedback):** In an HTGR, the Helium (coolant) and Graphite (moderator) are entirely decoupled. Helium is virtually transparent to neutrons. If debris blocks a channel, the helium flow stops, but the solid graphite block remains locked in place. The graphite continues to perfectly moderate neutrons, meaning the fuel in the blocked channel continues to generate 100% of its normal power with near-zero active cooling. The heat simply builds up until it can thermally conduct through the solid graphite to a neighboring, unblocked channel.

### 8.2 Geometric Susceptibility

While LWRs utilize rigidly spaced fuel assemblies that make large-scale blockages difficult, graphite cores rely on geometries that are inherently susceptible to flow issues:

- **Prismatic Blockages:** In channel-type reactors (like Saint-Laurent or Fort St. Vrain), coolant flows through narrow holes drilled into stacked graphite blocks. If a block shifts slightly due to thermal expansion, or if foreign debris (like the Saint-Laurent metal sheet) covers a hole, that specific channel is entirely starved of coolant, leading to rapid localized overheating.
- **Pebble Bed Bypass Flow:** While pebble beds do not have strict "channels," they suffer heavily from flow channeling and bypass flow. A pebble bed is a randomly packed bed. If pebbles pack too tightly in one specific region, the physical flow resistance spikes. The helium coolant simply takes the path of least resistance and flows *around* the dense region. This leaves the tightly packed core regions starved of cooling, creating massive "hot spots" (which is exactly what caused the severe fuel overheating and fission product release in the German AVR).

### 8.3 The TRISO Solution

Modern HTGR engineering accepts that localized flow blockages and pebble-bed hot spots are mechanically inevitable over the multi-decade lifespan of a reactor. Rather than trying to guarantee mathematically perfect helium flow, the modern solution is purely material: TRISO fuel. Engineers

rely on the fact that even if a local hot spot reaches  $1500^{\circ}\text{C}$  due to bypass flow, the SiC layer in the TRISO particle will safely maintain containment until the heat can conduct its way out of the core structure.

## 9 Evaluating the “Walk-Away Safe” Claim of Pebble Bed HTGRs

The primary safety claim of the High-Temperature Gas-Cooled Reactor (HTGR) is that it is “walk-away safe”—meaning that in the event of a total loss of cooling, the reactor will safely shut down and cool itself without human intervention or active mechanical systems.

To evaluate this claim, we must look past the bulk averages and examine the absolute physical limits of the system. Because the core has a strong negative temperature coefficient, any significant temperature rise will inherently subcriticalize the reactor. Therefore, the safety case is entirely a race between decay heat generation and passive heat removal.

The ultimate barrier to radiation release is the Silicon Carbide (SiC) layer in the TRISO fuel particles. This layer slowly begins to degrade and release fission products (like Strontium-90) above  $1600^{\circ}\text{C}$ , significant degradation and fission product release become increasingly likely above  $\sim 1600\text{--}1800^{\circ}\text{C}$  and it experiences rapid failure above  $2000^{\circ}\text{C}$ . Therefore, the core must never reach these temperatures.

### 9.1 The Starting Temperature Problem: The AVR Experience

Accident models often assume a uniform starting temperature. Under normal operation, the bulk average outlet gas temperature is roughly  $750^{\circ}\text{C}$ , and the average fuel pebble sits around  $900^{\circ}\text{C}$  to  $1000^{\circ}\text{C}$ .

However, pebble beds are randomly packed, which inevitably leads to local variations in packing density. Denser clusters of pebbles create higher flow resistance, causing the helium coolant to bypass these regions. This phenomenon was proven dramatically during the operation of the German AVR reactor. In 1986, engineers sent “monitor pebbles” containing melt wires through the core. While the bulk coolant was at normal temperatures, the melt wires revealed that macroscopic clumps of pebbles were experiencing severe “hot spots,” with local temperatures reaching between  $1350^{\circ}\text{C}$  and  $1420^{\circ}\text{C}$ . If an accident occurs, these hot spots have a vastly reduced thermal margin to the  $1800^{\circ}\text{C}$  failure point.

### 9.2 Adiabatic Temperature Rise Calculations

If we assume as a bounding case that a localized flow blockage completely isolates a clump of pebbles (an adiabatic heat-up), we can calculate how quickly they will fail using only decay heat. To justify this mathematically, we can apply the physical parameters of the Chinese HTR-PM commercial reactor.

The relevant design parameters for a single HTR-PM module are as follows:

- **Thermal Power ( $P_{th}$ ):** 250 MWth
- **Core Inventory ( $N$ ):** 420,000 pebbles
- **Mass per Pebble ( $m$ ):**  $\approx 0.2\text{ kg}$  (6 cm diameter graphite sphere)
- **Specific Heat of Graphite ( $c_p$ ):**  $\approx 1800\text{ J}/(\text{kg} \cdot ^{\circ}\text{C})$  at elevated accident temperatures
- **Initial Decay Heat Fraction:** 6% of nominal power immediately after scram

- **Local Power Peaking Factor ( $F_p$ ):**  $\approx 1.7$  for the central high-flux zone

First, we determine the average steady-state thermal power generated by a single pebble under normal operation:

$$P_{avg} = \frac{250 \times 10^6 \text{ W}}{420,000 \text{ pebbles}} \approx 595 \text{ W/pebble}$$

To analyze the worst-case blocked hot spot, we must account for the local power peaking factor in the center of the core. Immediately following a scram, the decay heat generated by a single pebble in this hot zone is:

$$P_{decay,hot} = P_{avg} \times 0.06 \times 1.7 \approx 60.7 \text{ W (or J/s)}$$

Over the course of one minute, the total thermal energy ( $Q$ ) deposited into this isolated pebble is:

$$Q_{min} = 60.7 \text{ J/s} \times 60 \text{ s/min} = 3642 \text{ J/min}$$

Using the specific heat capacity formula ( $\Delta T = \frac{Q}{m \cdot c_p}$ ), we calculate the adiabatic temperature rise per minute:

$$\Delta T = \frac{3642 \text{ J/min}}{0.2 \text{ kg} \times 1800 \text{ J/(kg} \cdot ^\circ\text{C)}} \approx 10.1^\circ\text{C/min}$$

This derivation confirms that immediately following a scram, an uncooled hot-spot pebble will heat up at approximately  $10^\circ\text{C}$  per minute.

- **Scenario A (Normal Average Pebble):** Starting at  $1000^\circ\text{C}$ .

$$\text{Time to Failure} = \frac{1800^\circ\text{C} - 1000^\circ\text{C}}{10^\circ\text{C/min}} = 80 \text{ minutes}$$

- **Scenario B (AVR-style Hot Spot):** Starting at  $1400^\circ\text{C}$ .

$$\text{Time to Failure} = \frac{1800^\circ\text{C} - 1400^\circ\text{C}}{10^\circ\text{C/min}} = 40 \text{ minutes}$$

Without convective heat transfer to pull this energy away, a pre-existing hot spot clump could theoretically begin leaking Strontium in under an hour.

### 9.3 Heat Transfer Mechanics and Geometric Limits

Fortunately, the core is not perfectly adiabatic. Heat moves outward through the pebble bed via two mechanisms:

1. **Conduction:** This is poor in a pebble bed relative to a prismatic core because the spherical shape means pebbles only touch at microscopic point contacts.
2. **Radiation:** This is the dominant heat transfer mechanism at high temperatures, as the effective radiative conductivity scales approximately as  $T^3$  (arising from the  $T^4$  dependence of thermal radiation).

Because the effective thermal conductivity ( $k_{eff}$ ) of a pebble bed is generally low, the physical distance the heat must travel becomes the critical limiting factor. We can demonstrate this by modeling the reactor core as an infinite cylinder with uniform internal heat generation. The steady-state heat conduction equation in 1D cylindrical coordinates is:

$$\frac{1}{r} \frac{d}{dr} \left( r k_{eff} \frac{dT}{dr} \right) + q''' = 0$$

where  $q'''$  is the volumetric heat generation rate (decay heat in  $W/m^3$ ).

Integrating this equation twice and applying the boundary conditions for a solid cylinder—symmetry at the center ( $\frac{dT}{dr} = 0$  at  $r = 0$ ) and a known surface temperature at the edge ( $T = T_s$  at  $r = R$ )—yields the radial temperature profile:

$$T(r) = T_s + \frac{q'''}{4k_{eff}} (R^2 - r^2)$$

The absolute peak temperature occurs at the core centerline ( $r = 0$ ):

$$T_{max} = T_s + \frac{q''' R^2}{4k_{eff}}$$

Therefore, the temperature difference between the center of the core and the outer reflector wall is:

$$\Delta T = \frac{q''' R^2}{4k_{eff}}$$

This equation is the defining architectural constraint of all modern High-Temperature Gas Reactors. During a loss-of-coolant accident, the decay heat ( $q'''$ ) is dictated by physics, and the effective thermal conductivity ( $k_{eff}$ ) is inherently poor due to the pebble bed geometry.

Therefore, the *only* variable designers can control to ensure the centerline temperature ( $T_{max}$ ) remains strictly below the 1600°C safety limit is the radius of the core ( $R$ ). Because the temperature penalty scales with the **square of the radius** ( $R^2$ ), modern designs are strictly geometrically limited to skinny, annular, or highly restricted cylindrical cores. For example, the Chinese HTR-PM utilizes a core that is just 3 meters in diameter (a radius of only 1.5 meters) but 11 meters tall.

## 9.4 Failure Modes: PLOFC vs. DLOFC

When assessing a loss of cooling, we must distinguish between two distinctly different physical scenarios:

- **Pressurized Loss of Forced Cooling (PLOFC):** The primary blowers fail, but the helium loop remains intact and pressurized (e.g., at 7 MPa). Because the helium is dense and the core is tall, strong natural convection loops form (the chimney effect). This rapidly equalizes core temperatures and keeps peak temperatures well below 1200°C. China successfully tested this exact scenario on the commercial HTR-PM in 2023, proving the system safely cools itself.
- **Depressurized Loss of Forced Cooling (DLOFC):** A primary coolant pipe shears, and the pressurized helium completely escapes into the confinement building. The density of the helium drops to atmospheric levels (0.1 MPa), shutting down all natural convection. The reactor relies purely on solid-state conduction and radiation. Because the helium cannot be

easily replaced, recovery is very difficult, and it takes up to 30 hours for the central hot spots to slowly radiate their heat to the outer walls, pushing the peak temperatures dangerously close to the 1600°C regulatory limit - and potentially exceed it in the presence of initial hot spots. Note that it is not necessary for a pipe to break for such an accident scenario: the HTR-PM helium line is equipped with pressure relief valves which open automatically and close again when the pressure drops below the normal operating pressure (6.9MPa setting). All that needs to occur for a DLOFC is for the valve to get stuck open and additional safety mechanisms to fail, analogous to what triggered the TMI-2 accident.

## 9.5 The Ultimate Threat: Air Ingress


A DLOFC introduces a secondary, potentially catastrophic threat. Once the helium escapes and reactor pressure equalizes with the building, atmospheric air can flow backward through the broken pipe into the core. The reactor is essentially a giant 11-meter chimney filled with 1400°C carbon. If oxygen enters, the graphite will rapidly oxidize at high temperatures, causing an exothermic oxidation reaction that burns away the fuel's structural integrity. To mitigate this, some HTGR designs propose flooding the reactor cavity with inert Nitrogen gas, while others rely on highly restrictive cavity designs to naturally choke the oxygen supply. Regardless, air ingress remains one of the most severe design-basis vulnerabilities.

## 9.6 The Water Ingress Vulnerability

To achieve the high thermal efficiencies characteristic of HTGRs, the secondary Rankine cycle must operate at extremely high temperatures and pressures. Consequently, the water/steam in the steam generator is maintained at a significantly higher pressure than the primary helium coolant. In the Chinese HTR-PM, for example, the primary helium loop operates at 7 MPa, while the secondary steam pressure in the heat exchanger is approximately 13.2 MPa (nearly double the primary pressure).

Because of this severe pressure differential ( $P_{steam} > P_{helium}$ ), any crack or leak in the steam generator tubes will not result in radioactive helium escaping. Instead, high-pressure water and steam will be forcefully driven backward into the primary helium loop and flooded into the hot reactor core.

When high-pressure steam contacts the 1000°C+ graphite pebbles and reflector blocks, it initiates the steam-graphite reaction:



This reaction physically eats away the graphite moderator and structural internals. Fortunately, the steam does not chemically react with the Silicon Carbide (SiC) shell of the TRISO fuel particles. Because the SiC layer remains intact, a water ingress event does not typically result in the direct release of fission products from the fuel itself.

However, the secondary consequences are severe. The reaction causes considerable degradation of the reactor internals and generates massive quantities of potentially explosive hydrogen ( $H_2$ ) and carbon monoxide ( $CO$ ) gases inside the primary loop. If the loop overpressurizes and vents into the confinement building, this creates a significant explosion hazard.

Historically, chronic water ingress was the Achilles' heel of early HTGRs. The American Fort St. Vrain reactor, for instance, was ultimately doomed by recurrent water ingress issues—though in that specific design, the water leaked from the water-lubricated bearing seals of the helium circulators rather than the steam exchangers.

To mitigate this catastrophic risk, modern HTGRs are equipped with highly sensitive moisture detectors in the primary helium coolant stream. If even trace amounts of water vapor are detected, the reactor must immediately scram, and the steam generator must be rapidly isolated and blown down. While this protects the core, it makes the reactor highly sensitive to minor leaks, leading to frequent trips and representing a significant worry for the long-term commercial availability and uptime of the plant.

## 9.7 The Imperfection of TRISO

Finally, the “functional containment” argument—which suggests the reactor does not need a traditional concrete containment dome because the TRISO fuel acts as its own containment—relies on the assumption that TRISO particles are perfect. In reality, manufacturing tolerances dictate a baseline defect fraction. Studies have shown that high-quality TRISO has a defect rate between  $1 \times 10^{-5}$  and  $1 \times 10^{-4}$ . In a commercial core containing billions of microscopic fuel particles, tens of thousands of particles are inherently defective before the reactor even turns on. During a severe DLOFC, these defective particles will act as immediate pathways for fission product release into the now-vented confinement building.

## 10 Summary: The HTGR Trade-Off

The evolution of the High-Temperature Gas Reactor represents a fascinating shift in nuclear engineering philosophy—and a fundamental shift in how these reactors fail. By moving away from water and embracing helium, graphite, and TRISO coated-particle fuel, engineers have effectively eliminated the risks of rapid, catastrophic light-water disasters such as high-pressure steam explosions or positive void coefficient excursions. From a global neutronic perspective, the core is remarkably stable and thermally forgiving.

However, as historical operations have proven, this neutronic elegance is paid for with severe mechanical and material vulnerabilities. Rather than suffering from sudden thermal-hydraulic crises, HTGRs are highly susceptible to chronic, localized, and mechanical failures. As demonstrated by Fort St. Vrain, the AVR, and the THTR-300, the operational hurdles are immense: preventing water ingress from secondary loops, extracting massive pebble beds without crushing the fuel, containing highly abrasive and radioactive graphite dust, and surviving inevitable localized flow blockages.

The true test of the 21st-century HTGR renaissance—led by designs like the Chinese HTR-PM and the X-energy Xe-100—is whether modern innovations such as active magnetic bearings and ultra-resilient TRISO fuel have finally addressed these historical shortcomings. If so, the HTGR promises a future of 40%+ thermal efficiencies and the ability to directly decarbonize heavy industrial process heat.

## References and Further Reading

- **Textbooks:** Lamarsh, J.R. & Baratta, A.J., *Introduction to Nuclear Engineering*. Section 4.5 (Gas Cooled Reactors).
- **World Nuclear Association:** “Nuclear Power in China” (Comprehensive details on the HTR-PM and HTR-PM 600 pebble bed reactors and their commercial deployment).  
<https://world-nuclear.org/information-library/country-profiles/countries-a-f/china-nuclear-power.aspx>

- **U.S. Department of Energy:** "TRISO Particles: The Most Robust Nuclear Fuel on Earth."  
<https://www.energy.gov/ne/articles/triso-particles-most-robust-nuclear-fuel-earth>
- **U.S. Nuclear Regulatory Commission (NRC):** "Fort Saint Vrain Gas Cooled Reactor Operational Experience" (NUREG/CR-6839). Details the historical operational challenges, specifically water incursion events.  
<https://www.nrc.gov/reading-rm/doc-collections/nuregs/contract/cr6839/index.html>
- **Wikipedia:** "High Temperature Gas Cooled Reactor" (Nice summary of the reactor concept with many references).  
[https://en.wikipedia.org/wiki/High-temperature\\_gas-cooled\\_reactor](https://en.wikipedia.org/wiki/High-temperature_gas-cooled_reactor)
- **X-energy:** "The Xe-100 Reactor" (Example of a modern commercial pebble-bed design).  
<https://x-energy.com/reactors/xe-100>
- **AVR Safety Re-evaluation (The Whistleblower Report):** Moormann, R. "A safety re-evaluation of the AVR pebble bed reactor operation and its consequences for future HTR concepts." *Kerntechnik* 74.1-2 (2009): 8-21. The seminal paper that exposed the extreme core temperatures, operational cover-ups, and radioactive dust contamination in the German pebble-bed program.  
<https://juser.fz-juelich.de/record/1304>
- **Official AVR Investigation:** Hahn, L., et al. "The AVR Experimental Reactor – Development, Operation, and Incidents: Final Report of the AVR Expert Group." *Forschungszentrum Jülich* (2014). The independent expert inquiry detailing the operational failures and the staggering concrete-sarcophagus decommissioning reality of the AVR.  
[https://www.fz-juelich.de/en/news/archive/press-release/2014/docs/report-avr-expert-group-summary/@download/file/report-avr-expert-group\\_summary.pdf](https://www.fz-juelich.de/en/news/archive/press-release/2014/docs/report-avr-expert-group-summary/@download/file/report-avr-expert-group_summary.pdf)
- **French Nuclear Safety Authority (ASN):** "Nuclear accidents and developments in nuclear safety and radiation protection." *Les cahiers Histoire de l'ASN #01* (2023). Covers the severe 1969 and 1980 partial core meltdowns caused by graphite and metallic debris blocking the coolant channels at the Saint-Laurent plant. Found on p. 8-9 in French.  
<https://www.asn.fr/publications/2024/Les-cahiers-Histoire-de-lASN-01/27/>
- **Thermal-Hydraulic Vulnerabilities in Gas Reactors:** Martin, C. R., "Perspectives on Understanding and Verifying the Safety Terrain of Modular High Temperature Gas-Cooled Reactors." *Proceedings of the 7th International Topical Meeting on High Temperature Reactor Technology (HTR 2014)*. An excellent engineering analysis detailing the historical evidence of core bypass flows, localized operating hot spots, and the thermodynamic challenges inherent to solid-moderator HTGR cores.  
<https://nucleus-new.iaea.org/sites/htgr-kb/HTR2014/Paper%20list/Track8/HTR2014-81367.pdf>
- Zhang, Z., Dong, Y., Li, F., Huang, X., Zheng, Y., Dong, Z., Zhang, H., Chen, Z., & Li, X. (2024). Loss-of-cooling tests to verify inherent safety feature in the world's first HTR-PM nuclear power plant. *Joule*, 8(7), 2146–2159. <https://doi.org/10.1016/j.joule.2024.06.014>



- Zheng, Y., Shi, L., & Wang, R. (2018). Study on the DLOFC and PLOFC accidents of the 200 MWe pebble-bed modular high temperature gas-cooled reactor with TINTE and SPECTRA codes. *Annals of Nuclear Energy*, 120, 763–777. <https://doi.org/10.1016/j.anucene.2018.06.041>
- Demkowicz, P. A., Liu, B., & Hunn, J. D. (2019). Coated particle fuel: Historical perspectives and current progress. *Journal of Nuclear Materials*, 515, 434–450. <https://doi.org/10.1016/j.jnucmat.2018.09.044>