
COMPOSITE TOTALJOIST FRAMING FOR

HENRICKS HOME

541 BLOOMFIELD RIDGE S RD, ESN 474, NEW BRUNSWICK



SHEET LIST					
SHEET NUMBER	CURRENT REVISION DATE	CURRENT REVISION	SHEET NAME		
S.00	2022-07-14	2	COVER PAGE		
S.100	2022-07-14	2	NOTES / SCHEDULES		
S.200	2022-07-14	2	1ST FLOOR FRAMING PLAN		
S.200.1	2022-07-14	2	1ST FLOOR JOIST HOLE LAYOUT PLAN		
S.201	2022-07-14	2	2ND FLOOR FRAMING PLAN		
S.201.1	2022-07-14	2	2ND FLOOR JOIST HOLE LAYOUT PLAN		
S.500	2022-07-14	2	COMPOSITE FASTENING DETAILS		
S.501	2022-07-14	2	FLOOR DETAILS		
SL.200	2022-07-14	2	1ST FLOOR BUNDLE PLAN		
SL.201	2022-07-14	2	2ND FLOOR BUNDLE PLAN		



	CONSULTANT DRAWING REVISION SCHEDULE						
ARCHITECTURAL REVISION	ARCHITECTURAL REVISION DATE	ELECTRICAL REVISION	ELECTRICAL REVISION DATE	MECHANICAL REVISION	MECHANICAL REVISION DATE	STRUCTURAL REVISION	STRUCTURAL REVISION DATE
1	2022-06-13	N/A	N/A	N/A	N/A	1	2022-06-13



2022/04/08

SCALE:

2022-07-21 1:56:56 PM

GENERAL NOTES

- 1.0 The design of the work displayed on these drawings is in accordance with the NBCC 2020, CSA standard S136-16 North American standard for the design of cold formed steel structural members, CSA A23.3-14 design of concrete structures and CAN/CSA S16-19 design of steel structures.
- These drawings are to be read in conjunction with the structural, architectural, mechanical, and electrical drawings. The owner (or appointed representative) and the contractor shall check the drawings for conflicts in dimensions and locations of building components related to the work shown on these drawings. Any discrepancies shall be reported to iSPAN Systems LP before the start of the fabrication process.
- 3.0 Provision for future expansion or alterations:
 - 3.01 The structure has not been designed for future lateral expansion.
 3.02 The structure has not been designed for future vertical expansion.
- The installer shall notify iSPAN Systems LP of any damage to product prior to it being installed and within 24 hours of delivery. iSPAN will address the damage promptly and / or agree on a solution to proceed at iSPAN's cost. If damaged product is installed or notification is given later than 24 hours from delivery, the installer shall be responsible for the cost of labour and material to repair damaged materials.
- 5.0 iSPAN Systems LP issues drawings for various stages of a job. Information presented on these drawings may differ from drawings and / or documents provided by other firms and / or from perviously submitted drawings by iSPAN Systems LP. Differences may be from, but not limited to, interpretations of contract requirements, provisions for structural performance, or manufacturing capabilities. The most recent set of drawings sealed by an iSPAN engineer take precedence over all previous drawings / documents. The customer shall perform a thorough review of all items shown on each drawing set recieved in order to confirm adherence to the contract requirements.
- Approval from the customer, or delegated customer representative is required in order to proceed with manufacturing / fabrication. When the approval stamp is present, please sign and date each drawing and clearly indicate any changes required. Failure to do so in a timely manner may result in project delays or additional costs. Changes requested on the drawings are not binding unless subsequently agreed to in writing by iSPAN Systems LP. Approval of iSPAN drawings constitute agreement that the iSPAN products as shown represents the total of the materials to be supplied. Any change request that occurs after approval may result in additional costs and delays.

LOADING

- .0 General
- 1.01 The structure has been designed for the loads shown on these drawings only. No other loads have been considered in the design including, but not limited to, lateral loads, loads to support top of concrete / masonry walls, loads to brace beams by others, etc.
- 1.02 If additional loading is required that is not shown on these drawings, the consultant responsible for the design of the element imposing load shall provide the following to iSPAN:
 - Specified load magnitude and type.
- ii. Specified load location at all locations where loads are imposed.
- 2.0 Gravity Loads

<u>Floors</u>		
Live Loads		
Units	40 psf	
Dead Loads		
CTJ W/ 4" SLAB	75 psf	

- 2.01 Garage floor system is designed for a 4050lb point load at any location.2.02 See plans for special loading areas.
- 3.0 Lateral Loads
- 3.01 Design of lateral force resisting system, including vertical (e.g., shear walls) and horizontal (e.g., diaphragm, collectors, drag struts) lateral force resisting systems by others.
- 4.0 Deflection Limits

Floor		Roof	
LIVE LOAD	L/480	LIVE LOAD	L/360
TOTAL LOAD	L/240	TOTAL LOAD	L/180

<u>MATERIAL</u>

- 1.0 Miscellaneous Metals
 - 1.01 All miscellaneous materials shall be designed by others. Where loads are imposed on the structure from the miscellaneous materials, the designer of the miscellaneous materials shall inform iSPAN of location(s), load type and magnitude of all loads.
 - 1.02 Elements not specified upon these drawings shall be deemed as miscellaneous metals.
 - 1.03 Examples of miscellaneous materials include, but are not limited to, ladders, railings, stair stringers, risers, treads, permanent seating and associated framing, permanent shelving and associated framing, grating, framing to support finishing materials, etc.
- 2.0 CFS Material
 - CFS Material
 2.01 18ga joists: ASTM A653 SS grade 50.
 - 2.01 18ga joists: ASTM A653 SS grade 50. 2.02 16ga and 14ga joists: ASTM A653 HSLAS grade 60
 - 2.03 Galvanized coating thickness is minimum G602.04 All other sheet metal: ASTM A653 SS grade 50 U.N.O.
- 3.0 Fasteners
 - 3.01 Anchor bolts conform to ASTM A307 grade C.
 - 3.02 Structural bolts, nuts and washers conform to ASTM F3125 A325.
 3.03 Sheet steel screws shall be ITW self drilling, self tapping screws or equivalent.
 - 3.04 All sheet steel screws and connectors shall be corrosion resistant. minimum coating 0.0007" of mechanical zinc.
- 4.0 Welded Connections
 - 4.01 Arc welding shall be performed by a fabricator certified in accordance with appropriate AWS standards and procedures for the type and position of welding being performed.
 - 4.02 Arc welds thickness from 1/32" to 1/8": Welding shall conform to the requirements of AISI S100 and shall be performed with the applicable requirements of AWS D1.3.
 4.03 When welding thicknesses over 1/8", welding shall conform to AWS D1.3.
- 5.0 Concrete For Floors
- 5.01 Concrete shall be minimum 3000 psi compressive strength in accordance with ACI 318-[19].
- 5.02 Max water to concrete ratio of 0.55.
- 5.03 Max siliceous or carbonate aggregate in accordance with ACI 318-[19].
 5.04 Areas exposed to freezing and thawing shall have 6% to 8% air entrainment
- (class f1).
 5.05 Concrete in garage areas shall contain minimum 6x6 6/6 welded wire mesh.

cylinders per 100 yd³ and shall forward the test results to iSPAN.

5.05 Concrete in garage areas shall contain minimum 6x6 6/6 welded wire mesh.
 Concrete in all other areas may contain macro synthetic fiber approved included in UL G555 at a dosage of 4 lbs/yd³ in lieu of or in addition to welded wire mesh.
 5.06 Contractor shall coordinate compressive strength tests during each pour, min. 3

EXECUTION

- .0 General
 1.01 Fabrication and erection shall conform to the approved shop drawings. Modifications required to accommodate as-built conditions shall be submitted to iSPAN for approval
 - prior to making modifications.

 1.02 Any unauthorized modifications shall be repaired in accordance with iSPAN and / or engineer of record direction at the contractor's expense, including labour, materials, and
- 2.0 Factorers And Wolds
- 2.0 Fasteners And Welds2.01 Ensure that connected parts are in contact. Provide clamping before welding or
 - mechanically fastening as required.

 2.02 Companies engaged in welding shall be certified by the American Welding Society, see 'materials, section 4.0' for details.
 - 2.03 Touch-up welds and coatings damaged by welding with zinc rich paint according to ASTM A-780.
 - 2.04 Penetration of sheet metal screws beyond joined materials shall be not less than 3 exposed threads. Sheet metal screw installation shall conform to the manufacturer's
 - exposed threads. Sheet metal screw installation shall conform to the manufacturer's recommendations.
 - 2.05 Screws shall not be placed closer than 3 times the diameter from the edge of any part nor shall they be closer than 3 times the diameter to adjacent screws.
 - Sheet metal screws covered by sheathing materials shall have low profile heads.
 Install concrete anchors in accordance with manufacturer's recommendations, including drilling and cleaning procedures, minimum edge distance and minimum anchor spacing. (See iSPAN details for minimum anchor embedment as required).
- 2.0 Handling And Charage Of Matariala
- Handling And Storage Of Materials
 3.01 Products shall be protected from conditions that may cause physical damage or corrosion.
 3.02 Handling and lifting of prefabricated panels and joists shall not cause permanent distortion
- to any member or collateral material.
- 4.0 Erection
 - 4.01 Methods of construction may be either piece by piece (stick-built) or by fabrication into panels (panelized) either on or off site.
- 4.02 Do not exceed design loads during construction.
 4.03 Temporary bracing shall be employed wherever necessary to withstand all loads to which the structure may be subject to during erection and subsequent construction. Temporary bracing shall be left in place as long as required for the safety and integrity of the structure. The erector shall ensure that during the erection, a margin of safety consistent with the requirements of the IBC and AISI S100 exists in the uncompleted structure.
- 4.04 Framing shall be erected according to AISI S202 under the direct supervision of an
- approved and qualified foreman.
 4.05 Do not cut openings in framing members except when approved in writing by iSPAN.
 Cutting of steel members, when approved, shall be by saw or shear, torch cutting is not
- 4.06 For the purposes of this section, camber is defined as the deviation from straightness of a member or any portion of a member with respect to its major axis, and sweep is defined as the deviation from straightness of a member or any portion of a member with respect to its minor axis.
 - i. For joists, sweep shall not exceed 1/720 of the member length.
 - Align web cut-outs in joists for the installation of services.
- 4.08 Make all field measurements necessary to ensure the proper fit of all members.
 4.09 Members with localized damage are to be replaced unless a written repair detail is provided by iSPAN. Any damage shall be brought to attention of iSPAN immediately upon observation. Do not proceed until damage has been reviewed and direction has been provided in writing by iSPAN.
- For variances of underside of joist elevation, the drywall contractor shall include shimming (including labour and materials) within their scope.


0 Concrete Placement

- 5.01 Concrete shall be placed in accordance with ACI 301
- Concrete slab shall be placed to a constant thickness with a tolerance of +3/8" / 1/4".
 Floor flatness shall conform to:
 - 90% compliance with 1/4" maximum gap under a 10' unleveled straight
 - edge. . 100% compliance with 3/8" maximum gap under a 10' unleveled
- straight edge.
 iii. Testing of floor flatness to comply with ACI 117.
 5.04 Construction joints in concrete floors are to be placed:
 - i. Over supporting walls / beams when perpendicular to joists.
 - Centered between joists when parallel to joists.
- jii. Joint surfaces to be left rough and wire mech sheet to be centered on joint.
 Concrete contractor shall take all appropriate measure for cold weather application. Cold
- Concrete contractor shall take all appropriate measure for cold weather application. Cold weather application procedures are required when the temperature is expected to drop below 40°F within 24 hours of placing concrete as predicted by the nearest meteorological office:
 - General contractor to ensure all required materials and equipment for cold weather concreting are on hand and ready for use prior to placement of concrete. This may include but is not limited to, heaters, insulating blankets, tarps, and protection below the floor being poured. Ensure all snow and ice is removed from the deck and formwork.
 - Calcium chloride or other de-icing salts shall not be used to de-ice deck or formwork.

 iii. Deck and formwork shall be maintained at a temperature that will not allow the concrete temperature to drop below 50°F for a min. of 3 days after concrete placement or the time it takes to reach 40% of the
 - compressive strength.

 iv. After slab finishing is completed, immediately install insulating blankets over the entire slab for a min. of 3 days or the time it takes to reach 40% of the compressive strength.
 - of the compressive strength.


 v. Winter mix concrete is to be reviewed with the general contractor, engineer of record, and iSPAN.




1) MAX 4 HOLES IN ANY SINGLE ZONE.
2) LARGER HOLES MAY BE ACCOMMODATED, CONTACT ISPAN SYSTEMS LP.
3) HOLES SHALL BE MADE BY SAW OR DRILL. TORCH OR PLASMA CUTTING SHALL NOT BE USED.
4) FOR SQUARE OR RECTANGULAR SHAPED HOLES, ALWAYS ROUND CORNERS.

COMPOSITE TOTALJOIST - ALLOWABLE

HOLES IN JOIST







ABBREVIATION

NOTES:
1. SERVICE HOLES ARE LOCATED 30" [763mm] FROM MEMBER ENDS, AND 36" [914mm] O/C FOR, UNLESS SPECIFIED OTHERWISE
2. SEE PLANS FOR SPECIFIC HOLE LOCATIONS NOTED FOR SERVICE COORDINATION

JOIST HOLE LOCATIONS - COMPOSITE


TOTAL JOIST

ABBREVIATION	DEFINITION
	la T
@	ANCHOR BOLT
A Bolt	
B PL	BASE (BEARING) PLATE
B.F.	BOTTOM FACE
BBO	BEAM BY OTHERS
BLDG	BUILDING
c/c, o/c or o.c.	CENTER TO CENTER
CA OR PA	COLUNN, POST ABOVE
CANT	CANTILEVER
CBO	COLUMN BY OTHERS
CFS	COLD FORMED STEEL
CL	CENTER LINE
COL	COLUMN
CONC	CONCRETE
CONT	CONTINUOUS
DIM	DIMENSION
DJ	DOUBLE JOIST
DL	DEAD LOAD
DO	DITTO
DWG(S)	DRAWING(S)
E.E.	EACH END
E.F.	EACH FACE
EA	EACH
EL	ELEVATION
EQ	EQUAL
EXIST	EXISTING
EXT	EXTERIOR
F.F.	FAR FACE
F.F.E.	FINISH FLOOR ELEVATION
FDN	FOUNDATION
FIN	FINISHED
FTG	FOOTING
GA	GAUGE
GALV	GALVANIZED
GT	GIRDER TRUSS
INT	INTERIOR
kg	KILOGRAM
Kip	1000 LBS
kN	KILONEWTON
kN-m	KILONEWTON METER

κN/m	KILONEWTON PER METER	
(N/m²	KILONEWTON PER SQUARE METER	-
«Pa	KILOPASCAL	=
Ksi	1000 Psi	
bs	POUNDS	
_L	LIVE LOAD	
M	METRE	
MAX	MAXIMUM	
МС	MOMENT CONNECTION	
MEZZ	MEZZANNINE	
MIN	MININUM	
MISC	MISCELLANEOUS	
MPa	MEGAPASCAL	
V	NEWTON	
N.F.	NEAR FACE	
NBI	NOT BY ISPAN	
No	NUMBER	
NTS	NOT TO SCALE	
OSB	ORIENTED STRAND BOARD	
Pa	PASCAL	
PL	PLATE	
Psi	POUNDS PER SQUARE INCH	
REF	REFERENCE	
REQ'D	REQUIRED	
REV	REVISION, REVISED	
S.I.	SHOP INSTALLED	
SL	SNOW LOAD	
SPEC'S	SPECIFICATIONS	
SQ	SQUARE	
STD	STANDARD	
Г&В	TOP AND BOTTOM	
Γ.F.	TOP FACE	
Г.О.	TOP OF	
ГВС	TO BE COORDINATED	
ΓJ	TIE JOIST	
ГҮР	TYPICAL	
J/N, UNO	UNLESS NOTED OTHERWISE	
J/S	UNDERSIDE	
N.C.	CENTERED IN WALL	
ΝL	WIND LOAD	
Ø	DIAMETER	


LIST OF ABBREVIATIONS


DEFINITION



HOLE SIZING						
A		В				
WIDTH	HEIGHT	WIDTH	HEIGHT	C DIAMETER		
2-1/4" [57mm]	2" [51mm]	3-1/4" [83mm]	1-3/8" [35mm]	2" [51mm]		
4" [102mm]	3-1/2" [89mm]	6" [152mm]	2-1/4" [57mm]	3-1/2" [89mm]		
6-5/8" [168mm]	6" [152mm]	9-7/8" [251mm]	4" [102mm]	6" [152mm]		
8-1/4" [210mm]	8" [203mm]	12-3/4" [324mm]	5-5/8" [143mm]	8" [203mm]		
9" [229mm]	10" [254mm]	14-5/8" [371mm]	6-7/8" [175mm]	10" [254mm]		
	WIDTH 2-1/4" [57mm] 4" [102mm] 6-5/8" [168mm] 8-1/4" [210mm]	A WIDTH HEIGHT 2-1/4" [57mm] 2" [51mm] 4" [102mm] 3-1/2" [89mm] 6-5/8" [168mm] 6" [152mm] 8-1/4" [210mm] 8" [203mm]	A WIDTH HEIGHT WIDTH 2-1/4" [57mm] 2" [51mm] 3-1/4" [83mm] 4" [102mm] 3-1/2" [89mm] 6" [152mm] 6-5/8" [168mm] 6" [152mm] 9-7/8" [251mm] 8-1/4" [210mm] 8" [203mm] 12-3/4" [324mm]	A B WIDTH HEIGHT WIDTH HEIGHT 2-1/4" [57mm] 2" [51mm] 3-1/4" [83mm] 1-3/8" [35mm] 4" [102mm] 3-1/2" [89mm] 6" [152mm] 2-1/4" [57mm] 6-5/8" [168mm] 6" [152mm] 9-7/8" [251mm] 4" [102mm] 8-1/4" [210mm] 8" [203mm] 12-3/4" [324mm] 5-5/8" [143mm]		

HOLE SIZING/PLACEMENT







ALL DRAWINGS AND SPECIFICATIONS ARE THE PROPERTY OF ISPAN SYSTEMS LP AND MAY NOT BE USED OR REPRODUCED WITHOUT THE WRITTEN APPROVAL OF ISPAN SYSTEMS LP.

READ THE DRAWING IN CONJUNCTION WITH THE STRUCTURAL, ARCHITECTURAL, MECHANICAL,

AND ELECTRICAL DRAWINGS. THE OWNER (OR APPOINTED REPRESENTATIVE) AND THE CONTRACTOR SHALL CHECK THE DRAWINGS FOR CONFLICTS IN DIMENSIONS AND LOCATIONS OF BUILDING COMPONENTS RELATED TO THE WORK SHOWN ON THE DRAWINGS. ANY DISCREPANCIES SHALL BE REPORTED TO ISPAN SYSTEMS LP BEFORE THE START OF THE WORK SHOWN.

DRAWINGS SHALL NOT BE SCALED.

CLIENT NAME

ELLIS HENRICKS

PROJECT NAME

SHEET NAME

HENRICKS HOME

541 BLOOMFIELD RIDGE S RD, ESN 474, NEW

NOTES / SCHEDULES

DRAWN BY: CHECKED: CURRENT ISSUE:

NL MS ISSUED FOR CONSTRUCTION


PROJECT NO.: DRAWING NO. **20221736**

DATE: **2022/04/08**

As indicated

SCALE:

S.100



JOIST SPACE CANNOT EXCEED 48" O.C.

JOIST OBSTRUCTION FRAMING

TOPPING THICKNESS:

T.O. STEEL ELEVATION:

T.O. CONCRETE ELEVATION: 8' - 11"

4" U.N.O.

4" BELOW TOP OF SLAB U.N.O.

DATE:

SCALE:

2022/04/08

As indicated

PLAN

2022-07-14


2022-06-15 DATE

1 01 - T.O. 1ST FLOOR HOLE CHECK 3/8" = 1'-0"

NOTES:

• DIMENSIONS ARE TAKEN FROM STRUCTURAL SUPPORT TO START OF ROLL FORMED JOIST SECTION, AND THEN TO HOLE EACH LOCATION

SEPARATION IN THICKENED -LINE REPRESENTS HOLE LOCATION





70 BRENTWOOD DRIVE PRINCETON, ON., NOJ 1V0 W: www.ISPANsystems.com

ALL DRAWINGS AND SPECIFICATIONS ARE THE PROPERTY OF ISPAN SYSTEMS LP AND MAY NOT BE USED OR REPRODUCED WITHOUT THE WRITTEN APPROVAL OF ISPAN SYSTEMS LP.

READ THE DRAWING IN CONJUNCTION WITH THE STRUCTURAL, ARCHITECTURAL, MECHANICAL, AND ELECTRICAL DRAWINGS. THE OWNER (OR APPOINTED REPRESENTATIVE) AND THE CONTRACTOR SHALL CHECK THE DRAWINGS FOR CONFLICTS IN DIMENSIONS AND LOCATIONS OF BUILDING COMPONENTS RELATED TO THE WORK SHOWN ON THE DRAWINGS. ANY DISCREPANCIES SHALL BE REPORTED TO ISPAN SYSTEMS LP BEFORE THE START OF THE WORK SHOWN.

DRAWINGS SHALL NOT BE SCALED.

CLIENT NAME

ELLIS HENRICKS

PROJECT NAME

HENRICKS HOME

541 BLOOMFIELD RIDGE S RD, ESN 474, NEW
BRUNSWICK

SHEET NAME 1ST FLOOR JOIST HOLE

LAYOUT PLAN DRAWN BY: CHECKED: CURRENT ISSUE:

SCALE:


As indicated

ISSUED FOR CONSTRUCTION


PROJECT NO.: DRAWING NO.


20221736 DATE:


2022/04/08




1 1ST FLOOR FRAMING LAYOUT 3/8" = 1'-0"









SUMMARY:		2N	10
FRAMING TYPE:	COMPOSITE TOTALJOIST	DRAWN BY:	N
DECK TYPE:	TOTALDECK		
TOPPING TYPE:	NORMAL WEIGHT CONCRETE	PROJECT NO.: 20221736 DATE:	
TOPPING THICKNESS:	4" U.N.O.		
T.O. CONCRETE ELEVATION:	18' - 1 5/8"	2022/04/08	
T.O. STEEL ELEVATION:	4" BELOW TOP OF SLAB U.N.O.	SCALE: As indicate	d






1) 02 - T.O. 2ND FLOOR HOLE CHECK 3/8" = 1'-0"

NOTES:
DIMENSIONS ARE TAKEN FROM STRUCTURAL SUPPORT TO START OF ROLL FORMED JOIST SECTION, AND THEN TO HOLE EACH LOCATION







PRINCETON, ON., N0J 1V0 W: www.ISPANsystems.com ALL DRAWINGS AND SPECIFICATIONS ARE THE PROPERTY OF ISPAN SYSTEMS LP AND MAY NOT BE USED OR REPRODUCED WITHOUT THE WRITTEN APPROVAL OF ISPAN SYSTEMS LP.

READ THE DRAWING IN CONJUNCTION WITH THE STRUCTURAL, ARCHITECTURAL, MECHANICAL, AND ELECTRICAL DRAWINGS. THE OWNER (OR APPOINTED REPRESENTATIVE) AND THE CONTRACTOR SHALL CHECK THE DRAWINGS FOR CONFLICTS IN DIMENSIONS AND LOCATIONS OF BUILDING COMPONENTS RELATED TO THE WORK SHOWN ON THE DRAWINGS. ANY DISCREPANCIES SHALL BE REPORTED TO ISPAN SYSTEMS LP BEFORE THE START OF THE WORK SHOWN.

DRAWINGS SHALL NOT BE SCALED.

CLIENT NAME

ELLIS HENRICKS

PROJECT NAME

HENRICKS HOME

541 BLOOMFIELD RIDGE S RD, ESN 474, NEW BRUNSWICK

SHEET NAME 2ND FLOOR JOIST HOLE LAYOUT PLAN


DRAWN BY: CHECKED: CURRENT ISSUE: ISSUED FOR CONSTRUCTION

PROJECT NO.: DRAWING NO.

20221736

DATE: 2022/04/08 SCALE:

As indicated



1 2ND FLOOR FRAMING LAYOUT 3/8" = 1'-0"

ISSUED FOR CONSTRUCTION NO. ISSUE DATE SYSTEMS 70 BRENTWOOD DRIVE PRINCETON, ON., NOJ 1V0 **F**: (519) 458-4460 W: www.ISPANsystems.com ALL DRAWINGS AND SPECIFICATIONS ARE THE PROPERTY OF ISPAN SYSTEMS LP AND MAY NOT BE USED OR REPRODUCED WITHOUT THE WRITTEN APPROVAL OF ISPAN SYSTEMS LP. READ THE DRAWING IN CONJUNCTION WITH THE STRUCTURAL, ARCHITECTURAL, MECHANICAL, AND ELECTRICAL DRAWINGS. THE OWNER (OR APPOINTED REPRESENTATIVE) AND THE CONTRACTOR SHALL CHECK THE DRAWINGS FOR CONFLICTS IN DIMENSIONS AND LOCATIONS OF BUILDING COMPONENTS RELATED TO THE WORK SHOWN ON THE DRAWINGS. ANY DISCREPANCIES SHALL BE REPORTED TO ISPAN SYSTEMS LP BEFORE THE START OF THE WORK SHOWN. DRAWINGS SHALL NOT BE SCALED. CLIENT NAME **ELLIS HENRICKS** PROJECT NAME HENRICKS HOME 541 BLOOMFIELD RIDGE S RD, ESN 474, NEW
BRUNSWICK SHEET NAME 2ND FLOOR BUNDLE PLAN DRAWN BY: CHECKED: CURRENT ISSUE: ISSUED FOR CONSTRUCTION PROJECT NO.: DRAWING NO. 20221736 DATE: 2022/04/08 SCALE: 3/8" = 1'-0"

